

Ecclesiastical (1899) Department.

ORDINARY MS.

G.O., No. 18

DATED 13 - 2 - 99

INDEXED.

[Despatch Abstract.]

Forwarding to the Ven^{ble} the
Archdeacon proos P.W.D. directing, with
remarks, that the sanction of the P.W.D.
be applied for to the proposed expenditure
of Rs. 13,490 on the construction of a residence
with out-houses for the Chaplain at
Wellington.

13-2-99

BACK PAPERS.

G.O.	No.	Department.	Date.	G.O.	No.	Department.	Date.


FURTHER PAPERS.

G.O.	No.	Department.	Date.	G.O.	No.	Department.	Date.
C.O. 338288 (P.W.D.) = 112 13-1-99							

53

BUILDINGS AND ROADS.
CIVIL WORKS.

Government {1899} of Madras. PUBLIC WORKS.



Recd. 8. 2. } 1899.
Regd. 8. 2. }

Enclosures

Spare copies

G.O., No. 275 W., 30th January 1899.

CS

Order no 18 of 13-2-99

communicated to

JANUARY. the Venible the Archbishop

9/2/99 9.2.99 10/2/99 11/2/99

To the Venible the Archbishop Dec 1899

Residence with out-houses for the Chaplain at Wellington

Directing, with remarks, that the sanction of the Government of India be applied for to the proposed expenditure of Rs. 13,490 on the construction of a —, Nilgiris.

GOVERNMENT OF MADRAS.
PUBLIC WORKS DEPARTMENT.

Buildings and Roads.
Civil Works.

READ—the following papers:—

From G. S. T. HARRIS, Esq., Consulting Architect to Government, to the Chief Engineer, Public Works Department, dated Chepak, 29th September 1898, No. 2055.

With reference to your memo., No. 2299 C., dated the 27th April 1898, I have the honour to submit plans and estimates, the latter amounting to Rs. 13,490, for constructing a residence and out-offices for the Chaplain at Wellington. The plans have received the approval of the Archdeacon.

Note by the Chief Engineer, Public Works Department.

The estimate, amounting to Rs. 13,490, for constructing a residence with out-offices for the Chaplain at Wellington, is recommended for sanction, subject to the following remarks.

2. The estimate for the main building provides for flooring the bath-room and verandah with 6" concrete and plastered with cement. The undersigned considers that flooring tiles laid in cement are preferable.

The width of each stall, viz., 8 feet in the out-house block, is also considered to be narrow. It should be made 10 feet.

(Signed) W. B. DEWINTON,
Chief Engineer.

16th December 1898.

ORDER—No. 275 W., dated 30th January 1899.

With his letter read above, the Consulting Architect submits a revised estimate, amounting to Rs. 13,490, for a residence with out-houses for the Chaplain at Wellington, Nilgiris. The estimate has been carefully prepared, and all possible reductions in cost and accommodation have been made; but as the rent calculated under Code rules exceeds 8 per cent of the salary of the occupant, the sanction of the Government of India will be applied for to the proposed expenditure.

2. The countersignature of the Venerable the Archdeacon to the estimate should be obtained before the work is put in hand.

3. The execution of the work will be entrusted to the Consulting Architect on receipt of sanction from the Government of India.

[Here enter No. 276 W., dated 30th January 1899.]

(True Extract.)

Under Secretary to Government.

To the Consulting Architect to Government, with enclosures.
" Superintending Engineer, IV Circle.
" Examiner, Public Works Accounts.
" Ecclesiastical Department.

Exd. T. K. Narayana Aiyangar.

When given for copying 13/2
When copied 14/2 1899.
When examined
When signed

READ AGAIN G.O., No. , DATED
189

CURRENT No.

ENCLOSURES TO G. No

ORDER OF GOVERNMENT A A A A A A A

LETTER OF GOVERNMENT.

STATEMENT WITH DITTO.

NOT FILED UP, BEING MEANT FOR DESPATCH
IN ORIGINAL.

N.B.—

A = Copy in full.
B = Not to be copied.
P = Copy abstract only.
Q = Copy heading only.