

1910
Educational (~~190~~) Department.

ORDINARY MS. Y

G.O., No. 116

DATED 12 — 3 — 10

(20)

[Despatch Abstract.]

C. M. S. College, ^{Tinnevely} Tinnevely Communi-
cating to the authorities of the C. M. S. College,
note by the Chief Engineer on the revised
plans and estimate amounting to
Rs 10,950 for the extension of the building
occupied by the College.

BACK PAPERS.

G.O.	No.	Department.	Date.	G.O.	No.	Department.	Date.

FURTHER PAPERS.

G.O.	No.	Department.	Date.	G.O.	No.	Department.	Date.

[E]

2,000-157-02

EDUCATIONAL DEPARTMENT.

CURRENT FILE.

✓

CONTENTS.

From	Number.	Date.	Pages.
[1809]	2-P 9	5958	29-7-09 1-19

[P. T. O. FOR PUT UP PAPERS.]

Papers of the department to which the current belongs.

EDUCATIONAL DEPARTMENT.

CURRENT No. 1809

Received 190 , Registered 190

Subject.

Recommending a grant of Rs. 3,650/- towards the cost of the extension of the building occupied by the C.M.S. College, Tinnevely.



ENCLOSURES.

No.

Spare copies.....

Ref on Cur No. 5 9 5 8 / 0 8.

Station M a d r a s, Dated the 29th September 1909.

From (Name) The Hon'ble Mr. A.G. Bourne, D.Sc, F.R.S, C.I.E.,

(Designation) Director of Public Instruction,

M a d r a s.

To The Secretary to the Government of Madras,

Educational Department.

Sir,

With reference to G. O. No. 852 Educational., dated 26th December 1908, I have the honour to submit the enclosed revised plans with estimate amounting to Rs. 10,950/- for the extension of the building occupied by the C. M. S. College, Tinnevely, and to recommend that a grant of Rs. 3,650/- be sanctioned to be paid when funds become available.

I have the honour to be,

S i r,

Your most obedient servant,

for Director of Public Instruction.

M.S.S.

20

Educational Department

CN. 1809.

Memo. N^o 1809-1

16-12-08

With reference to his letter No. C. N. 575 of 29th September 1909 submitting revised plans and estimate amounting to Rs 10,950/- for the extension of the building occupied by the C. M. S. College, Tirunelveli, the D.P. I is requested to obtain and submit to Govt further information on the following points:—

(i) In reply to para. 3 of the Consulting Architect's note of 18th November 1908 it is stated that the walls are of "brick masonry". Is this stock brick or country brick; and is it built in lime mortar or in mud?

(ii) The least diameters of the verandah columns in the ground floor and first floor should be figured, exclusive of the thickness of plaster, if any. It should also be stated ~~whether~~ whether there are any "through stones" in the columns and if ^{so} ~~there are~~, their thickness and distance apart should ^{be} given.

2. The plans and estimate are herewith forwarded for reference and return.

PP
13-12-09

80

13-12-09

Old

16/12

Pages of Jono 852 and
26-12-08

W.

To

The D.P. I with plans and estimate
(to be returned).

Sept with
encls
15/12/09

70196/10

DP 14/12

EDUCATIONAL DEPARTMENT.

Received 190 , Registered 1-2 190



Subject.

Submitting further information called for in Memo No. 1809-1 dated 14th December 1909 in connection with ^{the} extension of the building occupied by the C.M.S. College, Tinnevely.

ENCLOSURES.

No.

Spare copies

R.C. No. 5958/08

Station M a d r a s, Dated the 28th January 1910.

From (Name) The Hon'ble Mr. A. G. Bourne, B.Sc., F.R.S., C.I.E.,

(Designation) Director of Public Instruction,
M a d r a s.

To The Secretary to the Government of Madras,

Educational Department.

Sir,

No. 2 H /21-1-10.

From

The Principal,

C M. S. College, Tinnevelly,

To

The Director of Public Instruction,

M a d r a s.

Sir,

I have the honour to return the plans and estimate of the proposed rooms in the C.M.S. College, Tinnevelly, with the reply of the sub divisional officer to your Proceedings No. 5958 dated 15th January 1910. He came and inspected the building, and told me that unless the bricks needed are ready by the end of February, the work would have to be postponed for a year. I therefore have the honour to request that the matter may receive the earliest possible attention.

I have the honour to be,

S i r,

Your most obedient servant,

/Sd/ H. Schaffler,

Tinnevelly,
21-1-1910.

P r i n c i p a l.

R. C. No. 5958/08 dated 28th January 1910.

Submitted to Government with reference to Memorandum

Passing of C.F. No. 1809-1 Educational, dated 14th December 1909.

2. The plans and estimate are enclosed.

P. V. S.

For Director of Public Instruction.

X

From

Captain L. Donaghne,
Assistant Engineer, P. W. D.,
Palamcottah.

To

The Principal,
C. M. S. College,
Tinnevely.

Reference No. 5958 dated 15th January 1910 from the Director of
Public Instruction.

Sir,

I have the honour to inform you that stock bricks and
mortar have been used in the construction of the work.

2. The diameters of the pillars in the ground and first
floors have now been entered in the plan.

3. The through stones in the pillars are of cutstone 6"
thick and 2 feet apart.

I have the honour to be,

Sir,


Your most obedient servant,

/Sd/ L. Donaghne,

Assistant Engineer,

19 - 1 - 1910.

/True Copy/



For Director of Public Instruction.

P. V. S.



*Extension of the Ches. College
buildings, Lincolnton
Sustained*

8

NOTES.

C. No. 1809 From the D.P.D. No. 5958, dated 29-9-1909.

SUBJECT. Submitting the revised plans and estimate amounting to Rs 10,950 for extending the C. M. S. College buildings, Tinnevely.

The D.P.D. submits plans and estimate amounting to Rs 10,950 ^{for} ~~the cost of~~ extending the building occupied by the C. M. S. College, Tinnevely. ^{These are stated} They have been revised in accordance with the Consulting Architect's note of 18th November 1908 on page 4 of G.O. 852 of 26th December 1908.

2. Submitted that the plans and estimate may be forwarded to the P.W.D. Uo. for scrutiny.

5.10.09

5.10.09

P.W.D. Uo.

P.W. Department

The information given in reply to the previous reference is incomplete & further information is required before scrutiny can be completed.

1/ In reply to para 3 of the Consulting Architect's note it is stated that the walls are of "brick masonry" - Is this stock brick or country brick & is it built in lime mortar or in mud?

2/ The least diameters of the round arch columns in the ground floor & first floor

See page 2 of c/p.

W.

DP 5710
Ed No 1809-1
GOVERNMENT
8 OCT 1909
P.W.D. Uo. R. No. 819
7.10.09

should be figured, exclusion of the
thickness of plaster if any.
Also whether there are any "through
stones" in the columns & if so
their thickness & distance apart.
This information is required in order
to test for stability.

P. W. U. O. D No. 1400
Dated 8-12-09.



P.D.
10-12-09

Educational no. ¹³⁴ _{5/2}
Educational Department

The draft memo. placed below is submitted for
approval.

P.D. 13-12-09
N.D. 13-12-09

N. Chel
12/12

[Memo. no. 1809-1 dt 14-12-09.]

852 Chind 26-12-08.

4/ 3

11

Encl. no. 68

Regd 11-1-10.

Jan: 8. 10.

THE RETREAT,
TINNEVELLY.

11

Dear Dr. Wynch,

I hope you will not be
angry with me for laying before you a
matter of urgent need.

Some 3 years ago the London Com. of the
C.M.S. promised a grant of 500£ to the
Extension of the building of the College.
After a great deal of correspondence
the plans & estimates have been before
Govt. for several months. The London
Com. threaten to withdraw the grant, if
it is not used soon. This is my sore
need. The new rules necessitate
a lot of new classes, for wh. there is

Plans and estimates amounting to Rs 11, 150 for the extension of the building occupied by the C. M. S. College, Tirunelveli, were first received by Govt in October 1908. As they required revision they were returned to the D.P. I with G.O. 852 dated 26th December 1908. The revised plans and estimates were received in this office on 30th September 1909. There have again been returned to the D.P. I for furnishing certain further particulars required by the Consulting Architect on 14th December 1909. Please see memo.

DD 11.1.10 No. 1809-1, dated 14.12.09. slip X

DD 11.1.10

See
Oct
12/11

Page 1 of G.O. 852
26.12.08 W.

W.

Page 1 of C.F.

Vide C.F.'s note on pages 1 & 2
supra and also memo. on
page 2 of C.F.

A. Please send the D.O. letter to Mr Schaffte. I forget whether he is the Rev? H. Schaffte or not.

B. And then please send the papers to D.P.I. and ask him to push forward the matter as quickly as possible.

DD 15/1

Link.
14.1.10

D.O. No.68-1 dated 14th January 1910.

Dear Mr. Schaffter,

In reply to your letter of the 8th instant, I find that the plans and estimates were first received in October 1908. They were returned for revision to the Director of Public Instruction in the following December and received back last December.

The Consulting Architect still requires further particulars as regards the nature of "brick masonry" provided and also as regards the Verandah columns in order to test for stability. The information required was called for on the 14th of December last and has not yet been furnished. I am sending your letter on to the Director of Public Instruction and asking him to hurry up matters as much as possible.

Yours sincerely,

L.M. Wynch.

Many thanks for your kind congratulations on my recovery.

To

The Rev. H. Schaffter,
Tinnevelly.

157/10

A. The D.O. to Mr. Schaffler has issued. He is not the Revd. H. Schaffler - vide page 1527 of the Asylum Press Almanack for 1910.


2. The file may now be forwarded to the D.P.D. u.s. with reference to the Secretary's orders at B on page 4 supra.

PP
15.1.10

RD
15.1.10

Chd
1571

D.P.D. u.s.



2/571

Encl No 1809-3

15.1.10

Recd 16.1.10

u.s. No 3 of 18-1-10

Mr Schaffler can hardly blame us for the greater part of the delay. We asked in January for a revised plan and estimate and received it only in September - we are now waiting to hear about the further changes but the letter about this was despatched only on the 15th instant.

APJ 17.1.10

Submitted to Secretary for perusal of the D.P.D.'s remarks above.

RD
19.1.10

See
Chd
1571

San Hauk
Lubb
20/1/10

Printed
enc. 141
22-1-10

Urgent

NOTES.

Page

7

From the D.P.I. No 5958 of 28-1-1910

Vide page 23 of C.F.

The information now furnished by the D.P.I. was called for at the instance of the Public Works Department vide their note on pages 1+2 supra.

2. The file may be forwarded to the P.W.D. no. with the request that the scrutiny of the plans and estimates may be completed as early as possible and the file returned to this Department for the issue of orders regarding the building grant.

3. It is requested that this matter may be treated as 'Urgent'

ED
3.2.10

Chd
8/2

P.W.D. no.

PWD

ED no 180 3/2 4
3-2-10

DR
4.2.10
FEB 1910

The plans and estimate have been sent in to the Chief Engineer's Office. The pressures on the vertical columns being excessive the design is unsuitable. It is suggested that the mission be asked to have some other suitable proposal framed for providing the requisite accommodation.

Phil
3.3.10 [The pressures on the ground floor columns work at 6 tons per sq foot & they would probably crack, & the other are much overstressed & would not be safe.

It would probably be feasible to underpin the arches & put in suitable columns but this

Nothing from P.W. 2
always seems to take 3
days to get here
right to have
me on the 4th
H10/13



would require skilled supervision & the
mission may perhaps prefer to reconsider
the design & method of providing the
extra accommodation required.]

B.P. 10. ^{11/3}
4/3

Educational Department.

The draft order placed below is submitted for
approval.

1
Please type
H10/1
11.30 am
Typed.
10.3.

104
Draft submitted.
H10/13
7.3.10 9.3.10

Issued.
H10/13
11/3/10

[See No 116 dated 12. 3. 10]

11/3
H10/13
11/5/13

10

SP-EN-340
Regd 19-2-10

17



THE RETREAT,
TINNEVELLY.

17



Dear Mr. Wynch.

Reverting to your
letter No 68 dtd 14th Jan. I sent
in the plans & the Engineer's reply with
in a few days to the Director, & send down
to further delays. May I be allowed
once more to trouble you to see that the
matter as one of great urgency is
seen to as soon as possible.

With kind regards,

Yrs Sincerely
Hew Schaffer.

Per: 17.10
19/2/10

urgent

The file on the subject of the payment of a building grant to the C. M. S. College, Linnvelly, has been forwarded to the P.W.D. no. with this department's

Docket - M 40 No. 1809-4 of 3.2.10 for scrutiny of plans and estimates. Submitted that Mr. Schaffler's current letter may also be forwarded to that Deptt with the request that the scrutiny may be completed at an early date and the file returned to this department for the issue of orders

PP on the question of the grant applied for
22.2.10 ~~Sanctioning~~

AD
22.2.10

22/2 P.W.D. no

DP
22/2
EP 20 360-1
22.2.10

ds

The file is linked.

P.J.C.
22.2.10

23 FEB 1910
22/2

P.W.U.O. R No. 165
Dated 23. 2. 10.

19

Read again G.O. No. 852, dated 26th December 1908.

Read also -

C.No.1809, from the Director of Public Instruction, No.5958, d/29-9-09.

ORDER. No 116 dated 12.3.10
Mis.

The revised plans and estimate amounting to Rs.10,950 for the extension of the building occupied by the C.M.S. College, Tinnevely, received with the Director's letter R.O.C.No.5958, dated 29th September 1909, have been scrutinised by the Chief Engineer. The following note by the Chief Engineer should be communicated to the college authorities:-

Note.

"The pressures on the ground floor columns work out to over 9 tons per square foot and they would probably crush, and the others are much overloaded and would not be safe. It would probably be feasible to underfill the arches and put in suitable columns but this would require skilled supervision and the Mission may probably prefer to reconsider the design and method of providing the extra accommodation required."

Approved with plans & estimate 12/3/10

To the D.P.I. with plans and estimates.

H. 10/3

L. 11/3/10

When given for copying _____
When copied _____ } 190 .
When examined _____
When signed _____

READ AGAIN G.O., No. _____, DATED
190 .

CURRENT No.

ENCLOSURES TO C. No

ORDER OF GOVERNMENT.

A A A A A A A

LETTER OF GOVERNMENT.

STATEMENT WITH DITTO.

PAPERS NOT FILED UP, BEING MEANT FOR DESPATCH
IN ORIGINAL.

N.B.—

A = Copy in full.
B = Not to be copied.
P = Copy abstract only.
Q = Copy heading only.