

Edl (1913) Department.

Mrs. SERIES.

G.O., No. 705

DATED 31.7.1913

[Despatch Abstract.]

Grant. Recording correspondence with the Director of
Public Instruction regarding an application for a
award of a new building for the C.A.S. high school,
Palamcottah.

Stock No. 161.
5,000-80-6-11.

Educational
LOCAL AND MUNICIPAL DEPARTMENT.

C. 3356 ⁸⁶
2

Received  CURRENT No. 191 . Registered 13. 12. 1912

Subject.
Submitting for favourable consideration an application
for a grant in aid of constructing a new building for the
C.M.S. High School, Palamcottah, Tinnevely District.

ENCLOSURES.
No. _____
Spare copies _____

Ref on Current No 9 5 6 1 / 12,

Station M a d r a s, Dated the 11 December 1912.

From (Name) The Hon'ble Mr. A. G. Bourne, D.Sc. F.R.S.C.I.E.

(Designation) Director of Public Instruction,
M a d r a s

To the Secretary to the Government of Madras,
Local and Municipal Department.

Sir, N.V.S.

Handwritten signature/initials



Ref on Cur No. 9561/12 dated ⁱⁿ 11 December 12.

Submitted to Government and recommended.

2. The cost of the new school house, compound-wall and gymnasium amounts to Rs 80,750/- and that of the hostel and out-houses to Rs 58,950/- . A half grant on this may be sanctioned under the Grant-in-Aid Code.

R.A. Arum.

For Director of Public Instruction.

N.V.S.

18/12/12

129700

No. 866C

NOTE BY THE CHIEF ENGINEER, P.W.D. d/- 29.1.13

The Director of Public Instruction submits for sanction plans and estimate amounting to Rs.1,39,700 for constructing a new building for the C.M.S. High School, Palamcottah, Tinnevely District. The plans are defective in many respects and unfit for scrutiny. Some of the defects are:-

(1) Plans Nos.(2) & (3)

The section line on the plan of the ground floor differs from that shewn on the plan of the first floor. In section on A. B" (Plan No.3) the doors in the verandahs (front) and the turret with dome should be omitted. The turrets and domes are not shown in the elevation (Plan No.2).

(2) The girders and joists supporting the floors and roofs are not figured.

(This remark holds good in the case of the subsidiary buildings also)

(3) The details for the construction of the main stairs are not clear.

(4) It is not understood how the octagonal turrets and spiral stairs are supported.

(5) The ventilators shewn in elevation over the verandah arches serve no useful purpose and would be likely to cause cracks or distortions near the key.

(6) The diameters of circular masonry columns in the 1st floor are not figured.

Clusters of 4 or 5 columns in corners might well be replaced by solid walls.

(7) The width of the building is marked as 157'-0 on the plan of the ground floor and 99'-3" on the plan of the 1st floor.

-2X 5
(8) The thickness of the wall between rooms 8 & 9 on ground plan should be figured and the materials of the wall should be described.

(9) The length of the front wall (7) is marked 137' - 10½" on the plan of the 1st floor and that of the corresponding verandah on the rear-side 118' - 0".

(10) The distance between the verandahs of the wings is shown in plan (No.3) as 98' - 4½" and the distance between the exterior walls of main stair case rooms as 99' - 0"

(11) Plan No.4 (Large dining Hall)

This is 150'-0" x 15'-0". Owing to the great length, the longitudinal walls should have pilasters or buttresses at intervals of about 10'-0".

(12) Boarding house- Plan No.(6)

The slope of the verandah roof is insufficient for a width of 10'-0", the roof covering being flat and pan-tiles (provided for in estimate). Purlins are not shewn and the dimensions of the roof timber not figured. The doors are wrongly shewn in "Section on A.B".

With the above remarks the plans and estimate may be returned to the Director of Public Instruction with the request that they should be thoroughly revised by some competent professional man and resubmitted ~~xxx~~ in a shape fit for scrutiny.

(sd) C. A. Smith

b
Educational Dept.
[CM 3356]

Memo 3356-1 Est of 4. 2. 13

The plans and estimates for
the construction of a new building
for the C. H. S. High School, Palam-
cottah, received with the S.P.D.
letter R.O.C. No 9564/12 dated 11th
December 1912 are returned ^{to him} for
resubmission after revision
in accordance with the
Chief Engineer's note No 866C
dated 29th January 1913, a
copy of which is enclosed.

SN
1.2.13

CR
27/1/13

Let
3.2.13

2/3/✓

Voted in C.B. ^{10/11/13}

To
The S.P.D. with plans
+ estimates + copy of C.E.'s note

2/2/13

Sept 4-2-13
M.


Reminded 4/4/13
to 26/6/13.

EDUCATIONAL
LOCAL AND MUNICIPAL DEPARTMENT.

U.F.D.—80-1

CURRENT No. 232088

Received 191 , Registered 2877 1913.



Subject.

Stating that the authorities of the C.M.S. High School, Palamcottah, have abandoned the scheme regarding construction of a new building for their school.

ENCLOSURES

No.

Spare copies

No. 4212 of 13

Station Madras, Dated the 24th July 1913

From (Name) The Hon'ble Sir Alfred Gibbs Bourne D.Sc., F.R.S., K.C.I.E.,

(Designation) Director of Public Instruction.

To the Secretary to the Government of Madras,
EDUCATIONAL ~~Local and Municipal~~ Department.

Sir,

With reference to your memorandum No.3356-1 Educational dated 4th February 1913 regarding the construction of a new building for the C.M.S. High School, Palamcottah, I have the honour to inform you that the management have abandoned the scheme and are contemplating a new scheme which may take some time to mature.

I have the honour to be,

Sir,

Your most obedient servant,

N. Abrieve

V.S.

for Director of Public Instruction.

Page 5 of CF.

PA

12/10/13

8

C. No. 3356 From the DPD No 9561/12 dated 11-12-1912.

SUBJECT. Building front for the Church mission
Society high school, Palamcottah.

The plans and estimates may be forwarded
to the P.W.D. for scrutiny.

DPD 13.12.12 CA 14.12.12 P.W.D. 14.12.12

No. 3356-1 Est

Cus 83607 14.12.12

P. W. U. O. R No. 2328
Dated 18.12.12



P.W.D.

Note by the Chief Engineer P.W.D. 29-1-13

Copy made to the Chief

DPD

Chief Engineer In his note read above the
Chief Engineer Enclides that the plans & estimates are
not fit for scrutiny and suggests that they may
be returned to the P.W.D. for revision. With the note
read above, the file may be returned to Est.
for necessary action

TSN 24.1.13



24.1.13

P.W. No 83607-1
20.1.13

With 2 proposals
of plans.

24.1.13

Est. 20

SK
Received from
a hand from
14.1.13

Ret Sept

Draft memo to the D.P.D is submitted for approval.

SK CR
1.2.13 21/2/13

LM
3.2.13

page 5 of CF.

page 6 of CF.

[memo. no. 3356-1 Sldy 4-2-13].

From the D.P.D, Rec no. 4212 of 24th July 1913.

The papers may be recorded. A draft order is submitted for approval.

PP CR
30.7.13 30/7/13

AK
30.7.13

W.C.
CR
17/12
6pm

” ” ” ” ” ” 191

2320 279 4212 24-7-1913

No. 705, dated 31. 7. 1913

Mr

Recorded

$\frac{PA}{30.7.13} \cdot \frac{CA}{30.7.13}$

30-7-13

To, the Hon'ble (200)

When given for copying _____ }
 When copied _____ } 10
 When examined _____ }
 When signed _____ }

READ AGAIN G.O. No. _____, DATED
 12 _____

CURRENT No. _____

ENCLOSURES TO G. No. _____

ORDER OF GOVERNMENT.

A A A A A A A

LETTERS OF GOVERNMENT.

STATEMENT WITH DETAIL.

PAPERS NOT WILDED UP, BEING MEANT FOR DESPATCH
 IN ORIGINAL.

N.B.—

A = Copy in full.
 B = Not to be copied.
 P = Copy abstract only.
 Q = Copy heading only.