

Home (1918) Department.
Education
Ordinary SERIES.

G.O. No. 288

DATED 27-2-18

INDEXED

[Despatch Abstract.]

Kalavala Thiruvengadathan Chetti's Girls school, Georgetown, Madras.
Approving the design for tiffin rooms for the

PAPERS PUT UP WITH CURRENT No. _____

Papers of the department to which the current belongs.

Number.	Date.	Original (= O) or spare copy (= S.O.)	Remarks. (In this column such of the papers as have been removed for copying, printing, etc., should be marked with a cross.)	Initials of Referencer with date in token of return to Reference department.

Papers of other departments.

Department.	Number	Date.	Original (= O) or spare copy (= S.O.)	Initials with date of (1) Referencer acknowledging returns of the paper concerned or (2) Despatches to denote the return of the papers to the department concerned.

Please quote this in the reply.

Ref. on C. No. 8027 of 1916
Despatch TO GOVERNMENT



The Old College,

Dated 19.5.1917

1285
21/5/17

THE HON'BLE MR. J. H. Stone, M.A., F.R.H.S., C.I.E.,

DIRECTOR OF PUBLIC INSTRUCTION,

Madras,

To

The Chief Engineer,

Public Works Department,

Enclosures.

M A D R A S.

Sir,

I have the honour to forward for favour of your approval a design for tiffin rooms in connection with the kalavala Thiruvengadathan Chetty's Girls' School, Georgetown, Madras, as required in paragraph IV, Clause (iii) of your Note No. 1754 C dated 9th March 1917.

I have the honour to be,

Sir,

Your most obedient Servant,

Raani

for Director of Public Instruction

Y. V.

on 24/5
2017

IV of the Chief Engineer's note No.1754-
G., dated 9th March 1917 embodied in G.O.
No.335-Educational, dated 12th March 1917
the Director of Public Instruction sub-
mits for approval a drawing for the tiffin
rooms for Thiruvengadathan Chetti's Girls'
School, George Town, Madras.

(1) The necessity for five small rooms is not apparent, the number of girls for whom the rooms are intended is not stated.

(2) Why do the foundations for walls A & B differ from each other?

(3) What kind of roof is proposed for the verandah?

(4) what wood is proposed for roof timbers ? And verandan posts ?

(5) What is the thickness of the parapet wall ?

(6) Why should not windows be provided in walls marked A ?

III. The verandan posts should be rearranged so that they may be at equidistant

distant intervals without at the same time obstructing doors and windows.

IV. The parapet wall may be reduced from 2'-6" to about 1'-0" in height.

V. No additional grant has been applied for towards the cost of constructing the tiffin rooms.

VI. The site plan is inadequate. It should show the position of the tiffin rooms in relation to the class rooms and the means of communication between the two buildings.

VII. With these remarks the drawing is returned for revision. In this connection attention is drawn to Circular Memo No. 116-C., dated 4th January 1913.

S.B.M.
1/6/17
24/5/17

(Sd) S.B. Murray
Chief Engineer

Home (Eng) Dept.

Cto. 447B.

Memo. 447B-1 27.6.17

The design for tiffin rooms for the Kalavala Thiruvengadathan Chettis' girls' school, Georgetown, Madras, forwarded by the S.P.D. with his letter to the Chief Engineer, No. 8027 of the 19.5.17 is returned to him for resubmission after revision in accordance with the Chief Engineer's note No. 205.Dd, the 12th June 1917 (Copy enclosed).

R.P.
29/6

To,

the S.P.D. with design + copy of C.E.'s note.

(Please see R's orders in the note file)

Madras 25/6
Sd/-
Received 2/7
Designs 2/7
R.P. 4/7
File will be sent to the S.P.D. 4/7

See with the Engineer
has been mislaid and not
easily for the coming. 1/7
4/7
10/7

Home (Education)

DEPARTMENT.



Received 8 JAN 1918 191 Registered 8 191

Subject.

Submitting for approval fresh plans and estimates for tiffin rooms received from the Correspondent of the Kalavala Tiruvengathan Chetti's girls' school, Georgetown, Madras.

ENCLOS RES.

No.

Ref. on Cur. No. No. 8927/16,

Spare copies

Station Madras, Dated the 5th January 1918

From (Name) The Hon. Mr. J. H. Stone, M.A.F.R.H.S.C.I.E.

(Designation) Director of Public Instruction.

To The Secretary to the Government of Madras,

Home (Education)

Department.

Sir,

With reference to your memorandum No. 447 B-1, dated 26th June 1917, I have the honour to submit herewith for approval fresh plans and estimates for tiffin rooms received from the Correspondent of the Kalavala Thiruvengadathan Chetti's Girls' school, Georgetown, Madras.

I have the honour to be,

S i r,


Your most obedient servant,

R. A. Anand

for Director of Public Instruction.

P.V.S. 5/1.

5.1.18.



PUBLIC WORKS DEPARTMENT.

1257 C.D. 20-28
E. W. NOTE.

praut
pleaut
abund
With reference to the Note by the Chief Engineer No. 205-D dated 12-6-1917 embodied in Government (Home-Educational) Memo. No. 447 B-1 dated 26-6-1917, the Director of Public Instruction submits for approval ^{a drawing and} a detailed estimate amounting to Rs. 5,500 for constructing tiffin rooms for the ~~at~~ ^{at} Malavata Thiruvengadathan Chetty Girls' School, Georgetown, Madras.

II. The drawing and the estimate have been scrutinized in the Chief Engineer's office, and the following alterations carried out :-

- (1) Altering where necessary the sizes of floor and roof timbers.
- (2) Omitting the ridge beams, and providing collars to tie the feet of rafters supporting the roof.
- (3) Increasing the diameter of the verandah columns ^{in the} Ground floor from 1'-0" to 1'-3".
- (4) Making provision for a masonry stair and verandah railing in the 1st floor which are omitted in the estimate.
- (5) Correcting an error in the total of figures in the abstract of the estimate:— (Rs. 4,372 should be Rs. 5,372).

By these alterations the total amount of the estimate is increased from Rs. 5,500 to Rs. 7,060.

III. The height of basement is 2'-6" as indicated on the drawing; ~~shown~~ whereas

7
a height of 2 ft. is provided for in the estimate. It is considered that the latter height is sufficient and the drawing has been corrected to agree with the estimate.

IV. If, as shown on the drawing, a wall of the adjoining house abuts the rear wall of the proposed rooms, the ventilators provided in the latter wall serve no useful purpose, and may be omitted.

V. The details of the stairs are not shown; the Superintending Engineer should satisfy himself that it is properly constructed and that the foundations proposed are suitable.

VI With these remarks, the drawing and the estimate, as altered in the Chief Engineer's office, the latter amounting to Rs.7,060 are recommended for approval.

CPA
15/2/68

(Sd) S.B. Murray
Chief Engineer Port

NOTES.

P.W.D.

pl4 Cx- 1285-1285 From the S.D.I. Doc No 27/16 S 19.5.17
 pp2-34 Note by the Chief Engineer P.W.D. No 1285-1285/17-1285-17

design for kiffin rooms K.T.C. girls' school

Sg Leary

With reference to para IV (iii) of the Chief Engineer's note No 1754 C Sg Leary March 1917 the S.D.I. submits a fresh design for kiffin rooms for the K.T.C. girls' school, George Town. The design has been examined by the Chief Engineer & his remarks are embodied in the Chief Engineer's notes read above. Submitted that the file may be sent to Edl for necessary action.

Mr 8647 28/6

XD


Edl cc

klc 11.6.17

P.W.D. No. 1285-1285-1
 12-6-17

Cm 447 B 80

12.6.17



Home (200) Dept 4.


pages of C.F.

The D.P.D.'s letter was addressed to the Chief Engineer direct. The information required by the Ch. Engineer in his note on pages 2 & 3 of C.F. can therefore be obtained by him direct from the D.P.D. without the intervention of Home (200). In this view the file may be returned to Prod for disposal.

16.6.17 JH
D.P.D.
(C)

Such correspondence usually passes this way. The design for lifting rooms has been sent with exp. to P.O. 335 21 of 12-3-17. Please forward a memo. here

CR
20/6/17



A draft memo. is submitted for approval. 2. The Prod does not appear to have put up the design in the file. As it has to be returned to the D.P.D. that department may be requested to put it up.

20.6.17 JH
D.P.D.

CR
25/6/17

[memo. no. 447 B-1 4 of 26.6.17].

Returned to E.C.F.

From the D.P.D. Rec No. 327/168 of 5-1-18.

Senior S. P. M.
4.10.17

The revised plans and estimate now submitted by the D.P.D. may be forwarded to Prod for scrutiny.

To Supt. E.C.F. Dept
20/10/18

CR
21.1.18

CR
21.1.18

P.W.D. 200

1918

1918 Feb 20-2-18

By Secy

The revised plans & estimate have been submitted by the Chief Engineer whose remarks are contained in his note read above. The file may be forwarded to Home (E.M.) for the issue of orders.

20. 2. 1918

1918 Feb 20-2-18



1918 Feb 20

Home (E.M.) Dept

The design for tiffin zone may be approved - The

p. 50. F. does not recommend any additional grant.

2. A draft order is submitted for approval

22. 2. 18.

26. 2. 18

27. 2. 18

1918 Feb 20-2-18

1918 Feb 20-2-18

1918 Feb 20-2-18

1918 Feb 20-2-18

1918 Feb 20-2-18

1918 Feb 20-2-18

1918 Feb 20-2-18

1918 Feb 20-2-18

1918 Feb 20-2-18

1918 Feb 20-2-18

Home (Son) DEPARTMENT.

Kolavala Thiruvayyadathan Chetti's girls' school, G.T. madras

Approving the design for living rooms for the —

READ AGAIN G.O. No. 335 Home, dated the 12-3-1917
(En)

” ” ” ” ” ” [9]

READ ALSO:—

C. No. 447 B, From the _____, No. _____, dated _____ 191

35B 5P9 8027/6 5-1-1918

” ” ” ” ” ” ” 191

ORDER.

No. 288, dated the 27. 2. 1918

Mr's

The design for constructing
liffin rooms for the Kalava Thiru-
-venkata than Chetti's girls' school,
Georgetown, Madras, submitted
with the D.P. 2's letter No. 8027 of
the 5-1-18 is approved subject
to the remarks of the Chief
Engineer in his note No. 1257 C of
the 20-2-18 (copy enclosed).

Pa

22.2.18

$$\frac{CR}{23.2 \cdot 18}$$

A

76. 2. 18

27/2/18

Wick 28/12

To, The D.P.D with Plans & Estimates returned
- P. W. D.

When given for copying
 When copied
 When examined
 When signed

191

4/2/18

READ AGAIN G.O. No.
 191

DATED

CURRENT No.

ENCLOSURES TO C. No.

ORDER OF GOVERNMENT

A A A A A A A

LETTER OF GOVERNMENT

STATEMENT WITH DITTO.

PAYERS NOT FILED UP, BEING MEANT FOR DESPATCH
 IN ORIGINAL

N.B. -

- A - Copy in full.
- B - Not to be copied.
- P - Copy abstract only.
- Q - Copy heading only.