

Home (1918) Department.
(Education)

Ordinary SERIES.

G.O. No. 1410

DATED 4-11-1918.

INDEXED

[Despatch Abstract.]

Building Grant.

Recording papers relating to an application for
-----on account of the extensions to the St. Joseph's
European Boys High School, Calicut which was not complied with
owing to the inability of the school authorities to proceed with
the building operations.

BACK PAPERS.

G.O.	No.	Department.	Date.	G.O.	No.	Department.	Date.

FURTHER PAPERS.

G.O.	No.	Department.	Date.	G.O.	No.	Department.	Date.

C.F.—20.

Home (Education)

DEPARTMENT.

CN^o 1200 B

Received

191

Registered

191

Subject.

Recommending a half grant for the extension to the Buildings of St. Joseph's European Boys High school, Calicut



ENCLOSURES

No.

Spare copies

No. 3704/18

Station MADRAS.

Dated the

5 June 1918.

191

From (Name) The Hon'ble Mr. J.H. Stone, M.A., F.R.H.S.,

C.I.E.,

(Designation) Director of Public Instruction

To The Secretary to the Government of Madras,

Home (Education) Department.

Sir,

I have the honour to submit the enclosed plan (bearing No.26 E/1) with estimates amounting to Rs.7,000 for extensions to the building occupied by St. Joseph's European Boys' High school, Calicut, and to recommend that under article 57 of the Code of Regulations for European schools a grant not exceeding half of the total cost may be sanctioned payable when funds are available. The necessity for the extensions has been explained in the enclosed copy of the correspondent's letter No.21/18 dated 8-3-1918. A two-thirds grant is requested but as Calicut hardly comes under two-thirds grant, criterion contemplated

contemplated in Article 57 of the Code of Regulations for European schools, I do not recommend more than a half grant. I may mention that only a half grant was sanctioned towards the cost of acquisition of a plot of land for the use of the school. Vide G.O.No.146, Home (Education) dated 8-2-1918.

2. The correspondent has been asked to submit a site plan and one more copy of the plan showing the proposed extensions, and these will be submitted on receipt.

I have the honour to be,

Sir,

Your most obedient servant,

G. Krishnamoorti

B.R.

For Director of Public Instruction,

Copy of letter from the Correspondent, St. Joseph's European Boys High school, Calicut to the Inspector of European and Training schools No.21/18 dated 8-3-18.

I have the honour to submit herewith an application for building grant under article 50 (a) of the Code of Regulations for European schools towards extension to the existing school buildings. The said extension is to consist of two halls (see plan) an upper hall i.e., the continuation of the High school Physical Laboratory; a lower hall, to be used either for the manual training class or as Library or reading room for teachers and pupils.

The need of extension of the Physical Laboratory has been long felt. The present laboratory (for Physics and Botany) a room of 20' x 16' is much too small. The almirahs the demonstration and the work-tables leave hardly any room for the pupils and in consequence proper supervision of the practical work is next to impossible. Besides, some additional room must be provided for the teaching of Chemistry, a subject which eventually will be taken up along with Physics.

This

This application (with estimates and plans) was originally submitted in 1914 (cf R.O.No.4/1914 and your office letter of 1st May 1915) and is renewed now in the hope that it may meet with your approval.

The present revised estimates come up to a much higher total, than the original ones, owing to the rise in the prices of many some of the materials (such as iron and cement) but as this sad state of things seems likely to continue for some time to come, the management, relying on the good will of the Department, whereof they gratefully acknowledged to have received many signal proofs, have decided to submit to necessity and to undertake the work without any further delay provided a substantial grant is sanctioned.

The Management will procure the necessary funds to begin the work and hereby bind themselves to comply with all the conditions regulating building Grants.

You are aware of the heavy expenses partly undergone, and partly to be undergone by the management in connection with the various improvement schemes, detailed in my letter dated 19th January 1918. I have therefore the honour to request you to be so good as to recommend a grant of two-thirds of the cost of the contemplated extension.

B.R.

G. Krishnamoorti
For Director of Public Instruction

E. W. N O T E.

of
The Director/Public Instruction submits
a drawing bearing D.P.I.No.26-E/1 and a
detailed estimate amounting to Rs.7,000 for
extending the building occupied by St. Joseph's
European boys' High School, Calicut.

II. The drawing and the estimate have been
examined in the Chief Engineer's office, and
it is observed that they contain various
defects a few of which are summarized in the
following remarks :-

- (1) It is proposed to extend the stein-
ing of the existing wall and to construct
thereon one of the walls carrying a two-
storeyed building. This proposal is object-
ionable. The additional room should be con-
structed at least 15'-0" away from the well.
- (2) The pressures at plinth level on
piers marked X, Y, on D.P.I.No.26-E/1 are 3
tons and $3\frac{1}{2}$ tons per sq. ft. respectively, the
permissible limit for laterite on the west
coast being only 2 tons per sq. ft.
- (3) As steel girders are expensive and
difficult to be had, a wooden floor or a
flat, terraced floor supported on wooden
beams and joists is recommended to be pro-
vided instead of a jack-arched terrace floor.
- (4) As designed, the rafters supporting
the roof are tied by 2 collars. As the
clear span of the room in the 1st floor is
16'-4 $\frac{1}{2}$ ", the rafters should be supported by
purlins resting on king post trusses.
- (5) A site plan shewing the proposed

proposed extension and the existing building with all surroundings should be submitted.

III. With these remarks, the drawing and the estimate are returned for revision.

Handwritten notes on the left page, including dates like 28/6/18 and various signatures and initials.

NOTES.

Home (284) Def 4.

C.N. 1200 B/18.

Memo. No. 1200 B-2
5-7-18

The plan and estimates for extensions to the building occupied by St Joseph's European boy's high school, Calicut, received with the S.P.D. letter R.C. No. 3704/18 of the 5.6.18 are returned to him for resubmission after revision in accordance with the Chief Engineer's note No. 303 D of the 3-7-18 (Copy enclosed).

4-7-18

Handwritten signature or initials.


Handwritten note: The S.P.D. with plan and estimate & copy of the C.E.'s note.

(Remind on the expiry of a month after despatch)

Home (Education)

DEPARTMENT.

Received



191

Registered

31.001 1918

Subject.

Reporting the inability of the managing body of the St. Joseph's European Boys' High School, Calicut, to proceed with the work of extensions to the building.

ENCLOSURES
No. _____
Spare copies _____

Re No. 3704/18

Station M A D R A S, Dated the 30-10-1918

From (Name) The Honourable Mr. H.S. Duncan, M.A.
(Designation) Ag. Director of Public Instruction.

To The Secretary to the Government of Madras,
Home (Education) Department.

Sir,

With reference to Government Memo No. 1200 B-2 Home (Education) dated 5th July 1918 returning for resubmission after revision the plan and estimates for extensions to the building occupied by St. Joseph's European Boys' High School, Calicut, I have the honour to state that the Correspondent of the School writes that owing to lack of funds the managing body are unable to proceed with the work of extensions to the building at present and requests that the matter may be put

off

Subject.

Building grant to St. Joseph's European Boys' High School, Calicut.

Home (Edn) Department

[C.N. 1200 B] From the App, Re No 3704/18 & the S-6.

Submitted that the plans and estimate may be forwarded to the P.W.D. for scrutiny.

8.6.18

P.W.D. no.

P. 100

Note by the Chief Engineer


M-4-54

3030 337.08

DS

The plans and estimate have been scrutinized by the Chief Engineer and his remarks thereon are contained in his note read above.

The file may now be returned to the Home (Edn) Dept with reference to para III of the CE's note.



P.W.D. No. 1405 B-1

Home Edn no.

with a plan & est kept folder

13.7.18

off to more favourable times. In these circumstances the application for grant may be considered as withdrawn and the Correspondent will be informed accordingly.

I have the honour to be,

Sir,

Your most obedient servant,

R. A. Griener

for Director of Public Instruction.

SV

US

Home (Eon) Department

A draft memo. is submitted for approval.

PPD
4.7.18.

True L.S.


p. 7. C.p.

[no. 225813]. From the D.P.D., Re No. 3204 / 18 & 30.10.18.

In the circumstances stated in the
D.P.D.'s letter read above, the papers may be
Order 1410 d/ 4.11.18.
his Recorded

PPD
1.11.18.
L.S.
1.11.18

L.S.
11.11.18
To, Pres. Board
Mrs. 6.11.18
The D.P.D. (P70)



When given for copying

When copied

When examined

When signed

191

READ AGAIN G.O. No.
191

DATED

CURRENT No.

ENCLOSURES TO C. No.

ORDER OF GOVERNMENT

A A A A A A A

LETTER OF GOVERNMENT

STATEMENT WITH LITTO.

PAPERS NOT FILED UP, BEING MEANT FOR DISPATCH
IN ORIGINAL.

N.B.—

A = Copy in full.

B = Not to be copied.

P = Copy abstract only.

Q = Copy heading only.