

Howe (1919) Department.
Education
Ordinary SERIES.

G.O. No. 847

DATED

5-7-19

INDEXED

[Despatch Abstract.]

Building grant:

Sanctioning a grant not exceeding one-half of the actual expenditure nor Rs.2,165 towards the cost of constructing a hostel with out-houses for the Danish Mission High school, Tiruvannamalai.

BACK PAPERS.

G.O.	No.	Department.	Date.	G.O.	No.	Department.	Date.

FURTHER PAPERS.

G.O.	No.	Department.	Date.	G.O.	No.	Department.	Date.

HOME (EDUCATION)

DEPARTMENT.

Re. 2513/B
28.11.68

191 Registered 191



Subject.

Submitting plans and estimates for the construction of a Hostel for the Danish Mission High School, Tiruvannamalai, and recommending a half grant.

ENCLOSURES

No.

R. C. No. 9421/16

Spare copies

Station Madras, Dated the 26 November 1916

From (Name) the Hon'ble Mr. H. S. Duncan, I. A.

(Designation) Ag. Director of Public Instruction, MADRAS.

To The Secretary to the Government of Madras,

HOME (EDUCATION) Department.

Sir,

I have the honour to submit herewith the plans bearing Nos. 232 (A) and 232 (B) with estimates amounting to Rs. 16,738 including the cost of site for the construction of a hostel in connection with the Danish Mission High School, Tiruvannamalai, and to recommend that a grant not exceeding one-half of the total cost may be sanctioned, to be paid when funds become available.

2. The title deeds relating to the site have been called for and will be sent on receipt to the Government Solicitor.

3. The location of the sick room close to the dining room is not desirable and the Management will be asked to use this room as a dormitory for three pupils.

I have the honour to be,
Sir,

Your most obedient Servant,

R. A. Arum
for Director of Public Instruction,

Y. V. /23/11
Y. V. /23/11

1509C 427-2-19.

E. V. NOTE.

The Director of Public Instruction submits two drawings bearing D.P.I. Nos. 232-A and 232-B and a detailed estimate amounting to Rs. 16,788/- for a grant-in-aid towards the cost of constructing a hostel with out-houses for the Danish Mission High School, Tiruvannamalai, South Arcot District.

II. The Drawings and ^{the} estimate have been examined in the Chief Engineer's office and it is observed that they contain ^{some} defects ~~some~~ of which are noted below:-

(1) The ridge piece in the upper floor in corner room 'R' is not supported properly and it would be better and safer if the wall marked 'W' is shifted a little as shown on the plan D.P.I. No. 232-B, so that the ridge piece may be supported on the wall.

(2) In the absence of special reasons for a high basement, its height may be reduced from $4\frac{1}{2}$ to 2 feet.

(3) Dimensions for doors and windows verandah piers and openings are not noted on the plan.

(4) The height of masonry parapet in ground and first floor verandahs may be reduced from 3'-6" to 2'-6".

(5) As there is not sufficient headway over the steps in the present arrangement of staircase, the steps are to be shifted back as shown on the plan.

(6) Information as to the number of students to be accommodated in each room is not given.

(7) Considering the excellent nature of the sub soil moranbu, the depth of foundations given, appears unnecessary and may be reduced with saving in cost. The sand filling is for the same reason unnecessary.

(8) In accordance with the Circular Memo. No. 116-C dated 4-1-1913 the drawings and the estimate should be signed by a recognised Engineer or Architect, whereas in this case the drawings are signed by a retired Sub Engineer and the estimate by a contractor, and there is no specification and calculations attached to the estimate.

III. The reason for the omission of bath rooms, latrines, fuel and store rooms has not been explained.

IV. With these remarks, the plans and estimate are returned for revision.

(sd) W Hutton
ag. Chief Engineer
(B.C.R.)

6.25.13/B.

Memo.

25.13/18-2

5.3.19

The plans and

estimates for the construction of a hostel in connection with the Danish Mission High School, Tiruvannamalai, received with the letter from the D. P. S. R. C. 9421/18, dt/ 26th Nov. 1918 are returned to him for re-submission after revision in accordance with the Chief Engineer's note No. 1599-C dt/ 27th Feb. 19 (copy enclosed).

2 The attention of the School authorities should also be drawn to S. No. 1596 Home (Ed.), dt/ 13th Dec. 1918

(VII)

1.2.19

3.3.19

To the D. P. S. (with plans & Estimates & C. E. S. note at 11.24 to C. E.)

To be reviewed 3 months hence.

(cib) enatt

8/5/25.2

enatt

Amo amalf att

ahanthana att of ahamitaa
 this nation no, we ideal is go
 leader of a nation learnatt att
 ahanthana, ahamitaa
 a. att mass att att att
 P. att this (b. 31) 18 2 P. 3. 4
 tof. mial a hanantaa
 nationa att to uise
 att this, ahamitaa
 a. go. 1. att ahamitaa
 (aahana, go. 2) P. att 18 18
 att go nationa att
 a. ahamitaa ahamitaa
 18 18. att. att ahamitaa
 a. att 18 18 (cib) enatt


(11V)

Home (Education) DEPARTMENT.

C.F.-20.

906 Ed 8750

Received 191 Registered 191



Subject.

Resubmitting plans and estimates for the construction of a hostel for the Danish Mission High School, Tiruvannamalai.

ENCLOSURES.
No. _____
Spare copies _____

No. 9421/18

Station Madras, Dated the 1-5-1919

From (Name) The Honourable Mr. R. Littlehales, M.A.,
 (Designation) Ag. Director of Public Instruction

To The Secretary to the Government of Madras,
 Home (Education) Department.

Sir,

p. 5 and

With reference to your memorandum No. 2513 B/18-2 dated 5th March 1919 in connection with the construction of a hostel for the Danish Mission High School, Tiruvannamalai, I have the honour to resubmit herewith the plans and estimates with the necessary alterations made therein. A copy of the Principal's letter dated April 1919 is also sent herewith.

I have the honour to be,
 Sir,
 Your most obedient servant,

Ramane

for Director of Public Instruction.

9/5/25
S V

Letter from the Rev E. Hoff, Principal, Danish Mission High School, Tiruvannamalai to the Director of Public Instruction, Madras dated April 1919.

I have the honour to forward herewith the plans and estimates returned with your letter No. R.O.C 9421/18 dated 15-3-19 with the necessary corrections and explanations.

1. The ridge piece in the upper floor in corner Room R is not supported properly and it would be better and safe if the wall marked W is shifted a little as shown on the plan D.P.I. No. 232 B so that the ridge piece may be supported on the wall. Done accordingly.
2. In the absence of special reasons for a high basement its height may be reduced from $3\frac{1}{2}$ to 2 feet. The ground where the building is to be constructed is lower than the road level by $1\frac{1}{2}$ feet. The filling is to be to that level.
3. Dimensions for ~~doors~~ doors and windows verandah piers and openings are not noted on the plan. Noted.
4. The height of the masonry parapet in ground and first floor verandahs may be reduced from 3'-6" to 2'-6" Done accordingly.
5. As there is not sufficient headway over the steps in the present arrangement of staircase, the steps are to be shifted back as shown in the plan. Done accordingly.
6. Information as to the number of students to be accommodated in each room is not given. 21 students (3 in each)
7. Considering the excellent nature of the sub soil moranbu, the depth of foundation given appears unnecessary and may be reduced with saving in cost. The sand filling is for the same reason unnecessary. When Danish Mission High School was built near ~~the~~ the proposed site the same depth of foundation and sand filling was allowed by S.E. 7th Circle for the same sub soil Vice copy of plan attached.
8. In accordance with circular No. 116 C dated 4-1-13 the drawings and estimates should be signed by a recognised Engineer or Architect etc. Done accordingly.
9. The reason for the omission of bath rooms, latrines, fuel and store rooms is not clear. Now clearly shewn.

(True Copy)

R. A. Triene
for Director of Public Instruction.

9/23
20/4

E. W. N O T E.

170367 D
2266-19

The Director of Public Instruction resubmits for sanction 2 drawings D.P.I Nos. 232-A and 232-B and a detailed estimate amounting to Rs. 18,310/- for constructing a Hostel with outhouses for the Danish Mission High School, Tiruvannamalai, South Arcot District after attending to the remarks of the Chief Engineer

Pages 304 c

in his Memo. No. 1509-C dated 27-2-19.

2. The plans and estimates have been examined in the Chief Engineer's office and it is observed that the joists in the Dining room and purlins in the roof should be changed to 3" x 9" & 5" x 7" respectively. The excess of Rs. 24/- due to these alterations having been adjusted in the amount against contingencies the total amount of the estimate remains unaffected.

2. With these remarks, the plans and the estimate amounting to Rs. 18,310/- are recommended for ^{approval} sanction.

20
186
19

13
6-19

16th
20-19

Secretariat

NOTES.

Subject.

Construction of a
hostel for the Danish
Mission High School,
Tiruvannamalai

Le. 2513/B, from the D.P.D., R.C. 942/18, 26.11.18

Home (Edel)

Submitted that the
plans and estimates may be
forwarded w/o to the P.W.D. for
sanctioning in the first instance.

B
28.11.18.

A
25.11.18

P.W.D. do


Home (Ed) No 2513B-1
29.11.18

-Page 324 CF

Note by the Chief Engineer No. 1609C of
27-2-18

or

The plans and estimates
have been scrutinised by the
Chief Engineer PWD and his remarks
are contained in his note read
above. He recommends that they
be returned for revision. With
these remarks the file may be
returned to Home (Edel) for the
issue of necessary orders.



FORWARD WORKS DEPARTMENT
C. No. 23/4
DATE 3/12/18



PWD memo.
23.11.18

Re
Please receive
Memo 116 01413
Home (Ed) No. 430B
1.3.19

TR
24.2.19
Home

Home (Edel)

Home (Ed) No. 430B

1.3.19
2.2.19

2.2.19
2.2.19

5.1.19
5.1.19

P.S.C.F

Memo No. 2512/B-18-2, d/s. 3. 19.

to 906/B, from the D.P.D., R.C. 9421/18, 1.5.19.

P.S.C.F.

The revised plans and estimates

may be forwarded up to the P.W.D. for scrutiny.

6.5.19

7.5.19

P.W.D.

Edm 906B-1

Page 807 Note by the Chief Engineer

No 367 D of 26-6-1919



24 1919

DC

The plans and estimates have been scrutinised by the Chief Engineer and his remarks are contained in his note read above. The file may be returned to Home (Edel) for issue of orders.

TR

24-6-19

25-6-19


Home (Edel)

Home (Edel)

The estimate as altered by the Chief Engineer amounts to Rs 18,310. A draft order sanctioning a half grant on Rs 18,310 is subd. If appl., it may be circulated to H.M. & H.M., with refer. to the papers recorded in No. 271 Ed. 21, d/s. 4th March 1919.


28.6.19 T.K 1.7.19

3.7.19 5 Issue



FD

Parw No 955-115/19-1



5096

2-6-19

(M)

Building grant.

Home DEPARTMENT.

Sanctioning a grant not exceeding one-half of the actual expenditure not Rs 9,155

towards the cost of constructing a hostel with outhouses for the Danish Mission High School, Tirunelveli.

READ AGAIN G.O. No. _____, dated _____ 191

READ ALSO:-

C. No. 2513/ From the D.P.G., P.C. No. 9421/15, dated 26-11-1918.

" " Note by the Chief Engrs, P.W.D., 1509.C., 27-2-1919.

" " 906/2-13 " D.P.G.; R.C., 9421/15 " 1-5-1919.

Note by the Chief Engrs, P.W.D., 367 D., 26-6-1919.

ORDER. No. 847, dated 5-7-1919.

Mrs.

The Govt. are pleased to sanction a grant not exceeding one-half of the actual expenditure not Rs 9,155 towards the cost of constructing a hostel with outhouses for the Danish Mission High School, Tirunelveli, subject to the following conditions:-

(1) That in carrying out the work the suggestions of the Chief Engineer in his note No: 367 D., dt 26th June 1919 are adopted; and

(2) That all the conditions prescribed in the Grant-...

Grant-in-aid made, as
modified by G.O. No. 1596

(VII)

Ed. 4, of 13th Dec. 1918 and

duly complied with; and

② that the title of the
management to the site
on which the building are

to be constructed is presumed
to be valid by the Govt.

Solicitor

2 On the above conditions
being ~~complied with~~ fulfilled,
the grant will be paid as
funds become available.

28.6.19
1-7-19
3-7-19
11/7/19

To the D.P.D. (9 to with plans &
estimates & copy of C.E.'s
note - p. 8, c. f.)

Copy to the A.G. Hono. Genl.
... P.W.D.

... coll. of N. Inset

When given for copying

When copied

When examined

When signed

19

READ AGAIN G.O. No.
19

DATED

CURRENT No.

ENCLOSURES TO G. No.

ORDER OF GOVERNMENT

LETTER OF GOVERNMENT

STATEMENT WITH LITTO.

PAPERS NOT FILLED UP, BEING KEPT FOR DISPATCH
IN ORIGINAL.

N.B.—

A = Copy in full.
B = Not to be copied.
P = Copy abstract only.
Q = Copy heading only.