

E & P.H.

(194 9) Department.

SERIES.

G.O. NO. 818 Edn.

Dated 23-3-1949

closed -

~~1876~~

Supdt.

~~1876~~

[Despatch Abstract.]

Schools - Secondary - Aided Girls High School Lalgudy - Construction of buildings on wet lands - permitted.

Back Papers.

G.O.	No.	Department.	Date.	G.O.	No.	Department.	Date.

Further Papers.

G.O.	No.	Department.	Date.	G.O.	No.	Department.	Date.

Re.12749/43-B4 Office of the Collector, Tiruchy, Dated 21.10.43.

From: V.M.Rajan Esquire, I.C.S., Collector, Tiruchirappalli

To: The Secretary to the Government, Education and Public Health Department, Fort St. George, Madras.

Sir, Education-Girls' High School, Lalgudi - construction of a school building on S.F.Nos.16A/2 and 16A3 (wet lands) of L.Abishekapuram village. Lalgudi Taluk-permission requested


The Correspondent, Girls' High School, Lalgudi reports that the High School is at present located in a rent free building owned by Sri L.N.Gurusamasivayam Pillai of Lalgudi for a period of 5 years, and the period of occupation expires by June 1950. Further it is reported that as the Educational authorities insist on the construction of a permanent building for the school, the Lalgudi Girls' Education Society, managing the Girls' High School proposes to construct a new building at a cost of about a lakh of rupees in the site measuring 1.66 acres of wet land (S.F.Nos. 16A2 and 16A3) of L.Abishekapuram village of Lalgudi Taluk. The correspondent requests permission for the construction of the building in the above said wet lands.

It is essential that this promising school should have a permanent building of its own in the circumstances reported by the correspondent. But as regards the land required for the school, I find that building on wet land is unavoidable not merely because there are no dry lands in Lalgudi fit for this purpose but also because Her Excellency Lady Nye laid the foundation stone for this school at the site already selected by the authorities. It would be most awkward if the foundation stone laid by the last British Governor's wife is allowed to stay idle. In the circumstances, I recommend to the Government that the Lalgudi Girls' Education Society may be permitted to construct the building on the wet lands as a special case.

vvg 22/10

For Collector.

Education & Public Health
Dept-
Enclt No: 78366-B/48-18 dated 3-11-48
Referred to the Director of
Public Instruction for remarks



Assistant Secretary to Govt
28-10-48
1000
19-10-48

To The Director of Public Instruction

Not a school under
provision of law.

From The Director of Public Instruction,
Madras.

To The Secretary to Government,
Education and Public Health Department,
Madras.

Rc.1207 D2/47 dated 6--1--1949.

Sir,
Grant - Building - The Girls High School, Lalgudy -
Construction of building - Plans and estimates
- Remarks.

In resubmitting the letter received with Endorsement
No.78366-B/48-1 Edn., dated 3-11-1948 I enclose herewith
copies of the remarks of the Joint Consulting Architect on
the subject.

I concur with the views of the Collector and recommend
the construction of this school building on the wet lands, as a
special case.

Yours faithfully,

[Signature]

for Director of Public Instruction.

KHR.7-1.

Copy of the Joint Consulting Architect to Government's
remarks referred to above.

1. The plans and estimates of the above work have been scrutinised and the following are the remarks:
2. The safe permissible stress for the sub-soil (viz: a mixture of sand (75%) and clay (25%) met with at the proposed site ranges from 0.75 Tons to 1.5 Tons per S.Ft. On grounds of safety, it is advisable to restrict the intensity of stress on the sub-soil to 0.75 Ton.per Sft. as against 1.25 Tons per S.Ft. allowed in the design calculations. However, if the sub-soil at foundation level is tested, the average safe permissible load, obtained from the test results, for a total settlement of 1" with a factor of safety of 2, may be taken into consideration for determining the width of foundations.
3. It is proposed to take the foundations 3 ft. below the existing ground level and to raise the present ground level later, by earth filling to 2 ft. above the present ground level if only funds permit. (vide flag D - 'A').

Calculations to support the proposed 3 ft. depth of foundations should be furnished.

4. In view of the non-availability and high cost of R.S. Girders, it is economical to adopt R.C.slab and Tee Beams in the place of Madras Terrace over R.S. Joists as proposed.
5. The design of the R.C.Staircase proposed should be worked out and submitted.

The anchoring of the main reinforcement bars of the stairs slab with the landing beam and slab is not properly sketched in the drawing (vide Drawing "Details of R.C.Staircase"). These should be attended to.

6. Plastering for inside and outside of walls with cement mortar may be done with a 1:4 mix instead of 1:3 or 1:2 mix as provided in the estimate.

n.t.o.

7. Detailed working drawings of the entire work should be prepared and submitted to this office for technical scrutiny before the work is commenced.

8. The plans and estimates may be returned for revision and resubmission in this light of the above remarks.

(True Copy)

for Director of Public Instruction.

Schools - Secondary - Aided - Girls High School
Lalgudi - Construction of buildings on wet lands -
Permitted

From the collector of Tenkuchirapalle RC. 12749/48
Dt 21.10.48

From the D.P.S., RC 1207 22/47 3 6.1.49

Order no 8/8 Education dated 23.3.49
In the circumstances explained, the
Lalgudi Girls Educational Society is permitted,
as a special case, to construct a building for
the Girls High School. Lalgudi on wet lands

To the collector of Tenkuchirapalle.
D.P.S.
26/3
21.8.49
27/8/49

(True Copy)

10/10/48
From the collector of Tiruchirappalli RC. 12749/48-B₄
d/21-10-48.

From the collector of Tiruchirappalli RC. 12749/48-B₄
d/21-10-48.

From the collector of Tiruchirappalli RC. 12749/48-B₄
d/21-10-48.

10/10/48

10/10/48

10/10/48

C.No. 78366 B₁/48.

E & P. H. (B₁).

Schools - Secondary - Aided - The Girls High School,
halgudy - Construction of building on wet lands.

From the collector of Tiruchirappalli RC. 12749/48-B₄
d/21-10-48.

the D.P.G. RC. 1207 B₂/47 d/6-1-49.

p19

p34

The Girls High School, halgudy is at present located in a rent free building which is ~~not~~ owned by one Mr. Gurusamasivayam Pillai. The management of the High School propose to construct a building of their own for housing the school ~~in conformity with~~ to conform to the Departmental requirements. As the building has to be constructed on wet lands the correspondent has ~~applied~~ ^{applied} for permission to proceed with the work. For the reasons stated in his letter at p19, the collector of Tiruchirappalli, recommends that the management may be permitted to go forward with the construction programme. The D.P.G. to whom the matter was referred, endorses the opinion of the collector. As the foundation stone ^{has already been} ~~was~~ laid by Lady Nye, ~~it is not possible~~ and as there is an urgent necessity for a permanent building for the school, the management may be permitted ^{case} to construct the building on wet lands as a special ~~case~~. The extent of wet lands that will be used for the building is 1.66 acres. Dev. and Rev. may see for remarks if any prior to circulation.

p34

The collector says that there are no dry lands at halgudy.

p19

6236 B₁/49

19-1-49

E & P. H. D.O. No.

78366 B₁/48-2 Edn

18/1/49




E & P. H. Note above may be seen

used. No remarks ^{are} called for
in this Dept. The Legislation to prohibit
the construction of buildings on wetlands
is dealt with in Revenue Dept. May be
worked on to that Dept.

MR 19.1.49
22.1.49

23.1.49 Rev

Des. no. 6236 B II / 49-1
23.1.49




To As

This Dept. may agree to permission
being granted to the management of the school
for constructing a building on wet land
as a special case. E.P.H. may take
orders in circulation including H.M.(R),
and H.Pr.

26.1.49
26.1.49

27.1.49 EPH.

Rev no. 6262 F / 49-1
27.1.49



E & P.H. (B.)

The case relates to the ^{construction} acquisition of buildings
for the Girls' High School, Halgudi, on Wet lands. The
area of wet lands required for the purpose is only 1.6 acres.
~~The~~ The collector of ^{Tiruchirappalli} ~~Tiruchinopoly~~ states that there are no
dry lands at Halgudi. On the recommendation of the
collector and ~~the~~ the B.P.G., it is proposed to permit
the management to ~~use~~ ^{utilise} the 1.6 acres of wet lands
for building purposes as a special case. Revenue Dept.
have also agreed to the proposal.

p1 of.
p1 of and p3 of.
p1 of ante

2/. The file may be circulated to H.M. (Edn)
H.M. (L.R) and H. Pr. for orders whether permission
may be granted to the management for the construction
of the school buildings on wet lands as a special
case.

29.1.49
28.1.49

ISA 2.2.49
H.P. H. Pr.
O.P.R. 17/3



③ H.Pr. is also in charge
of the Rev. Dept.

Please see the orders in circulation on page 2 ante
A draft order is submitted below for approval

1282
21.3.49

22/3/49

S by mdy.

Please see the orders in circulation on page 2 and 3
A draft order is submitted below for approval

2