M.R. O. 1—22,000—15-10-99.

MADRAS RECORD OFFICE.

Government of Madras.

Judicial DEPARTMENT.

G.O. No. 92 Press ~~Mis.~~

124-125

124-125

Dated 23.1.1861 ~~19~~

3/4

Not to be folded or roughly handled

Proceedings of the Madras Government, Judicial Department,
23rd January 1861.

No. 124. Read the following Proceedings of Government in the Public Works Department, (Public,) dated 19th January 1861, No. 134.

Communicating copy of a letter from the District Engineer, Ganjam, submitted by the Chief Engineer, reporting on the Chicacole Jail which the former has inspected and informing of the steps he has taken to add to the security of its roof.

(Vide Proceedings Public Works Department, dated 19th January 1861, Nos. 269 & 270.)

No. 125. ORDER THEREON, 23rd January 1861, No. 92.

To be recorded.

(Signed) T. PYCROFT,
Chief Secretary.

Exd. T. O'Connor.

PUBLIC WORKS DEPARTMENT.

Public.

PROCEEDINGS OF THE MADRAS GOVERNMENT.

Read the following Endorsement of the Chief Engineer, dated Chepauk, 10th January 1861, No. 8,713 :—

Read the following letter from Captain E. H. HARINGTON, District Engineer, Ganjam, to Lieutenant-Colonel S. O. E. LUDLOW, Deputy Chief Engineer, Northern Circle, dated Chicacole, 13th December 1860, No. 320.

SIR,

1. With reference to Proceedings, No. 7,162, 20th November 1860, and Government Order 9th October 1860, No. 2,104, I have the honor to report that I have carefully inspected the Chicacole Jail and consider the roof to be *perfectly* safe. It is a couple roof with a span of only 15 feet, with a slope of one-third the span. The couples are connected each by two collar beams, of dammer wood. A few collar beams should be replaced, and I have, with the sanction of the Civil and Sessions Judge, directed that this should be done, at a cost not exceeding Rupees (18) eighteen.

2. The walls are well built of brick in chunam, and one and a half feet thick.

3. In letter, No. 89, dated 5th July 1859, I reported on certain points connected with the Chicacole Jail, and my recommendations were approved in Order of Government No. 1,013, 29th July 1859, communicated with Chief Engineer's Proceedings No. 3,608, 8th August 1859.

4. I have informed the Inspector General of Jails of the steps I have taken to add to the security of the roof, in the above mentioned Estimate, Rupees 18.

Submitted to Government with reference to their Proceedings No. 2,104, dated 9th October 1860, the other reports have been called for and will be submitted as received.

(Signed) W. H. HORSLEY, Lieut.-Colonel,
Chief Engineer.

ORDER THEREON, 19th January 1861, No. 134.

Ordered to be communicated to the Judicial Department with reference to paragraph 10 of the Proceedings in that Department, dated 5th October 1860, No. 1,293.

(True Extract.)

Deputy Secretary to Government.

To the Judicial Department.

Exd. S. T. Augustin.

Prov. 29th July 1859 ch. 36 & 87.
8th Aug. 1860 ch. 40 & 210

Prov. of Albany.
Judicial 1861 Dept.

Prov: of Govt in the
P. W. D. 134.

D. 19th
R. 21st Jany/61.
3 spare copies.

No 98.

Comg copy of a letter from the District Engineer Sanjan submitted by the Chief Engineer, reporting on the Thicacole Jail which the former has inspected & informing of the steps he has taken to add to the security of its roof.

No 92 - 23 January/61.

Recorded

134 & 135