

LOCAL AND MUNICIPAL
DEPARTMENT.

Paper taken out of the Records
from the charge of the Record-
keeper.

Press _____ No. _____
Miscellaneous _____

189

[illegible]

[L. & M.]
[2,000-3-3-96.]

INDEXED.

Local & Munl. (1896) Department.

MISCELLANEOUS.

G.O., No. 2093. M.

DATED 10-12-96

[Despatch Abstract.]

Water Supply.

Recording papers relating to
the filter bed improvements for the
— of Tanjore.

BACK PAPERS.


G.O.	No.	Department.	Date.	G.O.	No.	Department.	Date.

FURTHER PAPERS.

G.O.	No.	Department.	Date.	G.O.	No.	Department.	Date.

Local & Munl. (1896) Department.

CURRENT No. 3209 m



AMS

From

The Chairman
Municipal Council
Tanjore

No. 1765

Dated 26th November 1896

Received 30th "

Registered 30th "

Enclosures 1 with C No 2489 m etc

Spare copies

SUBJECT

Forwarding an extract from
the Proceedings of the
Municipal Council, Tanjore,
of 18th November 1896,
regarding the further
road improvements.

Misc
Order

In the circumstances
stated, the Government will
not insist upon the works
proposed by the Sanitary
Engineer being carried out
at present.

P.A.
8/12/96

order No 2093 dated 10-12-96

Recorded

8/12/96

Note.

Please see the notes and
orders in G.O. 1751 m of 14th Oct. 1896.

To.

The Chairman M.C. Tanjore.
The Sanitary Eng. with plans
The Public Works Department

5/12

2/12/96

Depd 12/12/96

BACK PAPERS.

G.O.	No.	Department.	Date.
80	1751	hkh	14-10-96

FURTHER PAPERS.

G.O.	No.	Department.	Date.

(Form No 43)

Local Municipal Office.
3209 M

TANJORE MUNICIPAL OFFICE,
26th November 1896.

No. 1765

FROM

The Honorable K. Kalyanasundaram Aiyaswar

CHAIRMAN,
MUNICIPAL COUNCIL,
TANJORE.

TO

The Chief Secretary,
TO GOVERNMENT,
Local and Municipal Department,
Fort St. George,
MADRAS.

Thro the Divisional Officer,

TANJORE.

SIR,

With reference to the endorsement of
* (Herein returned) Government No 1296, dated 12th Instant, on the letter of
the Sanitary Engineer No 2180, dated 14th July 1896, I
have the honor to enclose for the information of Government
copy of a resolution passed by the Council on the subject
at its meeting of the 18th Instant.

2. The Government is aware that the benefit
of the water works has not been extended to the whole
of the Town, and on a rough calculation made under
my orders I find that about Rs 30000 would be
required for extending the works to the more important
parts of the town.

3. In these circumstances the Council seems
to be justified in passing the resolution in question.

I have the honor to be,
Sir,
Your most Obedient Servant,

S. Swaminatha Sastri
Chairman Deputee

TANJORE MUNICIPALITY.

Extract from the Proceedings of the Municipal
Council, Tanjore, at a meeting held at 5 P. M. on
Wednesday the 18th November 1896. at the
Municipal Office, Tanjore.

PRESENT.

13 Councillors

Resolution No. I

Read

The Hon. K. Kalyana Sundaram Esq. ^{Chairman}
Mr. R. P. C. Murugesem Pillai ^{Esq. Dy. Collector}
and En-Officio Councillor

" Shunuchi Kambalam Chelthiar ^{Esq. Councillor}

" Gnathasah Rowther

" Ratha Krishna Raidu gam

" V. Appasamy Vandayar ^{Esq.}

" S. A. Swaminatha Sastri

" Sammiadu Pillai ^{Esq.}

" Palanayandi Pillai ^{Esq.}

" Krishnaasamy Raidu gam

" Sanjeeri Pillai ^{Esq.}

" Kandasami Pillai ^{Esq.}

" M. Nataraja Esq.

I. Read letter No 2687 dated 2nd September
1896.

1896 from the Sanitary Engineer Madras proposing to utilize a portion of the balance (Rs 27000) in executing works which will maintain a reserve supply for the months when the river is dry.

Read also endorsement No. 1296 dated 12th November 1896 from the Secretary to Government Local and Municipal Department, Madras referring for early comment the plan and estimate for constructing filter bed improvements for the water supply of the town of Tanjore, approved by the Sanitary Board.

Resolution. — There is a considerable portion of the town not served by the water-works. The water-tax is being collected from all. A fair quantity of water might be obtained by digging channels above the filter bed, as was done this year. In these circumstances the Council is of opinion that it is its first duty to utilize the balance in its hands in extending the water-works to those parts of the town which are not now reached by them, leaving the proposals of the Sanitary Engineer to be dealt with subsequently.

In R. P. S. A. Swaminatha Sastri
disenting.

K. Kalyanasundaram
Chairman

[L. & M.
1,000-28-10-96]

Local & Munl. (1896) Department.

CURRENT No. 3008m

Order
No. 1296

Referred to the Municipal Council, Tanjore for ^{early} remarks.

From
The Sanitary Board.

[Signature]
Secretary to Government.

No. 211-S

V.P.
11/11/96
For St. George
12th Nov. 1896

[Signature]
13/11/96

Vide Reso: of 18. 11. 96 No. 1.

[Signature]

Dated 5-11-96
Received 6-11-96
Registered 6-11-96
Enclosures *C.M. 2489 m with 4 sheets with (one plan)*
Spare copies

SUBJECT.

Approving the plan & estimate for constructing Filter Bed improvements for the water supply of the town of Tanjore.

The Chairman, M. C. Tanjore.

9/11

BACK PAPERS.

G.O.	No.	Department.	Date.
80	1751	du h	14-10-96

FURTHER PAPERS.

G.O.	No.	Department.	Date.

S. E. 25.2.96-1,000.

No. 2180

GOVERNMENT OF MADRAS.

OFFICE OF SANITARY ENGINEER,
Fort St. George, 14 July 1896.

From

J A JONES, Esq., MEM. INST. C.E., F.R.S.E.,

SANITARY ENGINEER TO GOVERNMENT,

To

The Chief Secretary to Government,

Local & Municipal Department.

Through The Chief Engineer, P. W. D.

SIR,

In continuation of my No. 1151 of 15th. April '96 I have the honor to report that the water in the Vennar fell to its lowest level this year on 2nd. May 1896, viz 114.58 or 1.03 feet above top of filter bed.

2. The Chief Engineer will now be able to decide which of the two plans proposed in my Nos. 1075 of 9th. April 1896 and 1151 of 15th. April 1896 should be adopted.

3. The plan proposed in the former letter was a series of Stoney's sluices across the river; these however would be very expensive as they would have to be constructed so as to rise completely clear of floods. I therefore think that ordinary baulk shutters would be best. These would be inserted when the river was falling just before the hot weather. I have not been able to estimate for these as I do not know the amount by which the water way could be limited & this would require to be fixed by the Public Works Department; any space taken up would however raise the water level only slightly. The proposed cross section of a pier I have shewn in pencil on the tracing of the filter bed accompanying (to be returned). Protective work in rear of the piers would probably be required.

4. As to the plan proposed in the latter of the two letters quoted above I herewith enclose an estimate and sketch shewing what I proposed. The pipes would be laid at level of top of filter bed and from the filter bed up the river with an inclination equal to that of the river. These pipes would be covered with gravel for a depth of 18" above bottom of pipe as shewn on sections of the pipe trenches.

5. The length of 1200 feet has been proposed because that length of Main open channel up the river was necessary to give even a short supply to Tanjore during the months hereafter referred to. There were however no branch channels.

6. If this plan is adopted the pipes would be laid only as required and after the river had fallen next year & required, again, the channel opening up and only the lengths actually required to maintain a supply would be put in (no baling has been allowed for in estimate as none should be required under the above proposal).

7. It is advisable whatever plan is decided on to ensure the delivery of the materials for the work before December next so that they may be at once used when the river has fallen so low as to require the additional works.


8. Before considering the adoption of either plan the Public Works Department might be asked to consider the possibility of always maintaining a supply of water which could be let down during the months of April, May & June.

9. There is an unexpended balance of about Rs 25000/ in the Tanjore Water Works account available for these works.

I have the honor to be,

Sir,

Your most obedient servant,



Sanitary Engineer to Government.

O.W. No. 7080

Regd 5-8-96.

En 3

Ench 3

1896.

From

The Sanitary Engineer
to Government,

To

The Chief Secretary
to Government
Local & Municipal Dept

Through The Chief Engineer, O.W.D.
No. 2180

Dated 14 July 1896.
Despd. 15
Recd.

Enc. 3 (with plan)

Subject.

In expressing his opinion on the proposals he recently submitted for augmenting the supply to Tanjore water beds, states that the Chief Engineer will now be able to decide which of the two plans could be adopted & suggests reference to O.W.D. for consideration as to the possibility of always maintaining a supply which could be let down during April, May & June -

Recd. 18-7-96
No 81309 18-7-96

E. J.

For favour of
remarks with reference
to paras 3 and 8

18/5/96

EW

There would be no objection whatever to the placing of the bank shutters at this time of the year in. decided, to raise the W.L. in the river.

2. Whatever water may be available in the river could always be turned down the Tinnai in April and May, and in June until the floods come down the river.

Ans. 11

21/7

96

0.254

2489 110896

P.W. Dept.
Local & Municipal Dept.
CURRENT No. 2489

Letter from the Sanitary Engineer, No. 2180 d/ July 14, 96
Pro: Local & Muni dlp. No. 1284 M. this d/ Aug. 3.

Note by the Chief Engineer

P.W. Dept. -

No. 11992, d/ 2nd September 1896
I have duly considered

the two proposals of the Sanitary Engineer contained in his letters No. 1075 of 9th April 1896 & No. 1157 of 15th April 1896 respectively and I consider the latter to be the better.

2. With reference to para 8 of the Sanitary Engineer's letter No. 2180 dated 14 July 1896 the Chief Engineer for irrigation states that whatever water is available in the river could always be turned down the

1284, M.
3-8-96

Vennar in April & May
and in June until the
floods came down the river.

(S) J. M. Neil Campbell
Col. R.E.

From Chief Engineer.

To No. 1200 d. of 2nd Sept. 1896
Transferred to

the Local & Municipal
Dept.

Dated.

Despd.

Recd.

J. M. Campbell Col. R.E.
Sout Secy to Gov. S. W. S.

To The Local & Municipal Dept
with letter No. 2180 of 15/7/86
from the Sanitary Engineer.

Government of Madras

Sanitary Board Office Sol 13/11/96

Proceedings of the Sanitary Board No. 211 S,
dated 5th November 1896.

Read the following:—

Proceedings of Government in the Local and Muni-
cipal Department No. 1751 M. Mis., dated 14th October
1896 forwarding for the approval of the Sanitary Board
plan and estimate amounting to Rs. 19,508 for
constructing Filter Bed improvements for the
water supply of the Town of Tanjore.

Resolution

The plan and estimate are approved
by the Sanitary Board.

(True Extract)

R. Parson S.
Secretary, Sanitary Board

To The Secretary to Government,
Local and Municipal Department
with (5) enclosures returned.