

Local & Munl. (1899) Department.

MISCELLANEOUS.

G.O., No. 1392 do

DATED 22-9-'99

INDEXED. DESPATCHED

[Despatch Abstract.]

Tirupati water-works. Recording.
G.O. P.O.D Communicating endorsement
of the Superintending Engineer IV Circle
on the Sanitary Commissioner's inspection
notes on —

BACK PAPERS.

G.O.	No.	Department.	Date.	G.O.	No.	Department.	Date.

FURTHER PAPERS.

G.O.	No.	Department.	Date.	G.O.	No.	Department.	Date.

Local & Municipal
Legislative (189) Department.

CURRENT No. 2433 m

From *Mu P.W. Dept*

His
Order No. 1372 *22/9/89*

No. 2384 W

Recorded

VR
15/9/89

20. 9/89

Dated *12th* September 1889.

Received 13 SEP 1889

Registered

Enclosures *nil*

Spare copies

SUBJECT.

Triupati Water Works.

Comtg. end of the

S.E. IV circle forwarding

copy of letter from the

Ex: Engr, North Arcot,

reporting on certain points

in the Sang. Comm. inspection

notes on

To
The Public works Dept.
" Chairman, M.C. Triupati, through the
Colr. of the arcot
" Sanitary Commg.
Sept. 24/89

16/9. 24/89

BACK PAPERS.

G.O.	No.	Department.	Date.

FURTHER PAPERS.

G.O.	No.	Department.	Date.

PROCEEDINGS OF THE MADRAS GOVERNMENT.

LOCAL & MUNICIPAL DEPT.

CORRESPONDENCE No. 2433 M

READ the following

Letter from the Executive Engineer, North Arcot Division, No.496 S.E. dated 16th August 1899:-

In reply to your No.444/ 12th August 1899, I have the honour to report that the suggestion in the Sanitary Commissioner's para 2 has already been carried out.

2. With regard to para 3, the rats and snakes are welcome to make a residence of the overflow chamber for they cannot get at the water to contaminate it. The masonry is in my opinion preferable to the iron suggested by the Sanitary Commissioner as being less liable to injury and more easily repaired when injured.

3. With regard to para 4, the usual masonry pillars have been adopted, but with pointed (instead of cement -- plastered) surfaces.

4. The Sanitary Commissioner's objection seems --- rather fine-drawn and it is hardly worthwhile to partly demolish all the pillars (all of which have been completed) merely in order to build glazed tiles into them.

Endorsement thereon by the Superintending Engineer, IV Circle, No.467 W, dated 23rd August 1899:-

Forwarded to the Chief Engineer, Public Works Department, with reference to G.O. No.2064 W of 7th August 1899. The suggestions of the Sanitary Commissioner in para 2 have been carried out and it does not seem necessary to make any alteration in the overflow chamber. As regards the Sanitary Commissioner's remarks in para 4, the insertion of the glazed tiles might be postponed till it is

seen

een whether the pillars do become dangerously insanitary.

ORDER thereon No.

2384 W 312-9-29.

Communicated to the Local and Municipal Department
with reference to G.O. No.980 M, dated 12th July 1899.

(True Extract)

A. Hulme

for Secretary to Government.

To

The Local & Municipal Deptt.

Given for copying _____
Copied _____
Examined _____
Filed _____ 23/9 } 189.

G.O., No. , DATED

URES TO C. No.

OF GOVERNMENT

LETTER OF GOVERNMENT.

STATEMENT WITH DITTO.

PAPERS NOT FILED UP, BEING MEANT FOR DESPATCH
IN ORIGINAL.

N.B.—

A = Copy in full.
B = Not to be copied
F = Copy abstract only.
Q = Copy heading only.