

Marine (1898) Department.

G.O., No. 83/ Marine

DATED 30 Sep 1898.

*12-7
5-69 mar/25-6-99*

[Despatch Abstract.]

Port office at Madras

*From: P. W. D. A. Approving & returning
to the (msg): Architects for sanction & execution
Estimate of Rs 1890 for constructing a Signaller's work-
out house over the _____ + allotting funds for the work,
Communicated to the Port Office.*

*Dr
Ludlow*

Indexed. 9/10/98.

G.O.	No.	Department.	Date.	G.O.	No.	Department.	Date.

Local & Munl. (1898) Department.

From *He I. W. Deftu*

Communicated to
the Presidency Post Office.

No. 2471 *W*

Dated 23 Sep '98

Received } 27-9-98
Registered }

Registered

Enclosures

Spare copies

SUBJECT.

Port office at Madras

Approving & returning
to the Cong. Architect
for Sanction & execution acc
Bureau of 10th 1890 for Cons. Ins. & the
a Signaller's look-out house &
over, acc ———, & all other things
for the work.

BACK PAPERS.

G.O.	No.	Department.	Date.
90	5058	16-6-98	
	2709	27-3-98	
	2962	1-6-98	
90	2438	31-3-98	

FURTHER PAPERS.

G.O.	No.	Department.	Date.
	773	elec.	10-8-99

PROCEEDINGS OF THE MADRAS GOVERNMENT.

Read the following:-

From the Presidency Port Officer, No. 1391/259 G, dated 26th July 1898:-

With reference to G.O. Marine No. 505, dated 16th June 1898, I have the honour to forward, duly countersigned, for sanction of Government and allotment of funds, an estimate amounting to Rs. (1910) one thousand nine hundred and ten, for providing a new look-out house on top of the Port Office building and a new staircase to lead thereto. The plan received with the estimate is also sent countersigned.

2. The Chairman, Harbour Trust Board, has intimated that the expenditure can be met from the following grants in the Port Fund Budget of the Madras Port for 1898-99, viz:-

Rs. 1000 from the balance of Rs. 1847-4-8 available under Repairs and Petties.

Balance from the grant of Rs. 6000 for moorings.

Note by the Chief Engineer, E.W.D., dated 24th August 1898:-

Considering the elevation of the room, about 60 feet above ground level with the mast 45 feet higher still, I recommend that the sleepers be bolted to the joists of the terrace to give further stability.

2. Galvanized iron ribbon $\frac{1}{8}$ " should be used for the lightning conductors instead of copper.

3. The consulting Architect should examine the rates for planking given in Circular No. 2709 G, dated 3rd June 1898. He can probably get it made up cheaper in Calicut than in Madras.

4. The amount of the estimate has been reduced from Rupees

Date:

1910 to Rs. 1890 by the correction of certain errors in arithmetical calculations.

3. With the above remarks, the estimate is recommended for sanction.

Order thereon:- No: 2471 W 23.9.98

The estimate, amounting to Rs. 1890, as

altered by the Chief Engineer, for constructing a signaller's look-out house over the Port Office at Madras, is approved, and returned to the Consulting Architect for sanction and execution.

2. A sum of Rs. 1000 is appropriated for the work from the reserve with the P.W.D. under Excluded Local Fund, and the balance will be provided later in the year.

1. Attention is drawn to the Chief Engineer's note read above.

(True Extract)

A. K. M. M.

Under Secretary to Government.

- To The Consulting Architect to Government, with enclosures
- " Examiner, P. W. Accounts.
- " Marine Department.

Forwarded to H.E. the Governor & the Hon'ble
Li Hany Min, M.D.

Had the following:-
The estimate for the construction of a signaller's look-out house over the Port Office at Madras, as sanctioned by the Government, is recommended for sanction.

Rs. 1000 from the balance of Rs. 1890 available under the estimate for the construction of a signaller's look-out house over the Port Office at Madras, as sanctioned by the Government, is recommended for sanction.