

1. Number of pgs. *6*
2. Date of receipt *20-7-3*
3. Initials of Recr. *[Signature]*

D.S.

M.R.O. 1-22,400-22-11-80

MADRAS RECORD OFFICE.

Government of Madras.

Public Works DEPARTMENT.

Cons. 25.3.57

G.O. No. *1612*

Press
Mis.

14-15

Dated *19* — *8* — 18*57*

Not to be folded or roughly handled

7

Fort Saint George, Public Works Consultation of 25th August 1857.

No. 14. Read the following Report from Colonel C. E. FABER, Chief Engineer; to H. FORBES, Esq., Acting Secretary to Government, dated 3rd August 1857, No. 2615.

Report J, on an estimate prepared by Lieutenant PALMER, Executive Engineer, for constructing a Police Cutcherry in the Town of Chicacole.

Amount of estimate, Rupees (1,450) one thousand, four hundred and fifty, comprising the items shown in the accompanying abstract.

1. The building is to be raised on a basement of 2 feet in height above foundations, which are to be sunk 3 feet.

The principal walls are to be 14 feet high, and the verandah pillars, and walls 8 feet, supporting a tiled roof.

2. The building is to contain 5 rooms.

One room 20 feet long by 15 feet broad.

Two do 15 feet „ 15 „

Two do 15 feet „ 13-6 „

with an open verandah in front, 7-6" broad, and a small compound in rear, 53 by 30 feet, enclosed by a wall 5-6" high.

3. Lieutenant Harington in his letter No. 551 of the 9th June 1857, states that Lieutenant Palmer represents the building at present used as a Police Cutcherry to be in so dilapidated a state, that he does not recommend spending any money in its repair; the Collector in his letter No. 256, dated the 11th Idem, supports this statement, and further observes, that the building is very inconvenient for the purpose required.

4. The plan proposed for the building is approved of by the Chief Engineer, and the estimate which is framed on moderate and sufficient data, is recommended for entry in the Budget of 1858-59.

On a new Cutcherry being constructed, the old building may be sold at Public auction.

No. 15. ORDER THEREON, No. 1612; dated 19th August 1857.

Referred to the Judicial Department for consideration.

(Signed) H. FORBES,
Acting Secretary to Government.

Ganjam District

1st 26/15

Judicial
Police Cutcheries

Report on an Estimate
prepared by Lieutenant Palmer,
Executive Engineer, for constructing
a Police Cutcherry in the Town
of Chicacole.

Amount of Estimate, Ru-
pees [7450] One thousand four
hundred and fifty, comprising
the items shown in the accom-
panying Abstract.

1. The building is to be raised on a base-
ment of 2 feet in height above foundations, which
are to be sunk 3 feet.

The principal walls are to be 14 feet
high; and the verandah pillars, and walls 8 feet,
supporting a tiled roof.

2. The building is to contain 5 rooms.

One room - 20 feet long by 15 feet broad.

Two - do - 15 feet - " - 15 - " - "

Two - do - 15 feet - " - 13 - 6 - "

with an open verandah in front, 7 - 6 - " broad, and a
small compound in rear, 53 by 30 feet, enclosed by

a wall 5.6" high.-

3. Lieutenant Harrington in his letter No. 551. of the 9th June 1857. States, that Lieutenant Palmer represents the building at present used as a Police Cutcherry to be in so dilapidated a state, that he does not recommend spending any money in its repair; the Collector in his letter No. 256, dated the 11th Idem, supports this statement, and further observes, that the building is very inconvenient for the purpose required.-

4. The plan proposed for the building is approved of by the Chief Engineer, and the Estimate which is framed on moderate and sufficient data, is recommended for entry in the Budget of 1858/59.-

On a new Cutcherry being constructed, the Old Building may be sold at Public Auction.-

Central Office of P.W.
Fort St. Geo. 3 Augt 1857.

W. H. Colver
Chief Engineer

W.
W. H. Colver

To The Secretary to Government
Public Works Department

List of Enclosures.

- J1. Letter from Lt. Harrington, dated 9th June 1857. No 551.
- J2. A. C. from Asst. Collector fromam dated 11th Idem. No 256
- J3. Abstract Estimate.
- J4. Plan.

N^o 1612.

Referred to the
Judicial Department
for consideration.

W

Fort Saint George
19th Aug^t/57—

Forward to the Civil Dept.
with 4 Encls.
C. J. P. 2124.

N^o 1445

Public Works 1857. Depart^{mt}.
D^o to Cons 25th Aug^t. J
N^o 1562

From
The Chief Engineer
To The Secretary to Government
P. W. D.

Dated 3rd } August 1857.
Rec^d 1st }
Extract from the Lull Report^{ed} Sept^r 1857
6th 1803 in Cons. 15.
4 Enclosures.

N^o 2615

Reports on an Estimate of
Rupees 1450. for constructing a
Police Catchment in the town of
Chiacoli in the Ljungum District
and recommends the same for
entry in the Budget of 1858/59.

With an Order.
No. 1612. 19th August
L