M.R.O. 1—77,000—8-6-37.

(1) Number of pages_____

(2) Date of repair_____

(3) Initials of the Referencer_____

MADRAS RECORD OFFICE.

Government of Madras.

Public Works DEPARTMENT.

G.O. No. 3339 Press Mis.

108-109

Dated 6-11- 1866.

Not to be folded or roughly handled

No. 108. Read the following letter from the Acting Superintending Engineer, 1st Division, to the Secretary to Government, Public Works Department, dated Waltair, 22nd August 1866, No. 153 :—

1. Referring to G. O. No. 2,261, of the 18th July 1866, I have the honor to report, that I pointed out to the Inspector General of Police that the Magazine at Rajahmundry was a very low roofed building, well protected by trees and loftier buildings, &c., around it, and therefore quite unlikely to attract any lightning.

2. It seemed to me, therefore, to be unnecessary to expend any considerable amount in putting up any elaborate system of conductors; but to afford additional security, I proposed transferring one of the single conductors from the Sapper Barracks at Dowlaishwarum now being dismantled.

3. To this the Inspector General has assented. If the Government do not object, I beg permission to carry out this plan, which will cost a mere trifle.

No. 109. ORDER THEREON, 6th November 1866, No. 3,533.

CIVIL WORKS, No. 24.

The Government have no objection to the proposal which is made in this letter. The plan and estimate for putting up a single conductor should, however, be submitted for approval, unless the work is likely to cost less than Rupees 100, in which case the Superintending Engineer is competent to order its immediate execution.

(True Extract.)

Colonel, R. E.,
Secretary to Government.

To the Superintending Engineer, 1st Division.
" Judicial Department.
" Inspector General of Police.

Ed. S. T. Augustin.

No. 153

Supdt. Engr's Office I.D.
Waltair, 22nd August 1866.

From,

Lieutt Colo. F. J. Moberly R.E.
Actg. Superintending Engineer I.D.

To,

Colonel C. A. Orr R.E.
Secretary to Government P.W.D.
Madras.

Sir,

Referring to G.O. No. 2261 of 18th July 1866, I have the honor to report that, I pointed out to the Inspector General of Police that, the magazine at Rajahmundry was a very low roofed building, well protected by trees and loftier buildings rea around it, and therefore quite unlikely to attract any lightning-

2. It seemed to me therefore to be unnecessary to expend any considera=ble amount in putting up any ela=borate system of Conductors; but to afford additional security, I propos=ed transferring one of the single conductors from the Sapper Barracks at Dowlaishwaram now being dis=mantled.

3. To this the Inspector General has demurred. If the Government do not object I beg permission to carry out this plan which will cost a mere trifle.

I have &c &c

J. J. Lindsay Lt Col R.E.

Actg Sup Mil Engineer I° Div

Public Works Department.

No. 3533

PROCEEDINGS of the MADRAS GOVERNMENT.

Under date the 6th November 1866

Read the following

From the Acting Engineer of the 1st Div.

(Here enter No. 153 - 22nd Oct. 1866.)

The Government have no objection to the proposal which is made in this letter. The plan and estimate for putting up a single conductor showed, however, be submitted for approval, unless the work is likely to cost less than Rs. 100 in which case the Superintending Engineer is competent to order its immediate execution

JP
Work

From

The Acting Engineer
1st Div.

To

The Secretary to Govt.
P.W.D.
Madras

Dated 22nd October 66.
Despd. 22nd
Recd. 30th

No. 153

Replies to G.O. No. 2261 of 18th July 1866, on the subject of putting lightning Conductors to the Magazine at Rajahmundry.

No. 100.

C. 2nd Nov. 66.

Ans. 3533 - 6th Nov. 66

execution -

To
The Superintendent & Asst
" Judicial Depty
" Inspector General
of Police -

Dept 7th September

P. W. 1866 Dec 28th

Pass. of Govt for Sum

of Rs 35:33

Pass. of the Madras Govt

dated 6th Novr 66.

The proposal of the Supg
Engr of the 1st Divn for providing a
Lightning Conductor for Magazine
at Rajahmundry Godavery Dist
approved &c.

Rs 100 - 109.

Corrd with Govt 1866