

(1) Number of pages 12

(2) Date of repair

(3) Initials of the Referencer

MADRAS RECORD OFFICE.

Government of Madras.

Public works DEPARTMENT.

G.O. No. 182	Press
357-58	Mis-
Dated 22 / 1	18 72.

Not to be folded or roughly handled

Read the following letters:—

No. 357. From the Acting Superintending Engineer, 7th Division, to the Secretary to Government, Public Works Department, dated Cassergode, 15th December 1871, No. 200.

I HAVE the honour to report that the Lunatic Asylum buildings at Calicut

1 Estimate, Rupees 3,500.

1 Plan.

1 Copy of a letter from the Sanitary Commissioner, No. 57 of 21st October 1871.

being, so far as the plan and estimate are concerned, nearly completed and ready to be handed over to the Medical Department, the Sanitary Commissioner

lately inspected them and addressed me regarding certain additions and alterations he considers indispensable to allow of their being safely and conveniently occupied by lunatics, etc., etc. A copy of his letter* is enclosed for the information of Government, and I here-

* No. 57 of 21st October 1871.

with submit an estimate, amounting to Rupees 3,500, which provides for all the requisitions deemed necessary, the omission of which from the original estimate must, I think, rest with the Medical Department, by whom the plans, etc., were approved.

2. I take this opportunity of reporting that, owing to the length of time the work has been in hand, involving up-keep and repairs to more than half the building for two monsoons, employment of watchmen, etc., etc., the sanctioned estimate of Rupees 34,000 will probably be exceeded by $2\frac{1}{2}$ per cent., and I request that Government will, when sanctioning the estimate now submitted and allotting funds for the same, add a further amount of Rupees 850 to cover the excess under 5 per cent. above referred to; and, in order to allow of at least some of the cottages being rendered fit for immediate use, I request permission to direct their alteration as suggested by the Sanitary Commissioner from funds remaining at the Range Officer's disposal for certain portions of the work still incomplete and not immediately necessary, which can be finished when the funds now applied for are available.

From the Sanitary Commissioner, Madras, to the Superintending Engineer, 7th Division, Coimbatore, dated Calicut, 21st October 1871, No. C-57.

I HAVE the honour to state, for your information, that I have inspected the new Lunatic Asylum buildings at Calicut, accompanied by Major G.V. Law and the Civil Surgeon, with the object of ascertaining, before the buildings are handed over by the Public Works Department, what minor additions or alterations are needed to fit the place for the reception of lunatics.

2. With the exception of some quarters for sweepers and privies for servants, which are incomplete, and the levelling of the ground, the buildings are generally finished and supposed to be ready for occupation.

3. There are a few particulars however in which I would suggest minor alterations before the buildings are given over for occupation.

4. The general plan of each block of the Asylum buildings is the same. The block consists of three rooms or wards, with intervening spaces roofed over to serve as work-sheds or day-rooms, a very necessary arrangement in a climate like this where the rain-fall is so heavy and persistent. Each room has a door-way in front and rear ventilation, and light are further provided for by four barred windows, high up from the ground. Two small rooms in the rear of each ward will suffice, the one for a night latrine, the other for a bath-room.

5. The doors at present are essentially faulty for the custody of lunatics. The doors are simply battened and open *inwards*, the fastenings being arranged to shut inside; whereas it is an essential of all establishments for lunatics that the doors of the wards should open outwards, and that the warders in charge should be able to get into the room, or to lock or fasten it from the outside. These wooden doors are besides so insecure that I should advise their being replaced by iron barred doors, which would not only allow a freer ventilation of the wards, but would enable the warders to see at once whether anything was amiss amongst the inmates.

The pattern of door in the Madras Lunatic Asylum would answer very well, provided that the iron bars are placed not more than five inches apart. In the Madras Asylum it has been found by experience that the bars are too wide apart, and that a thin man occasionally succeeds in getting through.

This suggestion applies to all the blocks.

6. The weather-boards provided for the windows of all the wards, except at the ends of the blocks, are unnecessary, and, as they only tend to darken the wards, I recommend their removal.

7. The wooden revolving shutters in the small bath-rooms and night latrine-rooms should be removed and iron bars substituted. The weather-boards for the windows will be useful in guarding these openings from too much sun and rain.

8. It is intended that the flooring of the several wards shall be of rammed clay, *leaped* with cowdung as is the custom of the people in their own houses. As a certain number of filthy patients are sure to be received, I think it is necessary that *one* room in each block should be floored with asphalt. Care should be taken in laying the asphalt to provide that water spilled on it should be rapidly drained off. As a daily washing of the floor would probably be necessary, it is of great importance that the surface should be rapidly dried.

9. The large double gate of the criminal enclosure is not only unnecessary but a source of weakness, inasmuch as a criminal lunatic would be assisted by the gate hinges in getting over the top, whereas he would find a difficulty in climbing the wall. I suggest that this gate be taken down and the wall completed, leaving only an ordinary strong door in the wall, such door being arranged to shut by a spring lock. It was never intended that the gateway to the enclosure should be big enough to admit a couple of carriages abreast. A criminal enclosure for lunatics should have all the security of a jail.

10. There is no separate yard for female criminal lunatics. The present block of three rooms includes accommodation for twelve of this class; but it is obvious that men and women cannot be allowed to inhabit the same yard in the day time. One of the rooms perhaps might be given over as a sleeping place for females, and for their custody in the day time the Superintendent will have to make other arrangements.

11. The three cells arranged as padded-rooms will answer for the retention of patients requiring separate accommodation. It will not, I think, be necessary to fit them up with padded side walls. The small loft above will be useful for the warders on duty. The ventilation of these rooms being defective I have suggested to Major Law that, as a temporary arrangement, holes may be cut in the doors.

12. In the building designed to be used as an hospital, which is on the same plan and size as the block in the criminal enclosure, there is no provision made for a bath-room, where hot and cold or shower baths might be administered.

The flooring of *all* the hospital wards should, I suggest, be asphalted. One of the open spaces between the wards might also be asphalted and fitted with a boiler for heating water, and with appliances for giving shower and douche-baths. The arrangements for the escape of waste water from the bath-rooms will also need attention.

13. The water-supply on the site of the building is said to be of good quality from wells in laterite rock. It would be proper, I think, to provide a well for the hospital and another for the womens' enclosure, otherwise there will be much trouble in carrying water to and for. These wells

should have masonry platforms, parapet walls, and be fitted with strong wooden covers, the openings in which should be fitted with hinges, hasps and staples, so as to admit of being secured by a padlock after use. Small bathing platforms and cisterns will be required close to the wells in the male and female enclosures, and surface drains to carry off waste water.

14. The ground chosen for the site of the Lunatic Asylum having formerly been quarried for laterite is very uneven and full of dangerous holes. The surface should be levelled and planted, in the first place about the womens' ward and hospital. The male lunatics ultimately can be employed in levelling their own grounds.

15. The boundaries of the property require to be defined and fenced.

16. The road to the Asylum should be improved, as I infer that the Civil Surgeon will have to visit it daily, and this he cannot well do if the road is not adapted for the passage of a carriage.

17. Each block of buildings, I observe, has been provided with a small cook-room and covered latrine. The multiplication of cook-rooms is undesirable. I have no doubt it will be found in practice most convenient to have the whole of the cooking done in one place on the ground of economy in labour, fuel, and supervision. One of the cook-rooms in the blocks for men should be fitted with two of the inexpensive kind of stoves, which have been introduced into the Central Jail at Coimbatore, and of which you can doubtless furnish a plan.

18. In the block for females I observe no provision is made for the residence of a head female warder or matron, although some such person must reside on the spot and be in charge of the women. The building assigned as an office or store-room is larger than will ever be required for the purpose, and, as a temporary measure, a portion of this building might be assigned for the use of the matron, with temporary out-offices; but I think it will be necessary to have a suitable building put up *within* the female enclosure. This, however, can be settled when it has been determined whether the head female warder is to be a European or Native.

19. The provision for the Superintendent and attendants of the Asylum would appear to be ample.

20. I have to request that a ground plan of the various blocks of building, showing their position and boundaries of the Asylum property, may be furnished for record in my office.

P.S.—Major Law informs me that he has an unexpended balance of about Rupees 1,500, and I think that the building of privies for attendants may stand over for the present, leaving the money to be expended, so far as it will go, in the alteration suggested.

No. 387A. From the Acting Superintending Engineer, 1st Division, to the Secretary to Government, Public Works Department, dated Dowlaishweram, 27th December 1871, No. 3,027.

WITH reference to G. O., No. 3,161, dated 15th December 1871, I have the honour to inform you that the total sum given up by the Range Officer out of the year's grant, Rupees 11,000, for the Central Jail at Rajahmundry is Rupees 8,000, from which sum Rupees 5,530 must be deducted for the purpose noted in the margin, leaving a further balance of Rupees 2,470 available for other works.

Deduct as per G. O., No. 3,161 of 15th December 1871...	RS. 2,000
Do. as per G. O., No. 3,174 of 16th December 1871...	530
Amount required for the construction of the house for the Superintendent of the Jail ...	3,000

2. I further beg to state that months ago I reported to the Inspector-General of Jails the saving from the grant for the Central Jail which was likely to be available for other works.

*Proceedings of the Madras Government, Public Works Department,
22nd January 1872.*

No. 358.

ORDER THEREON, 22nd January 1872, No. 182.

CIVIL WORKS, No. 18.

THE additions and alterations proposed by the Sanitary Commissioner to the Lunatic Asylum buildings at Calicut having already been approved by Government in the Judicial Department, in Proceedings No. 1,594, dated 28th November 1871, the estimate of Rupees 3,500, submitted with the foregoing letter, is sanctioned. The Government also approve of the proposal in the concluding portion of Colonel Farewell's letter for rendering some of the cottages fit for immediate use, pending an allotment of funds to cover the supplemental estimate now sanctioned and the excess of Rupees 850 over the original estimate; and towards meeting this additional demand the sum of Rupees 2,000 will be transferred from the amount surrendered by the Superintending Engineer of the 1st Division from the grant for the Rajahmundry Central Jail.

(True Extract).

Colonel, R.E.,

Secretary to Government.

To the Acting Superintending Engineers, 1st and 7th Divisions.
,, Controller of Public Works Accounts.
,, Judicial Department.

Exd. S. T. Augustin.

6. No 57

Office of Sanitary Commissioner

Calicut 21st October 1871

From

The Sanitary Commissioner
for Madras

To

The Superintending Engineer
7th Division
Coimbatore.

Sir

I have the honor to state for your information that I have inspected the new Lunatic Asylum buildings at Calicut, accompanied by Major G. N. Law, and the Civil Surgeon, with the object of ascertaining before the buildings are handed over by the Public Works Department what minor additions or alterations are needed to fit the place for the reception of lunatics.

2. With the exception of some quarters for sweepers, and privies for servants, which are incomplete, and the leveling of the ground, the buildings are generally finished, and supposed to be ready for occupation.

3. There are a few particulars however in which I would suggest minor alterations before the buildings are given over for occupation.

4. The general plan of each block of the Asylum buildings is the same. The block consists of three rooms,
or

or wards, with intervening spaces, roofed over, to serve as work sheds or day rooms. A very necessary arrangement in a climate like this, where the rainfall is so heavy and persistent. Each room has a door-way in front and rear. Ventilation and light are further provided for by four barred windows, high up from the ground. Two small rooms in the rear of each ward will suffice, the one for a night latrine, the other for a bath room.

5. The doors at present, are essentially faulty, for the custody of lunatics. The doors are simply battened, and open inwards, the fastenings being arranged to shut inside, whereas it is an essential of all establishments for lunatics that the doors of the wards should open outwards, and that the warders in charge should be able to get into the room, or to lock or fasten it, from the outside. These wooden doors are besides, so insecure that I should advise their being replaced by iron barred doors, which would not only allow a freer ventilation of the wards, but would enable the warders to see at once whether anything was amiss amongst the inmates.

The pattern of door in the Madras Lunatic Asylum, would answer very well, provided that the iron bars are placed not more than five inches apart. In the Madras Asylum it has been found by experience that the bars are too wide apart, and that a thin man occasionally succeeds in getting through.

This suggestion applies to all the blocks.

6. The weather boards provided for the windows of all the wards, except at the ends of the blocks, are unnecessary, and as they only tend to darken the wards, I recommend their removal.

7. The wooden revolving shutters in the small bath rooms and night latrine rooms, should be removed and iron bars substituted. The weather boards for the windows, will be useful in guarding these openings from too much sun and rain.

8. It is intended that the flooring of the several wards shall be rammed clay, luted with cowdung, as is the custom of the people in their own houses. As a certain number of filthy patients are sure to be received, I think it is necessary that one room in each block should be floored with asphalt. Care should be taken in laying the asphalt to provide, that water spilled on it should be rapidly drained off. As a daily washing of the floor would probably be necessary, it is of great importance that the surface should be rapidly dried.

9. The large double gate of the criminal enclosure is not only unnecessary, but a source of weakness, inasmuch as a criminal lunatic would be assisted by the gate hinges in getting over the top, whereas he would find a difficulty in climbing the wall. I suggest that this gate be taken down, and the wall completed, leaving only an ordinary strong door in the wall, such door being arranged to shut by,

4
by a spring lock. It was never intended that the gateway to the enclosure should be big enough to admit a couple of carriages abreast. A criminal enclosure for lunatics should have all the security of a jail.

10. There is no separate yard for female criminal lunatics. The present block of three rooms includes accommodation for 12 of this class, but it is obvious that men and women cannot be allowed to inhabit the same yard, in the day time. One of the rooms perhaps might be given over as a sleeping place for females, and for their custody in the day time, the Superintendent will have to make other arrangements.

11. The three cells arranged as padded rooms, will answer for the retention of patients requiring separate accommodation. It will not I think be necessary to fit them up with padded side walls. The small loft above will be useful for the warders on duty. The ventilation of these rooms being defective I have suggested to Major Laro, that as a temporary arrangement, holes may be cut in the doors.

12. In the building designed to be used as an hospital, which is on the same plan and size as the block in the criminal enclosure, there is no provision made for a bathroom where hot, and cold, or shower baths might be administered.

The flooring of all the hospital wards should,

5
I suggest, be asphalted. One of the open spaces between the wards might also be asphalted, and filled with a boiler for heating water, and with appliances for giving shower and douche baths. The arrangements for the escape of waste water from the bath rooms will also need attention.

13. The water supply on the site of the building is said to be of good quality, from wells in laterite rock. It would be proper I think to provide a well for the hospital, and another for the women's enclosure, otherwise there will be much trouble in carrying water to and fro. These wells should have masonry platforms, parapet walls, and be fitted with strong wooden covers, the openings in which should be fitted with hinges, hasps and staples, so as to admit of being secured by a padlock, after use. Small bathing platforms and cisterns will be required close to the wells in the male and female enclosures, and surface drains to carry off waste water.

14. The ground chosen for the site of the Lunatic Asylum having formerly been quarried for laterite, is very uneven, and full of dangerous holes. The surface should be levelled and planted. In the first place about the women's ward, and hospital. The male lunatics or ultimately can be employed in levelling their own grounds.

15. The boundaries of the property require to be

be defined and fenced.

16. The road to the Asylum should be improved, as I infer that the Civil Surgeon will have to visit it daily, and this he cannot well do, if the road is not adapted for the passage of a carriage.

17. Each block of buildings I observe has been provided with a small cook room, and covered latrine. The multiplication of cook rooms is undesirable. I have

no doubt it will be found in practice most convenient to have the whole of the cooking done in one place, on the

ground of economy in labor, fuel and supervision. One of the Cook-rooms in the blocks for men, should be fitted

with two of the inexpensive kind of stoves which have been introduced into the Central Jail at Coimbatore, and of which you can doubtless furnish a plan.

18. In the block for females I observe no provision is made for the residence of a head female warder or Matron although some such person must reside on the

host and be in charge of the women. The building assigned as an office or store room is larger than will ever

be required for the purpose, and as a temporary measure a portion of this building might be assigned for the use

of the Matron, with temporary out offices, but I think it will be necessary to have a suitable building put up

within the female enclosure. This however can be settled

when

when it has been determined whether the head female warder is to be a European or Native.

19. The provision for the Superintendent and Attendants of the Asylum, would appear to be ample.

20. I have to request that a ground plan of the various blocks of building, showing their position, and boundaries of the Asylum property may be furnished for record in my office.

I have &c

(Signed) W. Cornish F.R.C.S.
Sanitary Commissioner
for Madras.

P.S. Major Law informs me that he has an unexpended balance of about Rs 1500, and I think that the building of privies for Attendants may stand over for the present, having the money to be expended, so far as it will go in the alterations suggested.

(True Copy)

P.P.

W. Cornish Secy. C. R. S.
Ag. Supy. Eng. & S.

be defined and fenced.

16. The road to the Asylum should be improved, as I infer that the Civil Surgeon will have to visit it daily, and this he cannot well do, if the road is not adapted for the passage of a carriage.

17. Each block of buildings I observe has been provided with a small cook room, and covered latrine. The multiplication of cook rooms is undesirable. I have no doubt it will be found in practice most convenient to have the whole of the cooking done in one place, on the ground of economy in labor, fuel and supervision. One of the Cook-rooms in the blocks for men, should be fitted with two of the inexpensive kind of stoves which have been introduced into the Central Jail at Coimbatore, and of which you can doubtless furnish a plan.

18. In the block for females I observe no provision is made for the residence of a head female warder or matron although some such person must reside on the spot and be in charge of the women. The building so assigned as an office or store room is larger than will ever be required for the purpose, and as a temporary measure a portion of this building might be assigned for the use of the matron, with temporary out offices, but I think it will be necessary to have a suitable building put up within the female enclosure. This however can be settled

when it has been determined whether the head female warder is to be a European or native.

19. The provision for the Superintendent and Attendants of the Asylum would appear to be ample.

20. I have to request that a ground plan of the various blocks of building, showing their position, and boundaries of the Asylum property, may be furnished for record in my office.

I have &c

[Signed] W. Cornish F.R.C.S.
Sanitary Commissioner
for Madras.

P.S. Major Law informs me that he has an unexpended balance of about Rs 1500, and I think that the building of privies for Attendants may stand over for the present, having the money to be expended, so far as it will go in the alterations suggested.

(True Copy)

J.P.

Whitcomb Secy. Col. R. &
Ag. Supy. Eng. & S.

No 200

Supp Engineers Office 7th Lth
Camp Casergode 15th December 1871

From,

St. Coll. W. Farewell A.C.

By Supp Engr 7th Lth

To,

The Secretary to Government

S. P. M. Madras

Sir,

I have the honor to report that the Sanatorium Buildings at Calicut being so far as the Plan and Estimate are concerned nearly completed and ready to be handed over to the Medical Department. The Sanitary Commissioner lately inspected them and addressed me regarding certain additions and alterations he considers indispensable to allow of their being safely and conveniently occupied by Sanatics; &c &c. a copy of his letter is enclosed for the information of Government and I herewith submit an Estimate amounting to Rs 3,500 which provides for all the requisitions deemed necessary. The omission of which from the original Estimate must I think rest with the Medical Department by whom the Plans &c were approved.

I take this opportunity of reporting that owing to the length of time the work has been in hand involving up keep and repairs to more than half the building for two months, employment of watchmen

Enclosures

1 Est. Rs 3500

1 Plan

1 Copy of a letter from the Sanitary Commissioner No 57 of 21st Oct 1871

No 57 of 21st October 1871

Sanitary Commissioner

Sanitary Commissioner

Sanitary Commissioner

Sanitary Commissioner

Sanitary Commissioner

Sanitary Commissioner

Sanitary Commissioner

Sanitary Commissioner

Sanitary Commissioner

Sanitary Commissioner

Sanitary Commissioner

Sanitary Commissioner

Sanitary Commissioner

men & ca 400, the sanctioned estimate of
Rupees 34,000 will probably be exceeded
by 2½ per Cent and I request that Govern-
ment will when sanctioning the estimate
now submitted and allotting funds for the
same, add a further amount of Rs 850 to
cover the excess under 5 per cent above re-
ferred to; and in order to allow of at least
some of the Cottages being rendered fit for
immediate use, I request permission to
direct their alteration as suggested by the
Sanitary Commissioner from funds remain-
ing at the Range Officer's disposal for
certain portions of the work still incom-
pleted and not immediately necessary
which can be finished when the funds
now applied for are available -

I have the honor to be,
Sir,

Your most obedt servant

W. S. S. C.
As Supy Engr. J. D.

110
SUPERINTENDING ENGINEER'S OFFICE, 1ST DIVISION.
DOWLAISHWARUM, 27 December 1871

No. 3027
From

Major J. H. Lister R.E.
Acting Superintending Engineer

1st Division

19
indale R.E.
Government D. P. W.
MADRAS

dated 15th
informed you
by the Range
11,000 for the
Rs 8,000 from
deducted for the
ing a further
other Works.
months ago
of a failure
ally fail which
other Works.

honor fled

best Servant

W. S. S. C. Major R.E.

As Supy Engr. 1st Div.

men & ca. 400, the sanctioned estimate of
 Rupees 34,000 will probably be exceeded
 by 2½ per Cent and I request that Govern-
 ment will when sanctioning the estimate
 now submitted and allotting funds for the
 same, add a further amount at Rs 1000 to
 cover the ex-
 pended to; &
 some of the
 immediate
 direct their
 Sanitary &
 ing at the
 certain per-
 pleted and
 which can
 now applic

P. H. 1871, Deptt
 Dir of Govt for Sany
 P. H. 1871

From
 The Supy Engineer
 1st Division

To
 The Secretary to Govt
 D. P. W. Madras
 No 200

Dated 15th
 12th 22nd } December 1871
 Enclosures 3. 1. 1

Forwards for sanction
 a Plan and Estimate for
 additions and alterations
 to the Sanitary System
 at Palani.

No 182. 22nd Jan 1872

No 357
 16th Jan 1872 A. 1/2

No

No. 3027
 From

Major J. H. Fisher R.E.
 Acting Superintending Engineer
 1st Division

To

Colonel G. A. Cardale R.E.
 Secretary to Government D. P. W.
 MADRAS

SIR,

With reference to G. O. No 3161 dated 15th
 December 1871 I have the honor to inform you
 that the total sum given up by the Madras
 Government at the year grant Rs 11,000 for the
 Central Rail at Rajahmundry is Rs 8,000 from
 which sum Rs 5,530 much has been deducted for the
 purpose noted in the margin, leaving a further
 balance of Rs 2,470 available for other works.
 2. I further beg to state that months ago
 reported to the Inspector General of Railways
 saving from the grant for the Central Rail which
 was likely to be available for other works.

I have the honor to be
 Your most Obedt Servt.

W. H. Fisher Major R.E.

By Supy Engineer 1st Div.

Deducted as per G.O.
 No 3161 of 15 Dec 1871
 Rs 5,530
 as per G.O. No 3174
 of 16 Dec 1871
 Amount required
 for the construction
 of the house for
 the Superintendent
 of the Rail 3,000

Public Works Department
 No 182
 Proceedings of the Madras Government
 Read the following

From the Supy Engrs. 7843 (H.C. No 200 of 15 Decr/71)
 W^o ————— W^o ————— W^o 3 (H.C. No 3027 of 27 Decr/71)

The additions
 and alterations proposed
 by the Sanitary Commis-
 sioner to the Lunatic
 Asylum Buildings at
 Calicut having already
 been approved by Govern-
 ment in the Judicial
 Department in Proceedings
 No 1594 dated 28th Nov^r
 1871, the estimate of
 Rs 3500 submitted
 with

No 15 of November 1911 A. 65.24
 16 292.293.

No 1872 of Decr 1871
 The 1872 of 1871
 41

Shankar Singh
 1871

To the Secretary to Govt

Calicut 27 December 1871

Revenue Department

No 3027

Calicut 27

The reference to C. A. 1871

Calicut 27 December 1871

Shankar Singh

Calicut 27 December 1871

Shankar Singh

Calicut 27 December 1871

Shankar Singh

Calicut 27 December 1871

Shankar Singh

Calicut 27 December 1871

Shankar Singh

Calicut 27 December 1871

Shankar Singh

with the foregoing letter is
sanctioned. The Government
also approve of the proposal
in the concluding portion
of Colonel Farewell's letter
for rendering some of the
cottages fit for immediate
use, pending an allotment
of funds to cover the
supplemental estimate now
sanctioned, and the excess of
Rupees 850 over the original
estimate; and towards
meeting this additional
demand the sum of
Rupees 2000 will be trans-
ferred from the amount
surrendered by the Sup^r
Engineers of the 1st Div
from

from the grant for the
Regimentary Central
Bail.

G. H. Lane

143
13 To
6 Engineer 1st & 7th Divs & with Plan attached
Controller
Jual Sep 23-1-92

Ops 6116 & 4.

Govt. of 1872 Madras.

PUBLIC WORKS.

To *Chief Superintendent Engrs.*
Pl. & J. (Division)

[Signature]

Dated

Recd.

Recd.

G. O. 22nd 1871. No. 182.

Nos. 357-358/1871

Sanitary Acylum Buildings at
Cheruvu - The estimate of
Rs 3500 for alterations to
Sanitary Acylum Build-
ings at Cheruvu, structured.