

- (1) Number of pages _____
(2) Date of repair _____
(3) Initials of the Referencer _____

MADRAS RECORD OFFICE

Government of Madras

Public Works

DEPARTMENT

G.O. No.	455	Press	<i>Original</i>
B.P. No.		Mis.	
Dated	24 - 2 - 1874		-195-

Not to be folded or roughly handled

*Proceedings of the Madras Government, Public Works Department,
24th February 1874.*

No. 463. Read the following endorsement of the Inspecting Engineer for Civil and Military Buildings, dated Chepauk, 23rd January 1874, No. 103 :—
From Lieutenant-Colonel J. GODDARD, R.E., District Engineer, Presidency, to Colonel E. A. FOORD, R.E., Inspecting Engineer for Civil and Military Buildings, dated Fort St. George, 10th January 1874, No. 4,713.

I HAVE the honour to submit, for your approval and eventual submission to Government for sanction, a plan and estimate, together with a specification report, amounting to Rupees 295 for putting up a ridge ventilator over the contagious wards in the Vepery Dispensary, which have been prepared at the request of the Surgeon General, Indian Medical Department, and duly approved of by that Officer, who states that the work is very necessary in a sanitary point of view.

2. The rates provided for are reasonable and sufficient, and no supplementary works will hereafter be required.

3. Funds may be granted from any source at the disposal of Government.

THE plan and estimate of Rupees 295 (now altered to Rupees 285) are forwarded for the sanction of Government

- 1 Plan.
- 1 Abstract Estimate.
- 1 Specification.

2. The detailed estimate has been countersigned by the Surgeon General,

Indian Medical Department, in token of his approval.

(Signed) E. A. FOORD, Colonel, R.E.,
Inspecting Engineer for Civil and Military Buildings.

No. 464. ORDER THEREON, 24th February 1874, No. 455.

CIVIL WORKS, No. 40.

HIS Excellency the Governor in Council is not of opinion that a building such as the Vepery Contagious

Disease Ward, the enclosing walls of which are composed of bamboo matting, can really be held to require ridge ventilation, and accordingly declines to sanction the estimate of Rupees 285, submitted for the purpose.

(True Extract.)

(Signed) G. W. WALKER, Colonel, R.E.,
Secretary to Government.

To the Inspecting Engineer for Buildings.
„ District Engineer, Presidency.
Public Department.

Exd. S. T. Austin.
Spare Copies

Estimate No 431 of 1873-74 5

Feb. 2^o 1874

My dear Robinson

I don't consider that
the roof ventilation is
at all required - The
building is swept
a roofed shed, the
walls of masonry &
the ventilation is thorough
as it is from the top
of the building

W. M. M. M.

Estimate No 431 of 1873-74 5

Specification to accompany an estimate of giving
a ridge tentacles on the Contagious Ward in the
Kepher Dispensary.

Amount of Estimate Rupees ^{285.} 295.

Ridge Tentacles to be fixed with helix
couplers of 1 collar piece, 1 each rafter, flat
and pautiles and chumam borders.

The couplers to receive 2 coats of tar.

His mark.
John Goddard
Dist. Eng. Printing.

For St George
13 Dec 1873

Compd
13-12-73

Abstract of Estimate. No. 131 of 1873-74

Work Putting up ridge ventilator for the Contagious Wards in the Vepery Dispensary.

Quantity	Description of Work.	Rate	Amount.
500 Supp	Coaly hire for removing the tiles on the roof of the ridge for putting up ventilator	2	1000
20' 1-3' left	Teakwood wrought and put up	2 1/2	50
7.20 Supp	Covering the roof of the ridge ventilator with palm-leaf Coupler teakwood planks flat and prantiles and Chunnam borders	26 5/6	189 10 10
800 S	For 2 Coats to the Coupler	3 1/2	2800
580 S	Shifting tiles with 50 new prantiles & Chunnam borders	10 6	16 4 4
	Drumry Charges of		15 8
Total Rupees			285 0 0

Total Rupees Two hundred & Eighty five only.

Dist. Engrs Office Press
Fort Saint George
10 January 1874.

For Passed
Lieut. V.C.

District Engineer Press.

Major Colonel R.E.
Insp. Engrs for Buildings.

Comd. Engr.

District

87409-100000-2

Enclosure in a letter
No. 113 dated 15 Jan 74

1874/1/15

Specification for

putting up ridge vent-

ilator for the contagious

ward in the Vepery Dispensary

Estimate No 285.

N^o 14713.

From,

The District Engineer

Presidency.

To

The Inspecting Engineer

for Civil & Military Buildings

Sir,

I have the honor to submit for your approval, and eventual submission to Government for sanction, a plan and estimate together with a specification report amounting to Rs 295 for putting up a ridge ventilator over the contagious wards in the Vepery Dispensary which have been prepared at the request of the Surgeon General I. M. D. and duly approved of by that Officer who states that the work is very necessary in a sanitary point of view.

2. The rates provided for are reasonable and sufficient, and no supplementary works will hereafter be required.

3. Funds may be granted from any

Presidency District.

Enclosure in 2 Letters
No. 103 dated 23 June 1874.

Mr 476/74

Abstract Estimate for
putting up Ridge Vent.
later to the Contagious
Wards in the Vepery Dis.
pensary.
Estimate of Rs 285.

any source at the disposal of Govern-
ment.

I have rec-
d. Fort St. George } signed J. Goddard Lt. Col. R.E.
10th Jan'y 1874 } District Engineer
Presidency

N^o 103

The Plan and Estimate
of Rs. 295 (now altered to Rs. 285)
are forwarded for the sanction of
Government.

Enclosures 3.
1 Plan
1 abstract estimate
1 specification

2. The detailed Estimate has been
countersigned by the Surgeon General
Indian Medical Department in
token of his approval.

Office of the Inspecting Engs.
for Civil & Military Buildings
Chopank 23 Jan'y 1874 } E. A. Dorr Col. R.E.
Inspecting Engineer for
Civil & Military Buildings

To
Colonel J. M. Walker R.E.
Secretary to Government O.M.D.

Letter from the Inspecting Engineer
for Buildings No 103 dated
22nd January 1874 -

Circulated for order
whether a building
the inclosing walls of
which are composed
of Bamboo Matting
can really be held
to require Ridge
ventilation -

Inspection made
Comd's note
24th Jan

Fort St. George
Janry 1874

Wm. Mather Coll^{rs}
Secy to Genl. P.W.D.

For 1874 Mather
of 103rd Bt. for
view of 103rd Bt. for
the Inspecting Engineer
for Buildings
No 103
to the Secretary to
Government P.W.D.

Sept 23rd
Oct 24th Janry 1874
Recd 26th

Enclo: 3
Forward for
Plan & Estimate of Works
(alluded to No 285) for
putting up a ridge
ventilator over the
concealed works in
the 103rd Bt. for
Mather

No 463
in 26th Janry 1874
Oct 23rd 24th Janry 1874

UP 470

(21)

No 1253 P.W. Sept 15
C. W. H. H.

Proceedings of the Madras Government.

Under date the February 1874

Read the following

From the Inspecting Engineer
for Buildings.

1 Fore cutter No 103 of 23 Jan'y 1874

His Excellency
the Governor in Council
is not of opinion that a
building such as the
Vepery Contagious Disease
Ward, the enclosing walls
of which are composed
of Bamboo Matting,
can really be held to re-
quire Ridge Ventilation,
and accordingly declines
to

Handwritten signature

Printed Jan 176

to sanction the Estimate
of Rupees 285 submitted
for the purpose.

Y.M.W.

Oct 4/76

Govt. of Madras.

PUBLIC WORKS.

The Inspecting Engineer
for Buildings

Dated

Recd.

Encl. 3

G. O. 24th July 455.

No. 462 & 464

Very Commissions are

mand. Declining to sanction
the estimate for providing
Ridge ventilation to the
mand.

The Inspecting Engineer
for Buildings.
5th District Eng^r Presidency
11th Public Dept.

Recd 2 with S-c 26/2/74