

(1) Number of pages_____

(2) Date of repair_____

(3) Initials of the Referencer_____

MADRAS RECORD OFFICE

Government of Madras

Palei & Morris DEPARTMENT

G.O. No.

B.P. No.

Dated

18.9.3

Press

Mis.

C875

195

Not to be folded or roughly handled

*Proceedings of the Madras Government, Public Works Department,
5th July 1875.*

No. 126. Read the following endorsement of the District Engineer, Salem, dated
"25th June 1875, No. 49 :—

From the Officer in charge of Tripatore Range, to Major J. N. HUNTER, R.E.,
District Engineer, Salem, dated Camp at Therealem, 21st June 1875, No. 291.

AGREEABLY to your endorsement, dated 17th current, No. 246, I have the honor
to report that the roof of the last or western room of the Anglo-Vernacular School-house
at Tripatore has fallen in. The causes the reof are decayed timber used as rafters, the
rafters of insufficient scantling for a room 12 feet wide, and a very heavy semi-
terraced roof, consisting of three courses of terrace bricks instead of three courses of
thin flat tiles. The doors and windows of this room (made of inferior jungle wood
mixed with pieces of deal wood) are in pieces.

2. The materials above referred to are not required for any work in the
Tripatore Range.

3. Provision has been made in the estimate now submitted for repairing the
building to dismantle the walls of the last room and to remove all debris.

SUBMITTED to the Secretary to Government, with reference to G. O., No. 148,
dated 15th June 1875.

(Signed) J. N. HUNTER, Major, R.E.,
District Engineer, Salem.

No. 127. ORDER THEREON, 5th July 1875, No. 1,893.

CIVIL WORKS, No. 12.

COMMUNICATED to the Educational
Department.

(True Extract.)

Major, R.E.,
Off. Joint Secretary to Government.

To the Educational Department.
„ District Engineer, Salem.

Exd. A. Grubert.
Spare Copies

35

Tripatore Range Office

N^o 291 Camp There also, 21st June 18

From The Officer in charge
of Tripatore Range.
To The District Engineer,
Salem.

Sir,

I agreeably to your endorsement dated 17th Current, N^o 246, I have the honor to report that the roof of the East or western room of the Anglo Vernacular School house at Tripatore has fallen in. The causes thereof are decayed timber used as rafters, the rafters of insufficient scantling for a room 12 feet wide; and a very heavy semi terraced roof, consisting of 3 courses of terraced bricks instead of 3 courses of thin flat tiles. The doors and windows of this room (made of inferior jungle wood, mixed with pieces of deal wood) are in pieces.

2. The

2. The materials above referred to are not required for any work in the Tripstone Range.

3. Provision has been made in the estimate now submitted for repairing the building & dismantling the walls of the last room and to remove all debris.

Phone Sea
Signed W. H. Hiscor
Range Officer

District Engineer's Office,
Salem 25th June 1895.

N^o 49
Submitted to the Secretary
to Government with reference to
G. O. 118 dated 15th June 1895.

J. Webster Major R.E.
(District Engineer)

Encs.

2. The materials above referred
to are not required for any work
in the ^{8015 June 15 2-16 8 min. aft.}

3. Pr
in the
for repa-
dissem on
last per
debris.

East West 6 3 2 1
S. S. Section 4
S. C. 16-7-75

Department

Communicated to the Education

N^o 49

In
to Gov
S. C. 16-7-75

12126-127
Dep 2605-25-6-25-82

District Engineer

June 29.

1875 Sept.
From
The District Engineer
Salem.
To
No: 4214
The Secretary to Govt.
C. P. W.

Dated 25th
Recd 28th June 1875.

N^o 49

Forwards copies of
a letter from the Of-
ficer in charge of
the Trip at me Range
reporting on the
Western Room of the
Government School
house at Trip at me.
With Order

2. The materials above referred
to are not required for any work
in the

3. P
in the
for repa
diment
last pa
debit

4214
Govt. of 1875 Madras,
PUBLIC WORKS.

To

The Public Dept.

Dated

Issued

Recd.

G. O. 5th Mile

Encl.

1875, 18th 1873

Nos. 126 - 127

Western Room of the Govt.
School house at Tripatore

Letter of the Dtr. Engineer,
Salow, forwarding copy of
the letter from the officer
in charge of the Tripatore
Range, reporting on the
the Educational Dept.

With Dr

District Engineer

N^o 19

To
As. Genl.
S. C. A.

Rept 60052/675

Recd.