

(1) Number of pages 20 10  
(2) Date of repair 5/9/86  
(3) Initials of the Referencer gms

# TAMIL NADU ARCHIVES

GOVERNMENT OF TAMIL NADU

*Public Works* DEPARTMENT

|          |          |        |
|----------|----------|--------|
| G.O. No. | 3131(W)  | Press. |
| B.P. No. |          | Mis.   |
| Dated    | 5-8-1878 |        |

Not to be folded or roughly handled.

Archives I-10,006-19-4-79.

*Copy*

GOVERNMENT OF MADRAS.  
PUBLIC WORKS DEPARTMENT.

5th August 1878, No. 3,131 W.

Buildings and Roads.  
Civil Works.

Read the following papers :—

No. 47. From Colonel A. S. MOBERLY, R.E., District Engineer, Cuddapah, to the Chief Engineer, Buildings and Roads, dated Kadiri, 20th July 1877, No. 932.

I HAVE the honor to forward for approval and early sanction two plans, a specification report, and abstract estimate amounting to Rupees 310, for repairing the Munsif's Court-house at Nundalore, and to state that the necessity of the work is explained in the report.

2. There are no funds at my disposal available for this work except the 300 Rupees sanctioned in the Budget for Provincial Service for "Court-houses" in the three ranges of this district.

No. 47-A. From Lieutenant-Colonel J. N. HUNTER, R.E., District Engineer, Cuddapah, to the Chief Engineer, Buildings and Roads, dated Cuddapah, 29th July 1878, No. 1,032.

With reference to your memorandum No. 2,084, dated 27th July 1877, I have the honor to submit for approval and sanction two sheets of plan, a specification report, and abstract estimate, amounting to Rupees 485, for repairing the main building, out-house, and compound wall of the District Munsif's Court at Nundalore, and to state that, agreeably to your instructions, an estimate, amounting to Rupees 364, for repairing the roof of the building has been locally sanctioned and work completed last year.

2. The present estimate is prepared at the request of the District Judge who has countersigned the same on approval, and the amount can be met from the repair allotment under Civil Buildings sanctioned this year.

No. 48. ORDER THEREON, 5th August 1878, No. 3,131 W.

The plans and estimate of Rupees 485 for repairing the main buildings, out-houses, and compound wall of the District Munsif's Court at Nundalore are sanctioned for execution from funds at the disposal of the District Engineer.

2. This sanction has been registered as Provincial No. 71 B of 1878-79.

(True Extract.)

(Signed) E. A. FOORD, Colonel, R.E.,  
Secretary to Govt., P.W.D.

(True Copy.)

Major, R.E.,  
Under Secy. to Govt., P.W.D.

To the District Engineer, Cuddapah.  
" Examiner of Public Works Accounts.  
" Judicial Department.

Encl. T. D. Ryan  
8 pure Copies

3131

11

Accepted for

James H. [unclear]  
[unclear] [unclear]

If the Estimate is sanctioned early, the work <sup>will</sup> be completed <sup>as early as possible</sup> before the Court reopens for work, which will be about

the 2<sup>nd</sup> of May next.

This estimate provides for every  
thing necessary to be done, so  
that no supplemental estimate  
will be required.

Camp Verde

26<sup>th</sup> April 1878

E. R. R. R.  
Salary Business  
J. Schowry

Lieutenant Ranger  
12<sup>th</sup> May 1878

Ranger office

J. W. Hunter Lieut. Col. R. C.  
District Engineer

J. W. Hunter  
Ag. District Judge

the 28th of May next -  
1885

Report to accom-  
pany the estimate  
for repairing the  
Mundacolli Prison  
Court House,  
Pulhampton Sahy.

3131

Specification to accompany the  
estimate for repairing the Mundacolli  
Court House at Mundacolli in  
the Pulhampton Sahy, District  
of Buddapak.

Amount 1. Amount of Estimate Rs 742-0-0  
Nature of 2. The estimate provides for thorough-  
Work ly repairing the Court House, ex-  
cept the roof which has already  
been done, paving the floor with  
granite stone, repairing the  
out offices thoroughly, building  
the compound wall where it  
has fallen fixing a new Gate  
and painting the doors and  
windows of the Court House  
with 2 coats of green paint.

Whitewash 3. Before commencing to whitewash,  
ing the old coat of whitewash will  
be scraped off, and walls well  
cleaned and grease removed. The  
whitewash will be of such con-  
sistency that to drop immediately  
from the brush & dipped into it,  
and 1/2 pint of lime used  
there will be 1 1/2 pottins of gum  
and 1/4 measure of raw rice added.  
The second coat of whitewash  
is not to be applied until  
the first is thoroughly dried.

4- Before any plastering is done, the old plaster will be entirely removed and the joints raked out to a depth of half an inch and the surface well wetted with water. The plaster will be made of one part lime and two of sand well mixed and beaten up with water. The first coat will be laid on half an inch thick and left in the rough and before it is thoroughly dried, the second will be applied. The second coat will be about 1/4 inch thick and as soon as applied will be rubbed down smooth.

5- The mortar for pointing will be composed of 1 part lime and 2 of sand well ground together. In pointing the wall, the joints are to be first raked out to a depth of about 2 inches.

Mortar made of

6- The tiles of the Office will be old tiles and Ch

will be entirely new and the tiles relaid with care and new Chumam borders.

7- Before commencing to paint, the doors and windows are to be thoroughly scoured and

2/3

Concrete

Stone in mud

Stone Flooring

Materials

plaster will be first ground on a stone with oil sufficient to saturate it to a fine paste. When it is to be applied, a larger quantity of oil is to be mixed to render it fluid, after which it is to be strained and then applied.

8- Concrete will be made of 1 part of lime, 2 of sand and 6 of broken stone well mixed together with a little water. It will be laid to 4 1/2 inches in thickness and well rammed to 3 inches. 9- Each course of stone in mud will have bond stones at every 6 or 8 feet. The mud will be well worked into a puddle before being used.

10- The stones for flooring will be brought from Bird's nest and each stone will be 2' x 2' x 1/2' feet in dimensions, well dressed round all four sides. The bed for the stones will be levelled by the old floor being removed, and the joints are to be closely fitted and pointed with fine mortar.

11- Sand from Cheyair River 2 furlongs. Lime 1 1/2 miles distance. Stone 1 1/2 miles from end of Tank. Mortar stone 1 1/2 miles.

Camp Mundalora  
26th April 1898

C. Wady  
Sally Anderson

Lidiant Range  
12 May 1878

Lidiant Range office

I understand that  
District Engineer

to the (C) the  
Ag. Secy. of the

12 May 1878

Specification to  
accompany estimate  
for repairing the  
Koonseiffi Court  
at Madras.  
See - the estimate  
in the - Cuddalore  
office.

Buildings & Roads

No. 1032

District Engineer's Office,  
Cuddalore, 26<sup>th</sup> July 1878.

From

The District Engineer,  
Cuddalore.

To

The Chief Engineer,  
Buildings & Roads Branch,  
Madras.

Sir,

With reference to your memorandum No.  
2084 dated 27<sup>th</sup> July 1877 I have the honor to sub-  
mit for approval and sanction 2 sheets of plan,  
a specification, Report and abstract estimate  
amounting to Rupees 485 for repairing the main  
building, outhouse and compound wall of the District  
Koonseiffi Court at Madras and to state  
that agreeable to your instructions an estimate  
amounting to Rupees 364 for repairing the roof  
of the building has been locally sanctioned  
and work completed last year.

Your most best friend,

J. W. Hume, Lieut. Col.  
N. C.,  
District Engineer

From D. 2084 of 27 July 1877

Buildings & Roads

From

The District Engineer,  
Cuddapah.

To

The Chief Engineer  
Buildings & Roads  
Branch,  
Madras.

Dated 26th  
Recd. } July 1878.

No. 1032

Enclosures 5  
+ 2 Nos.

District Munsiff's court at  
Mandalore. ~~Submits for sanction~~  
Estimate re for repairing the  
main building, out house and  
compound wall of the ~~same~~.

Buildings & Roads

N<sup>o</sup> 932

P. R.

Cuddapah District Engineer's office  
Camp Madani. Dated 27<sup>th</sup> July 1877.

From

The District Engineer  
of Cuddapah

To

The Chief Engineer  
Buildings and Roads Branch  
& Mandalore

Sir

Enclosures 5

I have the honor to forward for  
approval and early sanction, 2 plans, a specification  
Report and abstract Estimate amounting to  
Rs 810 for repairing the Munsiff's Court House  
at Mandalore and to state that the necessity  
of the work is explained in the Report.

2. There are no funds at my disposal avail-  
able for this work except the 300 Rupees sanction-  
ed in the Budget for Provincial Service  
for "Court Houses" in the three Taluques of  
this District.

I have the honor to be

Sir

Your most Obedient Servant

A. M. S. C. S. D.

Copy  
to

Buildings and Roads.

From  
The District Engineer  
of Cuddapah  
To The Chief Engineer  
for Buildings and Roads  
Madras

Dated 20<sup>th</sup>  
Sept 22<sup>nd</sup> } July 1877  
Recd

N<sup>o</sup> 932

N<sup>o</sup> of Enclosure 5<sup>th</sup>

\* Returned.

Mونسيفف Court House at  
Mundalare:—

Forwards an Estimate amount-  
ing to Rs 810 for repairing the

No 3134

P. W. D.  
Works

Proceedings of the Madras Government  
under date the  
5<sup>th</sup> Aug 78.  
Read the following.

From  
The District Engineer,  
Cuddapah } H. E. N<sup>o</sup> 932 dated 22<sup>nd</sup> July 1878

Do

H. E. N<sup>o</sup> 1032 — 26<sup>th</sup> —

The plans and estimate  
of Rupees 485, for repairing the  
main buildings, out-houses, and  
compound Wall of the District  
Mونسيفف Court at Mundial,  
are sanctioned for execution  
from funds at the disposal  
of the District Engineer.

Wt

2/0

This sanction has been  
registered as Borminal No. 713  
of 1878-79.

District Engineer,  
Cuddapah

Examined P. W. Accounts with Estimate

Judicial Department

Recd. 11-8-78

1683/11/5

Act. of (1878) Madras.  
PUBLIC WORKS.

To The District Engineer  
Cuddalore

Dated

Month

Year

Encl.

At the S. A. 1878, No. 3/31/1878

No.

District Engineer's Office  
at Cuddalore

Sanctioned plan  
estimates for repairing  
the main sea bridge, and house  
and compound wall of the

✓

Act.