

(1) Number of pages 12.
 (2) Date of repair 23-10-86
 (3) Initials of the Referencer lang

TAMIL NADU ARCHIVES

GOVERNMENT OF TAMIL NADU

Public works DEPARTMENT

G.O. No.	4720(10)	Press.
B.P. No.		Mis.
Dated	10-12-1878	187.

297.

to be folded or roughly handled

4720
1

GOVERNMENT OF MADRAS.
PUBLIC WORKS DEPARTMENT.

10th December 1878, No. 4,720 W.

Buildings and Roads.
Military Works.

Read the following paper :—

No. 133. From J. W. RUNDALL, Esq., District Engineer, Bellary, to the Chief Engineer, Buildings and Roads, dated Bellary, 10th October 1878, No. 2,845.

I HAVE the honor to submit, for the sanction of Government, an estimate of Rupees 277 accompanied by a plan and report for constructing a new cistern for soaking tent pegs, &c., at the Arsenal, Bellary.

2. The present cistern is so situated that, the stench from the soaking bamboos and tent pegs is an intolerable nuisance to persons passing in and out of the lower fort, besides being prejudicial to the health of the men on the Main Guard and in the Garrison Prison in its vicinity. The use of this cistern has therefore been ordered to be discontinued by the Brigadier-General, and it is proposed to build a new cistern in a less objectionable situation.

3. The estimate has been approved by the Commander of the Forces.

4. Funds can be provided from the budget assignment for "Minor New Works, Military," for this district.

5. As the work is considered to be urgent early sanction to the estimate is solicited.

No. 134. ORDER THEREON, 10th December 1878, No. 4,720 W.*

THE plan and estimate of Rupees 277 for constructing a new cistern for soaking tent pegs, &c., at the Bellary Arsenal are sanctioned.

2. The Superintending Engineer will provide the necessary funds.

3. This sanction has been registered as Imperial No. 113 B of 1878-79.

(True Extract.)

Colonel, R.E.,
Secretary to Govt., P.W.D.

To the Superintending Engineer, Second Circle.
" Examiner of Public Works Accounts.
" Military Department.

Exd. C. Howarth.
Spare Copies]

UNITED STATES
MINISTRY OF WAR
OFFICE OF THE
CHIEF OF ENGINEERS
PUBLIC WORKS

THE SUPERINTENDING ENGINEER,
WASHINGTON, D. C.

RECEIVED

NOV 13 1891

For the purpose of providing a
plan of the proposed work
and for the construction of a new

Report to accompany the estimate of the cost of constructing a
cistern at the Arsenal.

22

Amount \$247.

The cistern will be of the form and
dimensions shown in the plan viz. interior capacity $20 \times 8 \times 2 \frac{1}{2}$.
it will be constructed of the best hammer dressed stone masonry
plastered on the inside with three coats and pointed on the outside, the
side walls will have a double coping of the same breadth as the walls.
It is to be erected at the site pointed out by the Ordnance Officer near
the South end of the gun shed the waste water will have to
fall into the great moat and as the floor of the new cistern
will, like that of the old one be below ground it is proposed to
pierce the Rampart and its stone pavement by an iron pipe as
shown in the section, the pipe is to be 14" in diameter to allow
of its being cleaned by means of a bamboo rod and friction. It
should be made in three lengths of six feet each with flanges
and bolt joints so that it may be taken up and examined for
repairs or whenever necessary.

Dellaly
19th September 1891

Meyer L. L. B.
Deputy Engineer, Dellaly

cial. to the health of the new in
Main

District Engineers Office
No. 2845. Bellary 10 October 1878.

From

The District Engineer
Bellary

To

The Chief Engineer
Buildings & Roads

Sir.

I have the honor to submit
for the sanction of Government an
Estimate of Rs 277 accompanied by
a plan and report for constructing a
new Cistern for soaking tent pegs &c
at the Arsenal Bellary.

2. The present Cistern is so situated,
that the stench from the soaking
bores and tent pegs is an intolerable
nuisance to persons passing in and out
of the lower Fort, besides being prejudi-
cial to the health of the men on the
Main

8.8.78

(5)

Main guard, and in the Garrison Prison
in its vicinity. The use of this Cistern
has therefore been ordered to be discon-
tinued by the Brigadier General, and
it is proposed to build a new Cistern in
a less objectionable situation.

3. The Estimate has been approved
by the Commander of the Forces.

4. Funds can be provided from the
Budget assignment for "Minor New
Works - Military" for this District.

5. As the work is considered to be
urgent, early sanction to the Estimate
is solicited.

I have the honor to be
Sir,
Your most Obedt. Servant
Geo. P. P. P.
District Engineer

From

The District Engineer
Bellary

To

The Chief Engineer
Buildings & Roads
Madras

Encl. 3. - No 2845

Dated 10 Oct. '98
Recd. 1 October 1898

Cistern for soaking tent
pegs at the Arsenal
Bellary -

Submitting for sanc-
tion of Government, an
Estimate of Rs 277 for
constructing a -

PROCEEDINGS OF THE MADRAS GOVERNMENT.

Under date the 10 Dec 90
Read the following: -

From the Dy Sup Bellary (H.E. No 2845 of 10 Oct 90)

The plan and
estimate of Rs 277 for
constructing a new cistern
for soaking tent pegs
at the Bellary
Arsenal are sanctioned.

Govt. letter received.
The Dy. Engr. provides
funds. & the Engineer work.
must be started. While
be must not hinder Arsenal
work now.

S. Engr. Second Circle
Exr. Mr. Asst. Engr. Bellary
Encl. 3. -

Dec 19-12-98

Land use not
available for the

2. The Dy. Engineer
will provide the necessary
funds.

3. This sanction has been
registered as Imperial No. 1131 of
10.12.90.

C. 1128

Dept. of (1928) Public Works

PUBLIC WORKS

The City of Grand Creek

121

...

...

...

...

at 10 Dec 1871 4720 W

...

Certain for making lent
page 9 at the Arsenal
Bellary Rancione plan
of building for constructing
a wall —

...