D. P. W.
SOUTH ARCOT. No. 145

DISTRICT ENGINEER'S OFFICE.

Camp Cuddalore
Dated 29th June 18

FROM

THE DISTRICT ENGINEER,
SOUTH ARCOT.

Roads and Buildings

TO

THE CHIEF ENGINEER
D. P. W.

Enclosures

1 Copy of Estimate

Sir,

I have the honor to forward for your information copy of an Estimate lately received from the Officer Vridachellum Division for certain alterations proposed by him at the desire of the Deputy Collector in charge of the Taluq, to the Taluq Cutcherry at Kallakurichi. The Estimate has been forwarded to the Collector and I propose sanctioning it on its return with his approval.

2. The Cutcherry was built only last year according to the Standard design, it would appear from the remarks appended to the

the Estimate that through the
eave openings of the record room
and 2 windows openings of the
Stair case room rain water
entered the Building and
spoiled records besides causing
inconvenience to the clerks in
the room below; also that
through the venetion of the
wooden turret water beats
in; and that a parapet or
iron railing is required at the
door of the record room at the
Stair case.

3. I myself inspected the
building on the 20th Instant and
noticed the above defects. I
would therefore submit for
consideration whether it would
not be advisable to alter
the Standard Plan so as to
remidy these palpable defects.

I

I have the honor to be
Sir,
Your most obedient servant
J B Pemberton C. E.,
Offg District Engineer.

Ohs 1986 8/13 July/75

1878 Dept.
1
No. 7331

Roads and Buildings

FROM DISTRICT ENGINEER,
SOUTH ARCOT.

Mem No 3114 B of 5-12-78

No. 145

Dated 29-
Despatched 29-
Received 1 July } June/78

No. of Enclosures 1

Taluq Cutcherry at Kullacurchy — Brought to notice certain defects in the — and submitting for consideration whether it would not be advisable to alter the standard plan so as to remedy these defects.

6 E No 2973 of 6 July/78
Referred to the Cons Archt for remarks

E A Irwin

Referred

To Coty 4-7-78

ROADS AND BUILDINGS.

No. 520

CONSULTING ARCHITECT'S OFFICE,
Chepauk, 24th November 1879.

FROM
THE CONSULTING ARCHITECT TO GOVERNMENT,

To
THE CHIEF ENGINEER, PUBLIC WORKS DEPARTMENT,
BUILDINGS AND ROADS BRANCH.

SIR,

I have the honor to reply to your Memo No. 2973 dated the 6th July 1878.

Enclosures.
1 Tracing.

In the new Taluq Cutcherries the pain is said to beat into the record room and to run down the Invret stairs. I think it would be advisable to add a blocking course to the eaves from the top of the wall to the underside of the purlin and to nail a ½" plank above the venetians in the Invret spire. Small windows might also be put in the loop holes and a door added at the top of the spiral to protect the records. This door is provided in the Estimate but not shown on the plan. I submit a tracing embodying these proposals in red.

I have the honor to be
sir
your most obedt. servt.

Cons. Archt. to Govermt.

13.7.75 No 1986
28.11.79 - 3575 Cs.

P.W.D.
25NOV79
No. 8377

ROADS AND BUILDINGS.

From

The Consulting Architect
to Government,

To

The Chief Engineer, P. W. Department,
Buildings and Roads Branch.

No. 520

Dated 24th November 1879

Received

No. of Enclosures. /

Modifications of certain points in connection with the Standard design for Taluq Cutcherries.

Enclosure B
Memo: No. 2973
d/6/7/78 called
for -
Received with Current No. 8549 -
(C.A's No. 533 d/1st Dec 2/79)
separately lodged.

8379

Mr Jackson.

Put up copy of
Standard plan for
D.E.W's reference.

J.F.
1/12

Mrs A: 3114 Tr of 5th December/79

Standard plans
for
[illegible]

I.M.P.
2-12-79.

Richmond
Coast.

Sandhurst

P. W. SECRETARIAT—1879-80.

KEEP-WITH.

Current No. 8379

Letter No. 520

Dated the 24th Novr. 1879

from the Consulting Architect to Govt:-

Note of Remarks.

Re Distr: Est: for petty alterations to the Taluq Cutcherry at Kallakurichie in South Arcot Distt, amounting to Rs: 60. The Distr: Est: provides for closing the cane openings of the record room & window openings of the staircase to prevent rain beating in & sundry repairs to doors. This being referred to the C. Architect for remarks, submits a tracing along with a letter of explanation embodying his remarks, & with that an Est: of quantities.

The Distr: Est: has been Exd. & found correct.

3/12/79 J. H. L

Read

No 3114 W

P. W. Department.

PROCEEDINGS of the MADRAS GOVERNMENT.

Under date the 5th Decr. 1879

READ the following

From the ~~D.E.~~ Engr S. Arcot (D.E. No 145 of 29 June/78

From the Consg. Architect (H.E. No 520 of 24th Nov/79)

The Consulting Architect's proposals are sanctioned, and the Supg Engineer is requested to arrange for giving effect to them.

D 5:12

Despd to Supg Engr Third Circle with the plan received from the Consg Architect's letter No 520 of 24 November 1879 and estimate received from the Distt Engr South Arcot

Despd to Consg Architect

Despd 6-12-79. Lee

5.12.79

P.H. 84

3114

✓

Mus A-3114 W 8 5: Dec 93

130–131