

No. 1162

MADRAS,

Chepauk, 29 June 1886.

From

THE SUPERINTENDENT OF WORKS,
PRESIDENCY,

To

The Chief Engineer,
P. W. Dept.

Sir,

Enclosures.

I have the honor to inform you that upon a requisition from the Secretary and Treasurer of the Monegar Choultry for an estimate for the repair of the roof of the Infirmary attached to that Institution, as called for in para 10 of G. O. Public Department, No. 621 of the 4th ultimo, the building was examined and the roof found to be in a very dangerous condition. The rafters and collar pieces of couples were found broken in four places, and the whole roof is much sagged. It is probable that when the roof is dismantled much of the timber will be found to require renewal. The roof has

has been temporarily supported at the points where the timber has given way, and the cots of the patents have been removed from under these places.

2 An approximate Estimate of Rs. 1980 has been prepared for the repair of this roof and considering that it is absolutely unsafe, I have ordered the repairs to be undertaken on emergency. But, as I have not as yet received any orders in the Public Works Department ^{referred} upon the G.O. in the Public Department above quoted, I request that I may be favoured at an early date, with the orders of Government in the P.W. Dept. on the subject.

I have the honor to be
Sir,

Your most obedient servant,

W. H. Thompson Esq. for R.R.

Superintendent of Works
R.R. Co.

W.H.

P. W. C. No 3813

From

The Supt. of Works,
Presidency.

No 1162.

dated. 29th June 1881.

Recd. 30th July 1881
No 1687 was 8th July 1881.

To/ Loaded with ref. 1st July 1881
Supt. of Works
19/7/81
D.W.

Infirmity attached to the
Monegar Choultry.

Reports unsafe condition
of the roof of the —
& that an Estimate of
Rs. 1980 has been prepared
for its repair & requests
orders.