

(1) Number of pages 10
(2) Date of repair 30.7.82
(3) Initials of the Referencer long

TAMIL NADU ARCHIVES

GOVERNMENT OF TAMIL NADU

P.W. DEPARTMENT

G.O. No.	3488-W	Press.
B.P. No.		Mis.
Dated	5-12-1883	198

Pl.

DV

Not to be folded or roughly handled.

GOVERNMENT OF MADRAS.

PUBLIC WORKS DEPARTMENT.

Buildings and Roads.
Civil Works.

READ—the following letter from the Assistant Engineer, Máyavaram, to the Executive Engineer, Tanjore, dated Camp Chittár Head, 24th November 1883, No. 1396:—

I have the honor to report, for your information, that the block of building adjoining the police hospital and civil dispensary at Tranquebar, known as the old range office, is in a dangerous condition. The roof of the room, marked A on the accompanying sketch, came down during the rains of the early part of this month, owing to the ends of the palmyrah couples in walls having rotten away.

The roof to room C is also showing signs of weakness from the same cause. The roof to other rooms with couples are, no doubt, in much the same condition, though not outwardly observable at present. I have had all the roof of A removed, and that to C propped up where it has shown signs of coming in. None of the rooms in the building are occupied except FF, and that temporarily by the hospital as cook-room and godown. These rooms, which have a "lean-to" roof, are, with E, which is terraced, in fair order.

The terraced roof to porch D is in a dangerous state, and must be pulled down.

On applying to the Acting Zillah Surgeon of Tranquebar to know whether he wished to have the use of any of the rooms in the building in connection with the police hospital, that officer has replied to the effect that he should like to be allowed to keep the rooms FF and E.

There being no use for the other portion of the block, I would recommend that it either be pulled down and the materials sold by public auction, or the materials sold as they stand, to be removed at the cost of the purchaser.

The south wall to remain as a boundary wall. The openings a-a and door, can be easily blocked up.

No. 3439.

Forwarded to the Superintending Engineer for instructions. I think it is unlikely that the building will ever be required, and would recommend Mr. Baker's suggestions being adopted.

25th November 1883.

(Signed) W. HUGHES,
Executive Engineer.

No. 1750 T.J.

Endorsement on the above.

Forwarded to the Chief Engineer, Public Works Department, with a request that Mr. Baker's proposal may be sanctioned. The plan of the building is herewith forwarded for inspection and obliging return.

TRICHINOPOLY,
30th November 1883.

(Signed) H. R. MEAD, Lieut.-Col., R.E.,
Superintending Engineer, Sixth Circle.

ORDER—dated 5th December 1883, No. 3488 W., Public Works.

Sanctioned.
(True Extract.)

Major, R.E.,
Under Secy. to Govt., P.W.D.

To the Superintending Engineer, Sixth Circle, with one enclosure.
„ Examiner, Public Works Accounts.

Exd. E. Fernandez.
Spare Copies

BUILDINGS AND ROADS.
CIVIL WORKS.

Govt. of (1883) Madras.

PUBLIC WORKS.

Dated December, 5th.

Recd.

Encl.

G.O., 5th Dec. 1883, No. 3488 W.

DECEMBER.

Range Office

The proposals of the Superintending Engineer, Sixth Circle, in regard to the disposal of the building known as the old — at Tranquebar, sanctioned.

No. 1396

Camp Chellam Head
24th November 1883

From
The Assistant Engineer
Mayavaram.
To
The Executive Engineer
Tanjore.

Sir,

I have the honor to report for your information that the block of building adjoining the Police Hospital and Civil Dispensary at Tranquebar, known as the old Range Office, is in a dangerous condition. The roof of the room marked A on the accompanying sketch came down during the rains of the early part of this month, owing to the ends of the palmyrah couples in walls having rotten away.

The roof to room C is also showing signs of weakness from the same cause. The roof to other rooms with couples are no doubt in much the same condition, though not outwardly observable at present, I have had all the roof of A removed, and that to C propped up where it has shown

signs

BUILDINGS AND ROADS.
CIVIL WORKS.

Gobt. of (1883) Madras.

PUBLIC WORKS.

Dated December, 5th.

Recd.

Encl.

G.O., 5th Dec. 1883, No. 3488 W.

DECEMBER.

Range Office

The proposals of the Superintending Engineer, Sixth Circle, in regard to the disposal of the building known as the old — at Tranquebar, sanctioned.

No. 1396

24th November 1883

Trans.

The Assistant Engineer
Mayabaram.

To The Executive Engineer
Tanjore.

Sir,

I have the honor to report for your information that the block of building adjoining the Police Hospital and Civil Dispensary at Tranquebar, known as the old Range Office, is in a dangerous condition. The roof of the room marked A on the accompanying sketch, came down during the rains of the early part of this month, owing to the ends of the palmyrah couples in walls having rotted away.

The roof to room C is also showing signs of weakness from the same cause. The roof to other rooms with couples are no doubt in much the same condition, though not outwardly observable at present. I have had all the roof of A removed, and that to C propped up where it has shown

signs

Both
clerks

Mr. W. 10709

3488

No. 3488 Ways Dept

From,

The Supr Engineer
6: Circle

To,

The Chief Engineer
P. W. D.

Sanctioned
Sanctioned

Cy.

4/12

No 1750 T.F

Dated 30: November/88.

3/12/88

encl: 1. Sketch

Old Range office
trailings at Tranquebar

Forwarded copies

SW
12/12

of correspondence
in regard to the di-
lapidated state of
the — + recommends
that a portion of —
may be pulled down

St. L. L. L. L. L.
S. S. S. S. S. S.
Box 222, P. W. D.

with order

10709

Govt. of (1883) Madras.

PUBLIC WORKS.

Dated

By

For

G.O. 5th Dec 1883, No. 3486. N

Range Office

The proposals of the
Supt. Engr. to erect
in regard to the de-
posal of the building
known as the old
at Tranquebar,
Sanctioned

40
/ 3

1037