(1) Number of pages 46

(2) Date of repair Jan. 88

(3) Initials of the Referencer Cova

# TAMIL NADU ARCHIVES

---

## GOVERNMENT OF TAMIL NADU

P. Tr. D DEPARTMENT

G.O. No. / B.P. No. 1430 Tr.

Press. / Mis.

Dated 7.6.1886 ~~198~~.

*Not to be folded or roughly handled.*

1430/1

## GOVERNMENT OF MADRAS.

## PUBLIC WORKS DEPARTMENT.

---

**Buildings and Roads.**
**Civil Works.**

Read—the following papers :—

From Colonel J. BEATTY, R.E., Superintending Engineer, IV Circle, to the Chief Engineer, Public Works Department, dated Coimbatore, 14th May 1886, No. 149 E.W.

I have the honor to forward, for sanction and provision of funds, five estimates as follows :—

| | RS. |
|---|---|
| I. Providing lightning conductors to Government House, Ootacamund ... ... ... ... ... ... ... | 2,400 |
| II. Providing lightning conductors to St. Stephen's Church at Ootacamund ... ... ... ... ... ... ... | 1,550 |
| III. Providing lightning conductors to Collector's office at Ootacamund ... ... ... ... ... ... ... | 1,970 |
| IV. Providing lightning conductors to Place of Arms on Bombay Castle Hill ... ... ... ... ... ... ... | 720 |
| V. Providing lightning conductors to Bombay Castle ... ... | 1,350 |

and to inform you that the estimates for providing lightning conductors for the Government offices and Council Chamber and Powder Magazine at Ootacamund will be submitted as soon as received from the Executive Engineer, Nílgiri division, to whom a reminder has this day been sent.

2. Although not called for in the G.O., No. 324 W., of 6th February 1886, the estimates, Nos. 2 to 5, have been prepared and submitted, as it is thought that the buildings are likely to be struck with lightning from their height or exposed situation.

3. I have also to inform you that the combined Post and Telegraph office at Ootacamund has already been provided with lightning conductors.

---

From the same officer, dated Coimbatore, 16th May 1886, No. 152 E.W.

With reference to the estimate for lightning conductors to Government House, Ootacamund, submitted with my letter, No. 149 E.W., of 14th May 1886, which is a work that was not provided for in the general estimate, I have the honor to inform you that it will have to be charged against savings effected on sub-heads of the above estimate. It may probably be most properly charged to sub-head, No. 3, "Constructing new Government House," but on this I shall report further after making a reference to the Executive Engineer.

---

From the same officer, dated Coimbatore, 16th May 1886, No. 156 E.W.

In continuation of my letter, No. 148 E.W., of 14th instant, I have the honor to forward, for sanction and provision of funds, the following three estimates, amounting in all to Rs. 3,570, viz. :—

| | RS. |
|---|---|
| I. Providing lightning conductors to Government offices on Stonehouse Hill ... ... ... ... .. ... | 1,850 |
| II. Providing lightning conductors to Council Chamber and Clock Tower on Stonehouse Hill ... ... ... ... ... | 730 |
| III. Providing lightning conductors to clerks' quarters on Stonehouse Hill ... ... ... ... ... ... ... .. | 990 |
| Total ... | 3,570 |

2. The specification attached to the estimates submitted with my letter, No. 149, of 14th idem, will be generally applicable to the above estimates also.

---

From the same officer, dated Coimbatore, 31st May 1886, No. 186 E.W.

In continuation of my letter, No. 152, of 16th instant, I have the honor to inform you that there was a saving up to 1st May 1886 on sub-head, No. 3, of the Government House completion estimate, amounting to Rs. 8,415, and against this I propose to charge the cost of lightning conductors, viz., Rs. 2,400, for which an estimate was submitted with my letter, No. 149, of 14th instant.

---

ORDER—dated 7th June 1886, No. 1430 W., Public Works.

The estimates for providing lightning conductors for the under-mentioned Government buildings at Ootacamund are sanctioned, and classified as Civil Buildings, Original Works :—

| | RS. | | | | |
|---|---|---|---|---|---|
| (1) Government House ... ... | 2,400 | Provincial | No. | 37 W. of | 1886-87. |
| (2) St. Stephen's Church ... | 1,550 | ,, | ,, | 38 W. of | ,, |
| (3) Place of Arms on Bombay Castle Hill ... ... | 720 | ,, | ,, | 39 W. of | ,, |
| (4) Bombay Castle ... ... | 1,350 | ,, | ,, | 40 W. of | ,, |
| (5) Government offices ... ... | 1,850 | ,, | ,, | 41 W. of | ,, |
| (6) Council Chamber ... ... | 730 | ,, | ,, | 42 W. of | ,, |

2. The cost of providing lightning conductors for Government House will, as proposed by the Superintending Engineer, be met from savings on sub-heads No. 3 of the general estimate referred to in G.O., No. 1015 W., dated 9th July 1883. The question of providing funds to meet the cost of the other estimates will be considered in connection with the statements of demands for incomplete and minor works.

3. Lightning conductors for such comparatively low buildings as the clerks' quarters on Stonehouse Hill and the Collector's office are not considered necessary.

4. The submission of an estimate for attaching lightning conductors to the Powder Magazine at Ootacamund should be expedited.

(True Extract.)

Major, R.E.,
Under Secy. to Govt., P.W.D.

To the Superintending Engineer, IV Circle, with the unsanctioned estimates.
,, Examiner, Public Works Accounts, with the sanctioned estimates, for note and return to Superintending Engineer, IV Circle.
,, Revenue Department.
,, Military ,,
,, Ecclesiastical ,,
,, Military Secretary to His Excellency the Governor.

Exd. A. Aubert.
Spare Copies

copper

BUILDINGS AND ROADS.
CIVIL WORKS.

# Govt. of {1886} Madras.

PUBLIC WORKS.

*Dated June, 7th.*

*Recd.* *Encl.*

**G.O., 7th June 1886, No. 1430 W.**

JUNE.

## Government Buildings at Ootacamund

Orders sanctioning estimates for providing lightning conductors for certain —.

---

1430/3

Public Works Department, 1886-87.

Current No. 3695

Letter No. 149/E.W.

Dated the 14th May 1886

From the Suptg. Engr. IV Circle

A.B. 1430 W 7/6/86

NOTE OF REMARKS.

1. The accompanying estimates are for providing Lightning Conductors for the below mentioned various Government Buildings at Ootacamund.

(I) Providing Lightning Conductors to Government House Ootacamund ---- Rs. 2,400.
(II) Do. Do. to St. Stephens Church at Do. ---- " 1,550
(III) Do. Do. to Collector's Office at Do. ---- " 1,970.
(IV) Do. Do. to place of Arms on Bombay Castle Hill ---- " 720.
(V) Do. Do. to Bombay Castle ---- " 1,350.

2. The minimum size of copper tape allowed in Standard Specification Appendix A Page 8 is 3/4" × 1/8" ~~for copper~~ tape but that allowed in the estimate is 1 1/4" × 1/8" which is rather more in width.

3. The same may be said of the copper

copper saddles and circuit details that they are greater in width by 1/4" of an inch than that laid down in the Standard specification Appendix A.

4. The terminals in the estimate are 3/4" in diameter but that allowed in Standard Specification Appendix A is only 3/8".

5. Coronals. The proper lengths of the needles attached to the ring is given but it is not stated that they should taper from 1/4" Diamr to as fine a point as can be made.

6. The width and thickness of the earth plates as allowed in estimate are 1 1/4" × 1/8" but the Standard Specification Appendix A allows only 3/4" × 1/8".

7. The estimates for providing Lightning Conductors for the Government Office and Council Chamber and Powder Magazine at Ootacamund will be submitted as soon as received from the Executive Engineer Nilgiri Divisn as noted by Superintg. Engineer in his letter No 149 dated 14th May/86.

8. Further states that estimates from II to V though not included in G. O. No 324 W of the 6th February 1886 are

really

1430/A

really necessary to prevent the buildings being struck with lightning from their height or exposed situation.

9. The specification shows the different places into which the earth plates are to be let in.

10. The combined Post & Telegraph office at Ootacamund has already been provided with Lightning Conductors.

11. The rates cannot be checked from the Distt. Schedule but requires a proper data.

12. The estimates have been countersigned by the proper authorities.

C. S.
20.5.86

To DW

The estimates may be sanctioned, the dimensions given in Standard specification are minimum ones. The estimates for Govt Office & Council Chamber & Powder Magazine will be awaited & the submission of the latter three be expedited

20/5/86

No. 148
3rd

Supg. Engineer's office IV circle
Coimbatore, 14th May 1886.

1430/3

From,
The Superintending Engineer
IV Circle

To,
The Chief Engineer
P. W. D

Sir,

With reference to your Memorandum No. 114 D of 11th Instant I have the honor to inform you that the estimate for providing lightning Conductors for the Government Offices Ootacamund has already been prepared, according to a report received from the Executive Engineer, and has been sent for counter-signature, so that it may be executed immediately.

I have the honor to be
Sir
Your most obt. servant

L. Beatty Colonel RE
Superintending Engineer
IV Circle

P.W.C. No. 3776

No. 142 D d/ May 17. 1886

From

The Supg. Engineer,
Fourth Circle.

Recorded
Record

15.5.86

15 MAY 86

No. 324 W d/ 6.2.86 }
" 114 D d/ 11.5.86 }

Dated 14th } May 1886.
Despd: }
Recd: 15th }

No. 142 D d/ May 17. 1886

No. 148
2nd

Lightning Conductors

Informs that the estimate for providing — to Government Offices Ootacamund has already been prepared and sent for countersignature.

With orders

---

Read the following paper

No: 149
2nd

Supg: Engineer's Office IV circle
Coimbatore, 14th May 18

From,

The Superintending Engineer
IV Circle.

To,

The Chief Engineer
P.W. Department

(430/7)

Sir,

Enclosures 6
1 Specification
5 Estimates

I have the honor to forward, for sanction and provision of funds 5 Estimates as follows:—

| | |
|---|---|
| I. Providing Lightning conductors to Govt. House, Ootacamund — Rs | 2,400 |
| II. — Do Do to St Stephens church at Ootacamund — " | 1,550 |
| III. — Do Do Collectors office at Do | 1,970 |
| IV. — Do Do to place of arms on Bombay Castle Hill — " | 720 |
| V. — Do Do to Bombay Castle — " | 1,350 |

and to inform you that the Estimates for providing lightning conductors for the Government Offices and Council Chamber and Powder Magazine at Ootacamund will

will be submitted as soon as received from the Executive Engineer Nilgiri Division, to whom a reminder has this day been sent.

2 Although not called for in the G.O. No. 324 W., of 6th February 1886 the Estimates Nos 2 to 5 have been prepared and submitted; as it is thought that the buildings are likely to be struck with Lightning from their height or exposed situation.

3 I have also to inform you that the Combined Post and Telegraph Office at Ootacamund has already been provided with Lightning Conductors.

I have the honor to be
Sir
Your most obt servt

E. Beatty Colonel R.E.
Supg. Engineer IV Circle

Wks: 3695

(4):

From
The Supg: Engineer,
Fourth circle.

Dated 14th } May 1886.
Despd: 15th }
Recd 17

No 149/E.W.

Encls. 6.

Lighting Conductors.—
Forwarding for sanction and provision of funds 5 Estimates for providing — to certain buildings at Ootacamund.

---

103

Supg: Engineer's Office 4th Circle
Coimbatore. 16th May 1886.

No 152/E.W.

153/a

From
The Superintending Engineer
4th Circle

To,
The Chief Engineer
P.W. Department.

Ch. 3695 with Wks. 17/5.

Sir,

With reference to the Estimate for lightning conductors to Government House Ootacamund, submitted with my letter No 149/E.W. of 14th May 1886, which is a work that was not provided for in the General Estimate, I have the honor to inform you that it will have to be charged against savings effected on sub heads of the above estimate. It may probably be most properly charged to subhead No 3, "Constructing New Government House," but on this I shall report further after making a reference to the Executive Engineer.

I

I have the honor to be
Sir
Your most Obedt. Servant

L. Beatty - Colonel R.E.
Superintending Engineer
4th Circle.

1420/10

P.W.C. No 3755

(4)

From,

The Superintending Engineer,
Fourth Circle.

Dated 16th } May 1886.
Recd [illegible] }

No. 152/E.W.

Lightning Conductor to Government House Ooty.

Informs that the amount of the estimate for providing — will have to be charged to Sub head No 3 for constructing New Government House.

---

125

No. 156/E.W.

Superintending Engineer's office 4th Circle
[illegible] 16th May 1886.

From,

The Superintending Engineer
Fourth Circle.

To,

The Chief Engineer,
P. W. Department

Sir,

Enclosures
3 Estimates.

In continuation of my letter No. 148 E. W. of 14th Instant, I have the honor to forward for sanction and provision of funds the following 3 estimates amounting in all to Rs. 3570: Viz.

| | | Rs |
|---|---|---|
| I | Providing Lightning Conductors to Government Offices on Stone House Hill | 1,850 |
| II | — Do — to Council Chamber and Clock tower on Do. | 730 |
| III. | — Do — to Clerks Quarters — on — Do. | 990 |
| | Total. | 3570 |

2. The Specification attached to

to the estimates submitted with my letter No. 14[illegible] of the idem will be generally applicable to the above Estm[illegible] also.

I have the honor to be,

Sir,

Your Most obt Sert

L. Beatty - Colonel R.E.
Superintending Engr
4th Circle -

+ not received
in O. & U. [illegible]

x
3695 with 13

1430/12

G.O. 142 D. 17.5.86.
114 D. 11 " "
324 W. 6.2.86.
G.O. 2459 W 3.9.83
" 1915 W 9.7.83
D.W. 3661 W 20.12.83
G.O. 2261 W 13.9.84
" 1632 W 30.6.84
" 2459 W 3.9.83
" 1916 W 9.7.83
" 1915 W 9.7.83
" 2139 W 19.8.82
D.Ry 799 W 24.3.82
G.O. 390 W 11.2.82
" 3038 W 6.12.81
" 3037 W 6.12.81

P.W.D. No. 3839

From
The Supg. Engineer,
Fourth Circle.

19 MAY 86

Dated 16th
Despd. 17th } May 1886.
Recd. 21st

No. 156
S.W.

Encls: 3

Lightning Conductors to Government Offices at Ootacamund:—
Forwarding for sanction and provision of funds 3 estimates amounting to Rs: 3,570 for providing
—.

Resubmitted to G.O. 26.5.86. R. 7.6.86

was Stonehouse among the buildings which S.E. IV was instructed to protect with lightning conductors?

If not, he should now be instructed to take the necessary steps at once.

13/5

10.5.86

W

Please see G.O. of 6.2.86, No. 324 W. The Govt. Offices & Council Chamber are included in the list of buildings to be protected.

For orders whether the S.E. shall be asked to expedite submission of the estimates.

10.5.86

Yes

10.5.86

That allowed in S. Specifica
is only 3/4" x 1/8" —

Letter from S.E. IV Circle
No 156 S.W. d 16.5.86

1430/111

TOW

Proposed to send these estimates to Madras office for scrutiny. —

It seems doubtful whether it is necessary to place a conductor on such a comparatively low building as the clerks quarters.

Funds for the work might be provided in the orders on the demand statements.

Cn
19.5.86

No. it is not included in list published in G.O. of 6.2.86, No 324

SAW

Please send to I.4 [illegible] to SW.

Cn
19.5.86

15.5.86

That allowed in S. Specification is only 3/4" × 1/8" —

Returned to [illegible] 26.5.86 R. 7.6.86

To W

1430 W
1430/15

The estimates (2) to (5) in the accompanying draft order were not called for in G.O. No 324 W of 6.2.86, but the S.E. appears to think that lightning conductors for the buildings in question are necessary.

Cu
1.6.86

I think the proposals may be sanctioned - as in the draft - with exception of W.3 - Collector's Office - which may be omitted for similar reason to that assigned in the case of the Clerks quarters.

Draft should be written afresh.

4.6.86

808

Resubmitted W.C. 1 26·5·86 R. 7·6·86

That allowed in S. Specifica
is only 3/4" × 1/8" —

Public Works Department, 188 -8 .

(14)

Current No. 3839.

Letter No. 156 / E.W.

Dated the 16th May 1886

From the Supt. Engr. [illegible] Circle

NOTE OF REMARKS.

(1) The accompanying estimates are for providing lightning conductors to Govt. Offices at Ootacamund viz

(a) Govt. Offices on Stone House Hill - Rs: 1850

(b) ~~Chancel~~ Council chamber and clock tower on Stone House Hill - Rs: 730

(c) Clerks quarters in Stone House Hill Rs 990

Total Rs: 3,570

2. The size of the copper tape, Saddle and Circuit des faites does not agree with that laid down in Standard Specifications Appendices A page 8. The estimated size is 1¼" × ¼" × ⅛" in thickness but that allowed in S. Specifications is only ¾" × ⅛" —

Resubmitted to C.E. 26·5·86. R. 7·6·86

5·86 R. 7·6·86

(3) The diameter of terminals also requires altering from 3/4 inch to 3/8" as laid down in S. Specification

(4) There is no reference as to how the earth plates are to be fixed or into what they are to be let in.

(5) The Supdt. Engineer IV Circle writes that the specification attached to estimate submitted with his letter No 149 of 14th idem will be generally applicable to the present estimates.

(6) The rates cannot be checked with the Dist: Schedule but require a proper date to each.

(7) The estimates have been countersigned by the Chief Secretary

C. S.
25/5/86

It is not necessary that the dimensions should agree exactly with those given in the standard specification as the latter gives minimum dimensions. The dimensions are recommended for [illegible] with the exception of (c) which [illegible] is not necessary

25/5/86

---

No 3755 sent [illegible] 25/5.

sent [illegible] 25/5.

---

Supg: Engineer's office IV circle
Coimbatore, 31st May 1886.

No 186
P.W.

From,
The Superintending Engineer
IV Circle,

To,
The Chief Engineer
P. W. Depart:

Sir,

In continuation of my letter No 152 of 16th instant, I have the honor to inform you that there was a saving up to 1st May 1886, on sub head No 3 of the Government House completion estimate amounting to Rs 8415, and against this I propose to charge the cost of Lightning conductors viz, Rs 2400, for which an estimate was submitted with my letter No 149 of 14th instant.

I have the honor to be
Sir
Your most obt servant

F. Beatty Colonel R.E.
Supg: Engineer IV circle

(8)

From

The Sup: Engineer,
Fourth circle.

dated 31st May /86
desp: 1st June /86

No: 186
E.W.

Lightning Conductors

states that it is proposed to charge the cost of — viz Rs: 2400 against the Completion estimate of Rs: 8415 on subhead No: 3 of Government House.

---

Public Works Departmen

# PROCEEDINGS OF THE MADRAS GOVERNMENT.

1432/18

Read the followin

From the Supdg. Engr. IV Circle. H. E. No: 149 E. W. d/ 14th May 1886,
——— do ——— do ——— 152 E. W. d/ 16th May 1886.

The estimates for providing lightning conductors to the under-mentioned Government buildings at Ootacamund are sanctioned and classified as Civil Buildings, Original Works.

Govt. House - Rs. 2,400 - Provincial No:
of 1886-8

St. Stephen's Church - 1,550 - Do - No: Wf-

Collector's office - 1,970 - Do - No: Wf-

Place of arms on Bombay Castle Hill } - 720 - Do - No: Wf-

Bombay Castle - 1350 - Do - No: Wf-

2. The cost of providing lightning conductors ~~to the~~ for Govt. House will, as proposed by the Supdg. Engr., be met from savings on sub-heads of the general estimate ~~[illegible]~~ referred

in G. O. No. 915 W dated 9th July 1883, The question of providing funds for the rest of the works will be considered in connection with the statements of demands for incomplete and minor works.

3. The Supdg. Engineer will expedite the submission of estimates for providing lightning conductors to the Council-Chamber and Powder Magazine at Ootacamund.

2/5/86

To
The Supdg. Engr. IV Circle with esti-
" Examiner of P. W. Accts with 6 esti-
mates for audit & return to S. E. IV
" Revenue Department
" Military Department
" Ecclesiastical Department
" Judicial Department
" Private Secy to H. E. the Govr.

---

P. W. D.

Memo

With advertence to G.O. No. 324 W dated 6.2.86, the Supdg. Engr. IV Circle is requested to expedite the submission of an estimate for providing lightning conductors for the Govt. Offices & Council Chamber Ootacamund.

11-5-86

S. E. IV Circle

Despd. 12-5-86.

G.O. 324 W d/ 16-2-86.

E. I. Form No. 22 PUBLIC WORKS DEPARTMENT.

# PROCEEDINGS OF THE MADRAS GOVERNMENT.

Under date the [illegible]

READ the following :—

A

From the Supdg. Engr. IV Circle, H. E. No: 149 C. W. d/ 14th May 1886.
——— Do ——— Do ——— No: 152 C. W. d/ 15th May 1886.
——— Do ——— Do ——— No: 156 C. W. d/ 16th May 1886.
——— Do ——— Do ——— 186 Ew. d/ 31 —

The estimates for providing lightning conductors for the under-mentioned Government buildings at Ootacamund are sanctioned, and classified as Civil Buildings, Original Works.

| | | | |
|---|---|---|---|
| (1) | Govt. House ——— | Rs 2,400 - Provincial No: | W of 1886-87 |
| (2) | St. Stephen's Church | 1,550 — Do — No: | W - Do - |
| ~~(3)~~ | ~~Collector's office~~ | 1,970 - Do - No: | W - Do - |
| (3) ~~(4)~~ | Place of arms on Bombay Castle Hill | 720 - Do - No: | W - Do - |
| (4) | Bombay Castle. ——— | 1,350 - Do - No: | W - Do - |
| (5) | Govt. Offices. ——— | 1,850 - Do - No: | W - Do - |
| 6 | Council Chamber. ——— | 730 - Do - No: | W - Do - |

2. The cost of providing lightning conductors for the Govt. House will, as proposed by the Supdg. Engineer, be met from savings on sub-heads No 3 of the general estimate referred to in

in G. O. No: 1915 W dated 9th July 1883.
The question of providing funds ~~for~~ to meet the other estimates ~~the cost of the works~~ will be considered in connection with the statements of demands for incomplete and minor works.

3. ~~A~~ lightning conductor ~~on~~ for such ~~a~~ comparatively low building as the Store house Hill & the Clerk's quarters & the Collector's Office ~~is~~ are considered unnecessary. ~~It is observed~~ ~~that the~~ building is ~~and it is~~ not included in the list published in G. O. No: 324. W. dated 6th February 1886. The estimate for the ~~same~~ work will therefore be returned to the Supdg. Engineer, ~~unsanctioned~~.

4. ~~The Supdg. Engineer will expedite~~ The submission of an estimate for ~~providing~~ attaching lightning conductors to the Powder Magazine at Ootacamund ~~will~~ should be expedited.

26/5/86

(4)

First draft

To The Supdg. Engr. IV Circle with [illegible]
" Examiner of P. W. Accts with the [illegible] estimates for note & return to S. E.
" Revenue Department
" Military Department
" Ecclesiastical Department
" Private Secy to H. E. the Governor

W 575 Co. 26.5.86

---

No. 1430 W.

B & R
Civil works

PUBLIC WORKS DEPARTMENT.

1525/21

PROCEEDINGS OF THE MADRAS GOVERNMENT.

UNDER date the 7th June 1886

READ the following

| | | |
|---|---|---|
| From the S. E. IV Circle | 3805 | (H. E. No 149 Ew. d/ May 14. 1886) |
| do | 3255 | ( " " 152 Ew. d/ " 16. " ) |
| do | 3839 | ( " " 156 Ew. d/ " 16 " ) |
| do | 4461 | ( " " 186 Ew. d/ " 31 " ) |

The estimates for providing lightning conductors for the under-mentioned Government buildings at Ootacamund are sanctioned, and classified as Civil Buildings, Original Works:—

| | | | |
|---|---|---|---|
| (1) Government House | Rs 2400 | Spl. No 37 W of 1886-87 |
| (2) St. Stephen's Church | " 1550 | " 38 W of " |
| (3) Place of arms on Bombay Castle Hill | " 720 | " 39 W of " |
| (4) Bombay Castle | " 1350 | " 40 W of " |
| (5) Government offices | " 1850 | " 41 W of " |
| (6) Council Chamber | " 730 | " 42 W of " |

2. The cost of providing lightning conductors for Government House will, as proposed by the Supdg Engineer, be met from savings on sub-heads No. 3 of the general estimate referred to in G.O. No. 1915 W d/ 9th July 1883. The question of providing funds to meet the cost of ~~other~~ the other estimates will be considered in connection with the statements of demands for incomplete and minor works.

1930/82

3. Lightning conductors for such comparatively low buildings as the clerks' quarters on Stonehouse Hill and the Collector's office are not considered necessary.

4. The submission of an estimate for attaching lightning conductors to the Powder Magazine at Ootacamund should be expedited.

To
The S.E. IV Circle
with the unsanctioned Ests (3) ✓
" Ex. PWA with the ✓
sanctd. Ests, for note & return to ✓
S.E. IV Circle. ✓
" Revenue dept ✓
" Milty dept ✓
" Ecclesiastical dept
" ~~Private~~ Military Secy to H.E. the Govr ✓

12/6/86

7/6/86

5.6.86

3839.
4161.
5-5-
37

Govt. of Madras.

PUBLIC WORKS.

Please send p.
5/6/86

Dated

Recd. Encl.

G.O., 7 June 1886, No. 1430 W.

Govt buildings Ootacamund

=

Orders sanctioning estimates for providing lightning conductors for ~~the~~ certain —

FC
No 2813 dd/26/10/86 100/8

P876