

No. 265-4. N.

FROM,

THE SUPERINTENDING ENGINEER

FIRST CIRCLE.

TO,

THE CHIEF ENGINEER

P. W. Department  
FOR IRRIGATION

DOWLAISHWARAM, 15<sup>th</sup> July 1886.

Depd 17-7-86.

SIR,

I have the honor to append  
extract from Inspection Notes of  
the Executive Engineer Rushikulya  
Division dated 11-6-86 received this  
day & to say that the action of the Exe-  
cutive Engineer appears to me to have  
been judicious.

I have the honor to be,

Sir,

your most obediently,

C. T. Walch

Sup<sup>r</sup> Engineer 1<sup>st</sup> Circle.

Gopalpur Pier.

Extract.

+ (sic)

"North pile of 16<sup>th</sup> Tier struck after  
"being screwed in 9½ feet leaving 2 feet  
"still to go down. Cricker would only  
"go down 7½ feet evidently hard soil not

"rock as point of pricker was not  
"upset- Had pile taken up- put  
"down a pipe and lowered a couple  
"of dynamite catridge into it and  
"had a blast, put down pricker after  
"blast  $9\frac{1}{2}$  ft in the same place- North  
"of pile where it would only go down  
" $7\frac{1}{2}$  ft blast evidently caused a  
"softening; but as there was no more  
"face to save further delay top 2 ft of  
"pile was cut off and then screwed  
"down to same depth as before"-

J.M.

No 2466C 13.7.86  
" 2212C 18.6.86  
" 2202C 17.6.86

No 2613C of 28-7-86

FROM,

THE SUPERINTENDING ENGINEER

FIRST CIRCLE.

TO,

THE CHIEF ENGINEER

P. E. d.  
FOR IRRIGATION.

DATED 15

DESPATCHED 17

RECEIVED 23

July 1886

No. 265 G.M.

ENCLOSURES.

No 2613C of 28-7-86

Gopalpur Pier—

Appends Extract from  
Notes of Inspection of  
Rushikulya & officers  
regarding the—

S. G. I. C. / Dead

28/7/86

H. L. 14/7/86

No 2613C of 28-7-86  
No 2613C of 28-7-86

2007

Subm

Subm