

No. of pages - 14
Date of repair - 27.2.58
Initial of the left - *less*

Tamil Nadu Archives

Govt. of Tamil Nadu

Public Works Department

G.O. No 2342 W
dt. 31.8.1987

15007

GOVERNMENT OF MADRAS.
PUBLIC WORKS DEPARTMENT.

Buildings and Roads.
Civil Works.

READ—the following letter from Colonel C. A. PORTEOUS, Acting Inspector-General of Police, to the Chief Secretary to Government, dated Madras, 1st August 1887, No. 3795:—

I have the honor to forward, for sanction, the Public Works Department plan, estimate, &c., amounting to Rs. 1,480, for the reconstruction of the police hospital at Chicacole, Ganjam district.

2. In the Executive Engineer's report accompanying the estimate, it is stated that the present building is past all repair.

Approved and transferred to the Public Works Department.

OOTACAMUND,
12th August 1887.
(By Order.) (Signed) A. G. CARDEW,
Under Secretary.

Note by the Chief Engineer, Public Works Department.

The plan and estimate, amounting to Rs. 1,480, for rebuilding the police hospital at Chicacole in the Ganjam district, is submitted for the sanction of Government with the following remarks:—

(1) The Superintending Engineer, I Circle, should report the site on which the hospital is to be built.

(2) The foundations should be carried to the depth marked on the plan and they might preferably be constructed of rough stone in mortar on a layer of concrete, instead of being built entirely of concrete.

(3) The whole of the wood-work should be painted.

(Signed) J. O. HASTED, Colonel, R.E.,
Chief Engineer, P.W.D.
27th August 1887.

ORDER—dated 31st August 1887, No. 2342 W., Public Works.

The plan and estimate, amounting to Rs. 1,480, for rebuilding the police hospital at Chicacole in the Ganjam district, is sanctioned for execution when funds are available.

2. Attention is drawn to the note by the Chief Engineer, Public Works Department, above recorded.

3. This sanction has been registered as Provincial No. 81 W. of 1887-88, and classified as Civil Buildings, Original Works.

(True Extract.)

Captain, R.E.,
Under Secy. to Govt., P.W.D.

To the Superintending Engineer, I Circle, with three enclosures.
" Examiner, Public Works Accounts, with the estimate for note
and return to Superintending Engineer, I Circle.
" Judicial Department.
Brd. W. H. French.
Spurs Copies

BUILDINGS AND ROADS.
CIVIL WORKS.

Gobt. of (1887) Madras.
PUBLIC WORKS.

Dated August, 1887.

Recd.

Recd.

G.O., 31st Aug. 1887, No. 2342 W.

AUGUST.

Police hospital at Chicacole

Estimate for rebuilding the — in the
Ganjam district, sanctioned.

Public Works Department.

Current No. 6365

Letter No.

Dated the 12th August 1887

From the Secy. to Govt. Judicial Dept.

17/8/87

NOTE OF REMARKS.

1. The accompanying plan and estimate provide for rebuilding the Police Hospital at Chicacole, Ganjam District. The amount of estimate is Rupees 1480.
2. This estimate is prepared at the request of the Superintendent of Police & the late Civil Surgeon of the place. It is not stated whether the building is to be built on the old or any new site & no site plan is submitted. The building is to be raised 3 ft. above the ground level.
3. The nature of soil is brown clay.
4. The depth of the foundation of the main building is 3 ft. is to be built of concrete which depth does not seem to be sufficient. Subject to your approval, it may be increased to 4 ft. deep in two steps as shown in pencil on the Section A.B. The depth of the basement of the main building is 2 ft. deep in the built-up wall.

to the height of 14 ft. from the basement level with chunam plastering inside & outside.

4. Flooring is to be of 9" large square tiles set in Portland Cement over a bed of 6" concrete in mortar.

5. Roofing is to be of 1/2 new flat and pan tiles, new rafter and chunam borders with roof ventilator.

6. All wood work is to be of Salwood wrought & put up & the beam things are correct.

7. All wood work (except the trusses which are to be painted with wood oiling) is to be painted with tar.

8. Report is submitted but not specification.

9. The rates are fair.

10. Petty supervision & contingencies are separately charged at 5 percent.

11. The plan and estimate have been countersigned by the Agt. Inspector General of Police and approved in the Judicial Department.

The plan & Est. may be submitted to the P.W. by E.W.

As to I will well remark whether the Hospital is to be built on the site of the old building ~~and if not, where~~

~~and if not, where~~ ~~the foundation~~

The foundation should be carried to the depth where on the plan, and then might, presumably, be constructed of rough stone or mortar, on a layer of concrete; instead of concrete.

The whole of the groundwork should be provided.

Wm
7.5.57

23421

Hutting & Building 1887-88.
General Department.

No. 3795.

CHIEF OFFICE OF THE INSPECTOR GENERAL OF POLICE,

Madras, 1 August 1887

FROM

Colonel G. P. Porteus
A. INSPECTOR GENERAL OF POLICE,

TO

THE Chief Secretary
to Government
Colacacund

SIR,

In Enclosures,

1. Plan
2. Detailed estimate
3. Abstract do.
4. Report
5. To

I have the honor to forward for sanction the G. P. W. plan, estimate & c. amounting to Rs. 1480 for the reconstruction of the Police Hospital at Chicaede, Ranjam District.

In the Executive Engineer's report accompanying the estimate it is stated that the present building is past all repair.

I have the honor to be
Your most ^{Sir} obedient servant
Wm. Porteus

10.32.77
Judicial (1887) DEPARTMENT.

From

Col. C. A. Porteous

Inspector General

of Police,

No. 3795

Dated

Received

1 August 1887

No.

SUBJECT.



Forwards for sanction the
S. P. W. plan, estimate &c.
amounting to Rs. 1480 for the
reconstruction of the Police
Hospital at Chicacole
Rayachoti District

13 7/1
Note by the Chief Engineer &c.

The plan and estimate amounting
to Rs. 1480, for rebuilding the police
hospital at Chicacole in the Rayachoti
District, is submitted for the sanction
of Govt. with the following remarks:-

(1) The Deputy Eng. I think should
have reported whether the
hospital is to be built on the site
of the old building

(2) The foundations should be
carried to the depth marked on the
plan and they might preferably
be constructed of rough stone in mortar
on a layer of concrete, instead of being
built entirely of concrete.

(3) The whole of the wood
work should be painted.

Done
27/8/87 E. W.

115-5-87

B. & R.
el works.

PUBLIC WORKS DEPARTMENT.

No. 2342W

23/8/07

PROCEEDINGS OF THE MADRAS GOVERNMENT.

Under date the

Read the following

From the Inspector General of Police, H. Co. No. 3795 of 1 August 1887
Recommencement by the Judicial Department, of 12 August 1887.
Note by the Chief Engineer P. W. Department of.

4

The plan and estimate
amounting to Rs. 1,430, for rebuilding
the police hospital at Chicaole in
the Ganjam District, is sanctioned
for execution when funds are available.

2. Attention is drawn to the
note by the Chief Engineer P. W.
Department above recorded.

3. This sanction accorded in
para. of these proceedings has been
registered as Provincial No. 81 W of 1887-88
and classified as Civil Buildings,
Original Works.

D. G. J.

To The Supty. Engr. I enclose with 3 enclos.
" Examiner of P. W. Accounts with the
estimate for notes and return to S. G. I.
" Judicial Department

25.8.87

27/8/87

2342
1

7-11-19
10-1-19

630
JUL 11 1887
PUBLIC WORKS

1/9/87

20 31/8 / 100 10 2302 W

Police hospital at Chicago

Estimate for rebuilding
the — in the Ganjam
District sanctioned

110
/ 5