

Inspection Notes.
Calicut Light House
12th February 1888.

In good order except
that new curtains round
the lantern room are
required, and the plankings
mentioned by the Chief Engineer
in his Notes with I.M. G.
160-161 Marine 14-4-87.
Plans and estimates for
the wooden ladder & lascar's
sheds therein ordered shall
go on soon.

C. P. T. P. S.
Superintending Engineer
1st Circle

To
The Chief Engineer
P. H. D.
23-3-1888.

Decd
Despatch 28/3/88

Inspection Notes.
Hope Island
Light House.
13th March 1888.

Column in good order generally but brick work exposed in a few small patches just under the gallery. - Gallery boards require caulking and to be so arranged that rain water which comes on to them flows off at the outer edge instead of as now, dripping down the column. The repairs recommended by the Chief Engineer in his Inspection Notes with I. M. G. No. 161 Marine 14/4/87 are in progress on a small estimate sanctioned by the Executive Engineer; but something more than therein provided for is required to make

page 9

the roofs of the Superintendents' Quarters and of the Lascar's shed fairly water-tight - especially along the ridges - the exposed wood work in external windows, verandah posts &c requires tarring.

C. Sewall

22/3/88 Superintending Engineer
1st Circle

To

The Chief Engineer
P. W. D.

Despatch 28/3/88



Marine Department.

PROCEEDINGS OF THE MADRAS GOVERNMENT.

Read the following paper :-

Endorsements of the Public Works Dept^y dated
6th April 1888, Nos 10 D & H. D on inspection
notes of Calingapatam Lighthouse 12th
February 1888. and Hope Island Lighthouse
13th March 1888.

Order 21st April 1888, No. 142.

Recorded.

2. The improvements suggested
should be carried out at an early date.

(True Extract)

W. Boulden

Under Secy to Govt
for Chief Secy.

To,

The Port Officer, Madras

Public Works Dept^y ✓

2
X² P. W.

100 No. D of 6. 4. 88.
110 No. D of 6. 4. 88.

By No. 1430 W of 16th May 1888

Communicated
to the Supty. Engineer
I Circle

See
12/5/88

[6] No. MC No. 3982
Govt. of 1888. Madras

To
The Public Works Dept

No. 1430 W of 16-5-88

1930 4-88

Proceedings, dated 21st April 1888
No. 142

Subject.

Recording letter from the
P.W Dept re. inspection
Notes of Calin gapalam
Lighthouse

LS
S & D Circle ✓ 16/15
1/15
12/5/88
12/5/88

In the order
12/5/88