

- (1) பக்கங்களின் எண்ணிக்கை 18
 (2) புதுக்கித் திருப்பிய நாள் 6-88
 (3) ஆதாரங்குறிப்பவர் சுருக்கொப்பம் 600 ✓

தமிழ்நாடு ஆவணக் காப்பகம்.

தமிழ்நாடு அரசு

பெரும்பணி துறை

அரசாணை எண்.	<u>1241 W</u>	அச்சகம்
மு. கோப்புத் தாள் எண்.		பலவகை
நாள் :	<u>27-4-1888</u>	<u>198</u>

மடிக்கவோ கண்டபடி கையாளவோ கூடாது

600

27TH APRIL 1888, No. 1241 W., PUBLIC WORKS.

GOVERNMENT OF MADRAS.
PUBLIC WORKS DEPARTMENT.

Buildings and Roads.
Civil Works.

READ—the following letter from G. T. WALCH, Esq., Superintending Engineer, I Circle, to the Inspector-General of Registration, dated Dowlaiswaram, 15th March 1888, No. 2781 G.D.:—

I have the honor herewith to forward a revised estimate, together with comparative statement, amounting to Rs. 3,380, for constructing Sub-Registrar's office at Ellore in the Godáviri district, and to request that sanction of Government may be obtained thereto. The original estimate (Rs. 2,540) for the work was sanctioned in G.O., No. 3456 W., dated the 3rd December 1883.

2. The revision of the estimate is chiefly due to the revision of the standard design which was sanctioned in G.O., No. 1049 W., of 5th May 1885. On account of the badness of the soil a continuous platform of concrete is proposed under the foundations as shown in the "sketch showing the arrangement of foundations" herewith.

3. As requested in your memorandum recorded in G.O., No. 163 W., dated the 16th January 1888, provision is made for glazed shutters, &c., in the revised estimate.

4. Weather boards sanctioned in G.O., No. 3456 W., dated the 3rd December 1883, over two windows on the sides of the office room are provided in the revised estimate.

G. No. 1597.

The plan and estimate were sanctioned in 1883 in the order cited by the Superintending Engineer. The estimate has been revised now to embrace the improvements since found necessary, and it is submitted for the sanction of the Government. The want of a suitable office at Ellore has been greatly felt.

MADRAS,
24th March 1888.

(Signed) G. HAMNETT,
Inspector-General of Registration.

Approved and transferred to the Public Works Department.
(By Order.)

6th April 1888.

(Signed) A. G. CARDEW,
Under Secretary.

ORDER—dated 27th April 1888, No. 1241 W., Public Works.

The revised estimate, amounting to Rs. 3,380, for constructing a Sub-Registrar's office at Ellore in the Godáviri district, is sanctioned in supersession of the estimate of Rs. 2,540 sanctioned in G.O., No. 3456 W., dated 3rd December 1883.

2. This sanction has been registered as Provincial No. 6 W. of 1888-89, and classified as Civil Buildings, Original Works.

(True Extract.)

Captain, R.E.,
Under Secy. to Govt., P.W.D.

To the Superintending Engineer, I Circle, with four enclosures.
" Examiner, Public Works Accounts, with the duplicate abstract estimate.
" Judicial Department.

Exd. L. Passaigne.
Spare Copies

BUILDINGS AND ROADS.
CIVIL WORKS.

Govt. of 1888 Madras.
PUBLIC WORKS.

Dated April, 27th.

Recd.

Encl.

G.O., 27th Apr. 1888, No. 1241 W.

APRIL.

Sub-Registrar's office at Ellore

Revised estimate for constructing a — in
the Godavari district, sanctioned.

16TH JANUARY 1888, No. 163 W., PUBLIC WORKS.

1241
2

GOVERNMENT OF MADRAS.
PUBLIC WORKS DEPARTMENT.

Buildings and Roads.
Civil Works.

READ—the following papers :—

From A. S. RUSSELL, Esq., Executive Engineer, Tinnevely Division, to the
Superintending Engineer, VI Circle, dated Palamcottah, 8th December 1887,
No. 2763.

In continuation of my letter No. 1994, dated 25th September 1887, I have the
honor to report that I receive continual complaints from the Registration Department
regarding the inconvenience the Registrars are exposed to in this district owing to
the absence of glass windows at the sides of the Registrar's room and clerks' room
(vide standard design for a Registrar's office).

2. For about half the year in this district there is a strong wind, and during the
north-east monsoon heavy rain. If the venetian windows at the sides of the room are
closed there is not sufficient light to see, and there is thus no alternative but to keep
the venetians open and be exposed to the inconvenience of wind and rain driving into
the room.

3. I have therefore had to call for estimates for the addition of glass windows to
several of the Registrar's office in this district, and would suggest that the standard
design be improved by the addition of glass windows to the sides of the building not
protected by verandahs.

No. 667 T.N.

True copy forwarded to the Inspector-General of Registration for his opinion and
for such suggestions as he may consider it desirable to make to Government about the
provision of additional glazed shutters to the side windows of the Registrar and Sub-
Registrar's rooms where there is no verandah.

2. The undersigned considers that the additional shutters are desirable.

14th December 1887.

(Signed) J. PENNYCUICK, Lieut.-Col., R.E.,
Superintending Engineer, VI Circle.

G. No. 5147.

Submitted to the Government, with the recommendation that glazed shutters be
sanctioned, as suggested by the Superintending Engineer, for all offices.

2. Experience has shown that such glazed shutters should also be provided for
all record-rooms in addition to the wooden shutters, that substantial doors should be
provided in lieu of half venetian and half pannelled doors for record-rooms, and that
the walls near windows should be sloped *outwards*, and *not inwards* as is done, as the
rain-water gets in through the crevices and finds its way into the record-rooms and
offices.

MADRAS,
23rd December 1887.

(Signed) G. HAMNETT,
Inspector-General of Registration.

16TH JANUARY 1888, No. 163 W., PUBLIC WORKS.

No. 19 R., Judicial.

Approved and transferred to the Public Works Department.

(By Order.)


FORT ST. GEORGE,
12th January 1888.

(Signed) A. G. CARDEW,
Under Secretary.

ORDER—dated 16th January 1888, No. 163 W., Public Works.

Communicated to Superintending Engineers, who will, in future, carry out the recommendations of the Inspector-General of Registration in framing estimates for Registration offices.

(True Extract.)



Captain, R.E.,
Under Secy. to Govt., P.W.D.

To Superintending Engineers.
To the Consulting Architect to Government.
" Judicial Department.

Ed. J. Moses.
Spare Copies

1241
3

BUILDINGS AND ROADS.
CIVIL WORKS.

Govt. of (1888) Madras.

PUBLIC WORKS.

Dated January, 16th.

Recd.

Encl.

G.O., 16th Jan. 1888, No. 163 W.

JANUARY.

Registration Offices

Communicating with instructions, to
Superintending Engineers correspondence
relative to certain improvements to be made
in future in —.

Public Works Department.

Current No. *3307*

Letter No. *124/4*

Dated *6th April 1888*

From the *Secy. to Govt. Engineering
Dept.*

NOTE OF REMARKS.

*The accompanying
Estimate amounting
to Rs 3380 provided
for constructing a
Sub Registrars Office
at Ellore in the
Madras Dist.*

*The original Est.
amounting to Rs 2540
was sanctioned in
G.O. No 3456 N of 3rd
December 1883.*

*The sum viz Rs 840
is stated to be mainly
due to the revision
of the Standard design
and to a continuous
platform of concrete
work.*

as the soil is bad, also
the provision made
in the Estimate, for
stone chert, and
for two low chert.

The rates are fair.
The Estimate has
been counterchecked
by Mr. Inspector
General of Registration
and approved by
H.H. in the Judicial
Office.

Encl 7

18/4/88.

Sanction

17.4.88

No. 2781 G. D.

FROM,

THE SUPERINTENDING ENGINEER

FIRST CIRCLE

TO,

THE Inspector General
of Registration

Dowlaiswaram, 15 March 1888
Recd 19/3/

SIR,

I have the honor herewith to
forward a revised Estimate together
with comparative statement amount-
ing to Rs 3380 for Constructing sub-
registrars Office at Ellore in the Goda-
vari District and to request that
sanction of Government may be
obtained thereto. The original Estimate
(Rs 2540) for the work was sanctioned
in G.O. No 3456 dated the 3rd Decem-
ber/83

The revision of the Estimate is
chiefly due to the revision of the stained
and design which was sanctioned in

G.O.

G.O. No 10494 of 5th May/85. On account
of the badness of the Soil a Continuous
platform of concrete is proposed under
the foundations as shown in the "sketch
showing the arrangement of founda-
tions" herewith.

3. As requested in your Memo
recorded in G.O. No 1634 dated the
16th January 1888 provision is made for
glazed shutters &c in the revised esti-
mate.

4. Leather boards sanctioned in
G.O. No 3546 dated the 3rd December
1883 over two windows on the sides
of the office room are provided in the
revised Estimate.

I have the honor to be
Sir

Your most obedient servant

C. Swales

Superintending Engineer

1st/10/88

G.O. No 1597-24 March 1888.

Madras.

124/2P

The plan and estimate were sanctioned
in 1883 in the order cited by the Superintending
Engineer. The estimate has been revised
now to embrace the improvements since
found necessary; and it is submitted
for the sanction of the Government. The
want of a suitable office at Ellorah has
been greatly felt.


W. Hammett
Inspector General of Registration

The Chief Secretary to the
Government
Fort St. George.

1241
7

90 12.2.83. 374
13.12.83. 3289 mm

P.W. 3307
CURRENT 1448



3P
of 6 April 1888
Admitted & transferred
to the Public Works Dept.
/ by order /
A. G. Cardew
Secy. to Govt.

3456 on 3.12.83.
163 on 16.1.88.
1049 on 5.5.85.

Judicial (1888) Department

"Registration"

From
The Inspector General
of Registrations
Madrass

To
The Chief Secretary
to the Government
Fort St. George

Dated 24th
Received } March 1888
 } 1888
 } No. 1597
 } Enclosure - 5
 } No. (4144)

Submitting for the sanction
of the Government for the
plan & estimate for the
construction of an office
at Ellore in the Godavari
district.

2.538 on 7.6.88 0
11.12.88 20/4

No. 124165

B. L. Works
PUBLIC WORKS DEPARTMENT.

124165 419

PROCEEDINGS OF THE MADRAS GOVERNMENT.

Under date the 27 April 1888

Read the following

From the Inspector General of Registrations. H. S. No. 1597 of 24 March 1888
Endorsement by the Judicial Department. d/6 April 1888.

The revised estimate
amounting to Rs. 3,380 for constructing
a sub-registrar's office at Ellore in
the Godavari District, is sanctioned
in supersession of the estimate of
Rs. 2,540 sanctioned in G.O. No. 3456W
dated 3 December 1883.

2. This sanction has been
registered as Provincial No. 6 W of
1888-89 and classified as Civil
Buildings, Original Works.

mem
20.4.88

To
The Supty. Engr. I kindly with 4 copies
" Reaminers of P. W. Acts with
the duplicate abstract estimate
" Judicial Department.

John
22/4/88

Cur

✓ 27/10/186
R 10/4

1241
9

Govt. of Madras
PUBLIC WORKS.

Dated

30/4

Recd.

Encl.

G.O. 27 Apr 1888 No. 1241 W.

Sub Registrar's office
at Ellore

=

Revised estimate for
constructing a — in the
Godavari District

80/0

27/4/88