

- (1) பக்கங்களின் எண்ணிக்கை 8
- (2) புதுக்கித் திருப்பிய நாள் 8-9-1
- (3) ஆதாரங்குறிப்பவர் சுருக்கொப்பம்

தமிழ்நாடு ஆவணக் காப்பகம்.

தமிழ்நாடு அரசு

புது துறை

அரசாணை எண். மு. கோப்புத் தாள் எண்.	2793	அச்சகம் பலவகை
நாள் :	6-10-1892	198..

மடிக்கவோ கண்டபடி கையாளவோ கூடாது

4 Sheets

ஆவண. கா-1-18,006-15-6-87.

Autograph

Judicial Department.



1/2793

PROCEEDINGS OF THE MADRAS GOVERNMENT.

Read the following paper:—

From the Inspector General of Jails, d 21st July
1892 No 9/382.

I have the honor to submit for the approval and sanction of Government, plans and estimates amounting to Rupees 2070 for the repair and renewal of the roofs of the buildings in the District Jail, Madras.

2. The last repairs to the roofs of these buildings were carried out by the Public Works Department in the year 1890-91, but so early as the occasion of Col Smith's inspection in February 1891, the Supt reported that the roofs still leaked in spite of repairs.

3. The Public Works Department now proposes to retille all the blocks with Mangalore tiles, and the Supg Engineer indicates a source from which the major part of the cost can be at once met.

From the same office, d 6th September 1892 No 3952 forwarding the communication from the Supg Engr who is referred to in his previous letter.

Order 17th September 1892 No. 1745

The estimates submitted

with the first of the letters read above are approved and will be transferred to the Public Works Department.

(Dunbarton)

McLennan

Under Secy. P. W. D.

for Chief Secy.

The Public Works Dept. with plain festoon

Inspector General of Dairies

X.B.D.

Public Works Department.

Current No. 9584.

Letter No. 1745

Dated 17th September 1892

From the Judicial Dept.

TECHNICAL NOTE.

Re-roofing the blocks H. in the District Jail at Madras.
Amount of estimate Rs 8070

In the report accompanying the estimate it is stated that the roof leaks badly & that ordinary repairs will be of very little use. It is therefore proposed to re-roof the blocks with mission tiles laid on oak rafters placed 6 inches apart. The alternating rafters are to be of a section 2" x 1" to hold the tiles & the intermediate rafters merely to prevent the escape of rain.

Provision is also made in the estimate for repairs to the roofs with old plank & pan tiles galvanized iron bands along eaves. (probably meant for eave gutters) & for repairs to decayed roof timbers where

It would in my opinion have been a much better arrangement to have provided a ceiling - for not only would the cells be kept much cooler, but a much more efficient safeguard against the escape of prisoners would have been provided. The all first immediate repairs will be to contain & to a safe guard, especially as the rafters are spaced for ordinary tilting. A ceiling would be much better, & answer a double purpose - Extra work about Rs 2000 - Mr. Gordon has however passed his bill to the Surveyor & sanctioned

over

necessary.

No rule of reduction is made in the estimate for the use of prison labor as required by para 937 of the Madras P. W. Code, as the work is to be given out on contract.

The estimate has been countersigned by the Inspector General of Jails & approved in the Judicial Dept.

Ho

23.12.92

The rates cannot be checked into date in support of the time of working with mission the are submitted.

Ho

3
2795

27/9

20

P. W. CURRENT No. 9584

Govt. of 18 Madras.

To

The Public Works Depto

Encls. 6 (11/11/92)
Recd. 22-9-92

Proceedings, dated 17 September 1892
No. 1745

Subject:

Approving the plans and
estimates for repairs to
the roofs of the buildings
in the Madura District Jail.

25.10.92
29-11-92

PUBLIC WORKS DEPARTMENT.

P2793 Wd/b. October 1892

PROCEEDINGS OF THE MADRAS GOVERNMENT

4/2793

Read the following

Prod. in the Judicial Dept. No. 1745 of 17 Sept. 1892

The estimate, amounting
to Rs. 8070. for re-roofing,
with Calicut tiles, the
buildings in the District
Jail at Madura, is
returned to the Suptg.
Engineer VI Circle for
sanction and execution
from the repair grant to
the Madura District under
Provincial Civil Buildings.
Any additional allotment
that may be required under
this head will be made
later in the year on
application by the
Suptg. Engineer.

* No. 5520

Recd
30/10/92

The S.E. VI Circle
with 5 enclos.
Judicial Dept.

Recd
24/10/92
Ct

29.9

No 2793 W a/b October 1899

✓
T X

2
13/10