

(1) பக்கங்களின் எண்ணிக்கை

(2) புதுக்கித் திருப்பிய நாள்

(3) ஆதாரங் குறிப்பவர் சுருக்கொவம்

3015
1992

தமிழ்நாடு ஆவணக் காப்பகம்.

தமிழ்நாடு அரசு

Pengi Seng

அரசாணை எண்.
மு. கோப்புத் தாள் எண்.

அச்சகம்
பலவகை

3015

நாள் :

2-11-1892

199

மடிக்கவோ கண்டபடி கையாளவோ கூடாது.

ச.சு.

ஆவண. கா. 1-18,006-6-9-90.

GOVERNMENT OF MADRAS.
PUBLIC WORKS DEPARTMENT.

Buildings and Roads,
Civil Works.

READ—the following papers :—

Proceedings of the Board of Revenue (Land Revenue), dated 26th August 1892, Mis. No. 5334.

Read—the following letter from M. HAMMICK, Esq., Collector of South Arcot, to the Secretary to the Commissioners of Land Revenue, dated 24th June 1891, Ref. on No. 3466-Eng. :—

Referring to para. 2 of G.O., No. 165, Revenue, dated 25th February 1890, communicated with the Board's Proceedings, Mis. No. 1904, dated 20th March 1890, I have the honour to forward, duly countersigned, for the approval of Government in the Revenue Department, an estimate, &c., amounting to Rs. 23,650, for constructing a first-class taluk cutcherry at Chidambaram.

Reference thereon, dated 16th July 1891.

The estimate is for a taluk of the old design. The new design will shortly be issued and the Collector will, therefore, be requested to have a fresh estimate prepared on the new lines.

Read—also the following letter from the same officer, dated 3rd August 1892, Ref. on Regr. No. 4241-Eng. :—

With reference to the Board's Reference on General Register No. 2120 of 1891, dated 16th July 1891, I have the honour to forward herewith copy of Superintending Engineer's letter, dated 23rd July 1892, No. 223 M., together with its enclosures, and request that sanction of the Government may be obtained to the estimate for the construction of a first-class taluk cutcherry at Chidambaram.

Resolution—dated 26th August 1892, Mis. No. 5334.

With reference to para. 2 of G.O., dated 25th February 1890, No. 165, Revenue Department, an estimate for the construction of a new taluk cutcherry at Chidambaram at a cost of Rs. 40,080 and the accompanying papers received with the Collector's second letter read above will be submitted for the sanction of Government.

(True Copies and Extract.)

(Signed) W. S. MEYER,
Acting Secretary.

Endorsement No. 4219, Revenue.

The plans and estimates are approved and will be transferred to the Public Works Department.

2. The Collector should be called upon to report regarding the disposal of the old cutcherry and sub-jail.

OOTACAMUND,
27th September 1892.

(Signed) R. H. CAMPBELL,
Acting Under-Secretary.

Note by the Chief Engineer, Public Works Department.

Teakwood is proposed to be used for the ceiling. It is considered that an as efficient ceiling might be obtained by the use of a cheaper description of wood, such as *Albizia Lebbek*, or *Cedrela Toona*. The Superintending Engineer will report on this point.

2. Provision is made in the estimate for new arm-racks and for prisoners and witness boxes. It should be reported if those now in use will not answer the purpose.

3. Provision is also made for tables and benches. Under para. 4, chapter XI, volume I of the Code, this is inadmissible unless specially ordered by the Government.

4. A sum of Rs. 540 is entered in the estimate as the cost of demolition of the old buildings. A report regarding the disposal of these buildings has been called for in the Revenue Department. They should not therefore be demolished pending further orders.

OOTACAMUND,
26th October 1892.

(Signed) G. T. WALGH,
Ag. Chief Engineer, P.W.D.

ORDER—dated 2nd November 1892, No. 3015 W., Public Works.

The estimate, amounting to Rs. 40,080, for constructing a first-class taluk office at Chidambaram, in the South Arcot district, is sanctioned.

2. A sum of Rs. 6,000 has been provided for the work in the current year's budget.

3. This sanction has been registered as Provincial No. 74 W. of 1892-93 and classified as Civil Buildings, Original Works.

4. Attention is directed to the note by the Chief Engineer.

(True Extract)

Major, R.E.,
Under-Secy. to Govt., P.W.D.

To the Superintending Engineer, V Circle, with plans and estimates.
" Examiner, Public Works Accounts.
" Revenue Department.
" Editors' Table.

Exdr J. Moses.
Spare Copies

3015
2

BUILDINGS AND ROADS.
CIVIL WORKS.

Govt. of {1892} Madras.
PUBLIC WORKS.

Dated November, 2nd.

Recd.

Encl.

G.O., 2nd Nov. 1892, No. 3015 W.

NOVEMBER.

Taluk Office at Chidambaram

Estimate of Rs. 40,080 for constructing
a first-class — in the South Arcot district,
sanctioned with remarks.

3015
/3

The estimate includes record
racks and cost of site. Surely some
cheaper wood than teak might be used
for ceiling planks.

(Intd) Res

25 Sept

96

Current No. 9983

Letter No. A-214

Dated 27 September 1892

From the Revenue Dept.

TECHNICAL NOTE.

Continuation of Telang Office at
Chidambaram, South Arcot District.
Amount of Estimate Rs 40080

This estimate was called for in
Cp. No. 941 w dated 22nd March 1890,
it provides for continuation of First
Class Telang Office with out-houses
at Chidambaram, in South Arcot
District.

The main building is to be con-
structed as per type design given:
dated with Cp. No. 3023 w dated
11th November 1891 for tiled roofing &
the out houses as per plans ap-
proved in Cp. No. 1409 w dated
28th May 1892.

The amount of the estimate is
made up as follows:-

Main building	Rs 32007
Second class	1580
Cook's room	550
Latrine	658
Gate with boundary wall	102
Forming road, levelling & clearing site	480
Shade & ditch	325

Estimated existing building Rs 840
 Compensation for land — 1320
 Petty expenses 5% — 1765
 Contingencies 3% — 1053

With estimate Rs 4000

The soil is situated to the south
 south to a depth of 6 feet below
 ground surface & sandy loam
 below that depth to an average
 depth of 18 inches. The founda-
 tions are proposed to be sunk
 to a depth of 9'6", the lower 2 feet
 to be built of concrete & the upper
 7½ feet of table moulded bricks in
 chunam. The superstructure
 walls are to be raised on a
 basement of 2 feet and built
 of table moulded bricks in chunam
 with flat & semicircular arches.
 Work over doors & windows, the
 walls are to be plastered inside
 with 2 coats of chunam & painted
 red outside with chunam. The
 floor is to be of 8" square bricks
 laid on 6" of concrete throughout
 except the second room & jail
 wards which are to be asphalted
 ½" thick over 6" of concrete. The
 roof is to be of Calicut tiles laid
 on teak rafters, rafters 4" and
 ceiling with ½" teak planks, the
 rafters being placed about 30" apart.
 The doors & windows are to be of

Rates per sq ft
 Mission taking office Irichinapet Dist.
 tiled roof — 2.12.5
 Randigama - Krishna Dist.
 tiled roof with flat & } — 2.9.2
 pan tiles —
 Chendragiri, North Arcot Dist.
 tiled roof with Mangalore } 2.7.2
 tiles without any ceiling }

the description noted in the estimate
 of teakwood & painted with
 coats of calcium oxide paint.

The calculations of the
 building are correct.

The rates as far as can be
 checked are fair, those for
 doors & windows cannot be
 checked from the existing rate
 list as there are no entries
 in the list.

The plinth area of the main
 building is 1084 sq ft. The
 cost per sq ft will be Rs 3.3.6
 which may appear rather
 high when compared with other
 taking offices but it is due chief-
 ly to the great depth of foundation
 & to the thick ceiling under the
 tiles.

The estimate provided for the
 following items:

1. Area walls in Police room — Rs 20.
 2. Prisoners & witnesses boxes — 60.
 3. Tables & benches — 60

The first two items are
 admissible being fixtures but
 the necessity for new articles
 should be explained as the
 existing ones may be removed
 to the new building. Tables &
 benches may be disallowed as
 these articles of furniture are
 not supplied by this dept. unless
 specially ordered by Govt. vide
 para

978 note 1 of the Madison P. H. Co. Co.
The existing building is to be dem.
which at a cost of \$540 but no
mention is made in the report
as to the use of old materials &
from the building, it is thought
that if the building be sold by
public auction & dismantled
at the cost of the purchaser, this
item will be covered.

The H. Co. remarks about the
use of tank planks (2") for ceiling
& suggests the use of cheaper
wood. This may be done by the
use of white cedar or oak plank
but they are not suitable
for the purpose as they generally
warp. They must at least
be 3/4" planks & many, even be
procured at Chidambaram
which at a large cost for trans-
port. It will almost bring
the rate up to the 20 per sq. ft.
for tank ceiling.

The plan & estimate have
not been counter-signed by the
Collector. Therefore they have
passed through him. They are
however appended in the Rev.
Dept. with the remarks that the
Collector should be called on to
report regarding the disposal
of the old buildings.

18-X-92

Adela Toma & I think
a good wood for
ceilings - It does
not warp, but by
weights & other pers
cft.

note by Secy

That wood is proposed
for use for the ceiling.

It is understood that
an efficient ceiling
might be obtained by the
use of a cheaper description

of wood, such as
Albizia, Labbaik,
Albizia Labbaik, or
Adela Toma. It
is with respect to this
point -

Provision is made in
the estimate for
some racks & for Provision
distances boxes - It

should be reported if
now in use will
not answer the purpose.

Provision is also made
for tables & benches.

Under para 4 the 1st of
the code this is inadvisable
unless specially ordered
by the Government.

amount of Rs 540
incurred in the site
as the cost of demolition
of the old buildings -

A report regarding
the disposal of these
buildings has been
submitted for the Rev.
Dept. They should not
therefore be demolished
pending further orders.

Yours
25-10-92



Proceedings of the Board of Revenue

(Land Revenue)

Dated 26 August 1892.

No. 5334 also

Mr. J. J. Arnold

READ the following letter from M. Hammick Esq. dated 24th June 1891. Refers to No. 3466 to the Secretary to the Commissioners of Land Revenue, Madras. ^{Colr. of South Arcot}

Referring to para 2 of G.O. No 165 Revenue dated 25 February 1890 communicated with the B. P. No 1904 Miscellaneous dated 20-3-90 I have the honor to forward duly countersigned for the approval of Government in the Revenue Department an estimate for amounting to Rs 23650 for constructing a first class Taluk cutting at Chedambaram.

(2) and the following reference thereon dated 16-7-1891

The estimate is for a taluk of the old design. The new design will shortly be issued and the Collector will, therefore, be requested to have a fresh estimate prepared on the new lines.

(3) also the following letter from the same officer dated 3 August 1892. Refers to Reg. No 4241 ^{Eng}

With reference to the Board's Reference on G.O. Reg. No 2120 of 1891 dated 16 July 1891 I have the honor to forward herewith copy of Superintendent Engineer's letter dated 28 July 1892

No. 223 in together with the
request that sanction of the Government may
be obtained to the estimate for the construc-
tion of a first class Taluk Cutcherry at
Chidambaram.

Resolution dated 21 Aug 1890, No. 5534 R
With reference to para 2 of Government
order dated 25 February 1890, No. 165 Recd. Sept.,
an estimate for the construction of a new Taluk
Cutcherry at Chidambaram at a cost of Rs 40080,
and the accompanying papers received with the
Collector's second letter read above will be
submitted for the sanction of Government.

In copies and Extract,

to
Sd/-
Secy. Secretary.

To
The Secretary to Government Recd. Sept.
with 9 enclos., plans & estimate & the
etc. and with copy of Supp. Inquiry.
Copy to the Collector of South Arcot.
9903/92

30/5/92

(1892.)

REVENUE DEPARTMENT.

P. W. CURRENT No. 9903

Current Number 7622

From Board of Revenue
Land Revenue

Encls: 11 (4 plans)

Rego: 3.10.92

Dated 26 August 1892

Received 1 September

Enclosures 7

No. 5334 Mis

SUBJECT.

Submg. for the sanction
of Govt. plans & estimates
for the construction of a
first class Taluk Cutchery
at Chidambaram
S. Arcot Dt.

St. B. W. 74/10 3/22 3-50

ABSTRACT.

Endorsement No. 4219

The plans and estimates
are approved and will
be transmitted to the
Public Works Department.
2 The Collector should
be called upon to report
regarding the disposal
of the old Cutchery
and subp. .

Amalgamated

Cotaca munda
27 Sept 92 3/4 under Secretary
J.

The Comd. of L.R.
.. P.W.D with enclos
and copy of remarks
of the Hon. Secy. & S. K. S. S. K. S. S.

Decd. 29-9

Encls: 11 (4 plans)

20/10 22.11.92

In old 45-9
m 3/10

20/10 22.11.92
P.W.D

Pros. of the B^d of Revenue (Land Rev.) No. 5334 Mis. 26 Aug 92
Endt in the Rev. Dept. No. 4219 of 27 September 1892

Note by Chief Engineer
P.W.D

3 P.W.
Teak wood is proposed
to be used for the ceiling.
It is considered that
an as efficient ceiling
might be obtained by the
use of a cheaper descrip-
-tion of wood, such as
Albizia Lebbek, or
Adreia Toona. The
Suptg. Engineer will
report on this point.

2 Provision is made in the
estimate for new arm
racks and for prisoners
and witness boxes. It
should be reported if
those now in use will
not

Editorial

2

25/10/92

40-5116

Ch
L

SDM
25 June

C No 9903
Govt. of Madras.
PUBLIC WORKS.

Dated

By

3
2nd November 1892 No 3015 W

Salak office at
Chidambaram

Estimate of Rs 14,00 80 for
constructing a first class
— in the South Arcot
District, sanctioned with
remarks.

90
6

20. 3/10