Public Works (1896) Department.

6346

G.O., No. 2477 W.

DATED 27 August 1896.

[Despatch Abstract:]

Police Hospital and Magazine: Estimate of Rs. 12,300 for constructing a — and improving the Stationhouse at Chintapilli in Vizagapatam Dt, sanctioned with remarks.

INDEXED. 29/8

[P. W. 26.
600—13-8-96.]

BACK PAPERS.

G.O.	No.	Department.	Date.	G.O.	No.	Department.	Date.

FURTHER PAPERS.

G.O.	No.	Department.	Date.	G.O.	No.	Department.	Date.

BUILDINGS AND ROADS.
CIVIL WORKS.

Government {1896} of Madras.
PUBLIC WORKS.

Recd. } 1896. *Enclosures*

Regd. *Spare copies*

G.O., No. 2477 W., dated 27th August 1896.

AUGUST.

Police Hospital and Magazine

Estimate of Rs. 12,300 for constructing a — and improving the station-house at Chintapilli in Vizagapatam district, sanctioned with remarks.

No. 2477 W., 27th August 1896.

GOVERNMENT OF MADRAS.

PUBLIC WORKS DEPARTMENT.

Buildings and Roads.
Civil Works.

Read—the following papers:—

G.O., No. 1120, Judicial, dated 6th July 1896.

Read again—G.Os., Nos. 1153 and 688, dated 29th May 1895 and 7th April 1896, respectively.

Read—also the following letter from the Inspector-General of Police, No. 2377, dated 16th June 1896:—

I have the honour to submit, duly countersigned, for the sanction of Government, plans and estimates amounting to Rs. 12,300 for the construction of a Police hospital and magazine and improvements to the station-house at Chintapilli in the Vizagapatam district.

2. The estimates have been revised in accordance with the instructions contained in G.O., No. 688, Judicial, dated 7th April 1896. The amount of the estimate has been reduced from Rs. 17,300 to Rs. 12,300.

3. The Superintending Engineer says: "At Chintapilli, labour is scarce, working hours limited, and materials dear and have to be conveyed to workspot by coolies. Under these circumstances, I do not think that the accompanying estimate is capable of any further reduction."

Order—No. 1120, Judicial, dated 6th July 1896.

The revised plans and estimates are approved and will be transferred to the Public Works Department.

(True Extract.)

(Signed) W. FRANCIS,
for Chief Secretary.

Note by the Chief Engineer, Public Works Department.

The estimate is recommended for sanction on the presumption that the Superintending Engineer will satisfy himself as to the suitability and reasonableness of cost of the iron roofing to be supplied by Calcutta contractors. No details for this roof have been received. But from the plan and estimate it would seem that it will be supported by four iron trusses at the points marked in pencil: but it is not clear how these trusses will be fixed, particularly at the ends where there are no intermediate pillars as supports; neither are there bressummers provided in the estimate. It is considered that details for iron work are as important as details for any other kind of work, and that contractors' estimates should not be blindly accepted.

2. The undersigned does not think mud plaster suitable for gable ends, or any parts of a building exposed to the weather. Such parts should be lime-plastered.

3. Provision has been made for eight iron bed-steads, each 6′ × 2′ 6″ at a total cost of Rs. 96. Apparently under paragraph 2, chapter X, Volume I of the Public Works Code, this item may be expunged, and, as the saving thereby effected will probably be required to cover the cost of substituting lime for mud plaster, it is not worth while to make any reduction in the estimate.

4. In regard to the additions to the existing police station, the loop holes, marked at points c. c. c. c., should be omitted under G.O., No. 2181 W., dated 24th August 1893.

(Signed) D. McNEIL CAMPBELL, Col., R.E.,
Chief Engineer.

21st August 1896.

Order—No. 2477 W., dated 27th August 1896.

The estimate, amounting to Rs. 12,300, for constructing a Police hospital and magazine and improving the station-house at Chintapilli in the Vizagapatam district, is sanctioned.

2. There is a provision of Rs. 4,000 in the current year's budget, and this will, if necessary, be augmented on application by the Superintending Engineer.

3. Attention is invited to the note by the Chief Engineer recorded above.

4. This sanction has been registered as Provincial No. 60 W. of 1896-97, and classified as Civil Buildings—Original Works.

(True Extract.)

Under Secretary to Government.

To the Superintending Engineer, I Circle, with thirteen enclosures.
„ Examiner, Public Works Accounts.
„ Judicial Department.

Exd. T. K. Narayana Aiyangar,

~~#6~~

Estimate for constructing a Police hospital and magazine & improving the station house at Chintapilli, Vizag. Dt.
No. 2477W, dated 27th August 1896

Public Works Department.

PROCEEDINGS OF THE MADRAS GOVERNMENT.

2P

Read the following

G.O. No. 1120 Judicial, dated 6th July 1896.

Note by the Chief Engineer,
P.W. Department:-

The estimate is recommended for sanction on the presumption that -- the Superintending Engineer will -- satisfy himself as to the suitability and reasonableness of cost of the iron roofing to be supplied by Calcutta contractors. No details for this roof have been received. But from the plan and estimate it would seem that it will be supported by four iron trusses at the --- points marked in pencil; but it is not clear how these trusses will be fixed, particularly at the ends where there are no intermediate -- pillars as supports; neither are --- there bressummers provided in the estimate. It is considered that --- details for iron work are as important as details for any other kind of work, and that contractor's estimates should not be blindly accepted.

(40—4,000—14-3-95.)

2. The

2. The undersigned does not think mud plaster suitable for gable ends, or any parts of a building exposed to the weather. Such parts should be lime-plastered.

3. Provision has been made for -- eight iron bed-steads, each 6' X 2' 6" at a total cost of Rs. 96. Apparently under para 2, Chapter X, Vol. I of the P.W. Code, this item may be expunged, and, as the saving thereby effected will probably be required to cover the cost of substituting lime for mud plaster it is not worthwhile to make any reduction in the estimate.

4. In regard to the additions to the existing police station, the loop holes, marked at points c.c.c.c., should be omitted under G.O. No. 2181 W dated 24th August 1893.

21/8/96
E.W.

Order:-

The estimate, amounting to Rs. 12,300, for constructing a Police Hospital and Magazine and improving the Station House at Chintapilli in the Vizagapatam District is sanctioned.

A.54
22.8.96

2. There is a provision of Rs. 4,000 in the current year's budget, and this will, if necessary, be augmented on application by the Suptg. Engineer.

3. Attention is invited to the note by the Chief Engineer recorded above.

4. This sanction has been registered as Provincial No. 60W of 1896-97, and classified as Civil Buildings, Original Works.

21/8/96

21-8-96

Resd 9/9/96

The Suptg. Engineer I Circle,
with 13 enclosures.
,, Examiner, P.W. Accounts.
,, Judicial Department.

E. 9/9/96

T
B C

CN 6346 / 95/322

W

The bed-steads do not form fixtures and their supply does not devolve on the P. W. D. vide paras 2 and 4, Chapter X, Vol II of the P. W. Code. It is therefore proposed to eliminate from the estimate, the provision made for these bed-steads and to utilise the saving thus effected in the substitution of lime plaster for ~~white~~ mud plaster provided in the estimate.

Maj
19/8/96

alter
15/8/96

PUBLIC WORKS DEPARTMENT.

F THE MADRAS GOVERNMENT.

READ the following

No. 1120 dated 6 July 1896)

Note by the Chief Engineer P. W. D:—

The estimate is recommended for sanction on the presumption that the Supt. Engineer will satisfy himself as to the suitability and reasonableness of cost of the iron roofing to be supplied by Calcutta contractors. No details for this roof have been received. But from the plan and estimate it would seem that it will be supported by four iron trusses at the points marked in pencil: but it is not clear how these trusses will be fixed, particularly at the ends where there are no intermediate pillars as supports: neither are there bressummers provided in the estimate. It is considered that details for iron work are as important as, if not more as than, details for any other kind of work, and that contractors' estimates should not be blindly accepted because the contractors may happen to be a well-known Calcutta firm.

2. The undersigned does not think mud plaster suitable for gable ends, or any parts of a building exposed to the weather. Such parts should be lime plastered.

3. Provision has been made for eight iron bed-steads, each 6'×2'6" at a total cost of Rs. 96. Apparently under

I cannot follow this. If [illegible] be the lime plaster [illegible] to the [illegible] [illegible]

As the saving thus effected be required to will probably cover the cost of substituting lime for mud plaster it is not advisable to make any reduction in the estimate

para 2, Chap: X, Volume I of the P.W. Code, this item may be expunged, but as lime plaster should be substituted for mud plaster as aforesaid, it is scarcely worth while to make a reduction in the estimate.

4. In regard to the additions to the existing police station the loop holes marked at points c.c.c.c. should be omitted under G.O. No. 2181 W dated 24 August 1893.

EW

Order:— CO 7825 14.8.96.

The estimate, — amounting to Rs. 12,300, for constructing a Police

Hospital and Magazine and improving the Station House at Chintapilli in the Vizagapatam District is sanctioned.

2. There is a provision of Rs 4,000 in the current year's budget, and this will, if necessary, be augmented on application by the Supdg Engineer.

3. Attention is invited to the note by the Chief Engineer recorded above.

4. This sanction has been registered as Provincial No. of 1896–97, and classified as Civil Buildings, Original Works.

Cross
14.8.96

H.E./

Estimate for constructing a police hospital and magazine and improving the station house at Chintapalli, Vizagn Dt

S. E. I Circle with Encls.
Ex P. W. A.
Judicial Depr

The estimate may be sanctioned with a note as follows:-

The estimate, amounting to Rs 12300, for constructing a Police Hospital & Magazine & improving the Station House at Chintapilli, ~~is sanctioned~~ recommended for sanction on the presumption that the Supdg Engineer will satisfy himself as to the suitability and reasonableness of cost of the iron roofing to be supplied by ~~the~~ Calcutta Contractors. No details for this roof have been received. But from the plan and estimate it would seem that it will be supported by four iron trusses at the points marked in pencil: but it is not clear how these trusses

60-200-18-12-95.

No 2477 W. dated 27th August 1896

Public Works Department.

Current No. 6306
Letter No. 1120
Dated 6th July 1896
From the ~~[illegible]~~ Judicial Department

NOTE BY TECHNICAL SECTION.

Name of work Constructing a Police Hospital & Magazine and improving the Station house at Chintapalli.

Amount of Estimate Rs 12,300

The plans & estimate under review, amounting to Rs 12,300, have been framed with reference to G.O. No. 1349 W dated 7th June 1895 and provide for the construction of a Police Hospital & Magazine and for improving the Station house at Chintapalli in the Vizagapatam District.

The amount of estimate is made up as follows:-

Rebuilding Station house	Rs	4,700
Constructing Hospital	"	6,000
Constructing Magazine	"	1,600
Total	Rs	12,300

The proposed hospital will measure 58' x 34½ feet outer dimensions and will consist of a ward to accommodate 8 beds, measuring 28'x16', an apothecary's room 10'x10', an office room 12'x10' and a store room 12'x6' with verandahs 7'9" wide.

The

The surface soil is reported to be black cotton to a depth of one foot & the subsoil red gravel below.

The foundations of the main walls will be laid with concrete to a depth of 3 feet & the verandah retaining walls 2'6" to ground ~~[illegible]~~ level; the basement will be raised 2 feet & built of rough stone in mortar, the superstructure walls will be 10¼ high & built of rough stone in mud except around doors & windows for a depth of one foot which will be rubble in mortar. The walls will be plastered with mud both interior & exterior & whitewashed with lime 2 coats & the floor laid with 6" of gravel well watered & rammed.

The roof will be of corrugated iron laid on trusses. This roof is proposed to be obtained from Messrs Burn & Co of Calcutta, details of which have not been submitted. This description of roof, it is reported, was ordered in G.O. No 2389 dated 28th Decr 1892 Judicial.

The Magazine will be 16'x10' & is designed as per plan approved & circulated with G.O. No 2564 W dated 13th Sept 1883.

The walls of the Magazine will be built of rough stone in mortar on a bed of concrete 3 feet deep & plastered both interior & exterior with 2 coats of lime mortar. The roof will be arched with concrete & the surface plastered with ½" Portland cement. Provision has ~~been~~ made for lightning conductors at a lump sum cost of Rs 150.

Improvements

will be fixed, particularly at the ends where there are no intermediate pillars as supports; neither are there bressummers provided in the estimate. It is considered that details for iron-work are as important as, if not more so ~~[illegible]~~ than ~~are~~ details for any other kind of work, that contractors' estimates should not be blindly accepted because the contractors ~~they~~ may happen to be a well-known Calcutta firm.

The undersigned does not think mud plaster suitable for gable ends, or any parts of a building exposed to the weather. Such parts should be lime plastered.

Provision has been made for eight iron bed-steads, each 6'x2'-6" ~~at a~~ total cost of Rs 96. Apparently "under para 2

Chap X volume I of the P.W. Code this item may be expunged, but as lime plaster should be substituted for mud plaster as aforesaid, it is scarcely worth while to make a reduction in the estimate.

In regard to the additions to the existing Police Station the op bits marked at points c.c.c.c should be omitted under G.O. No 2181 W dated 24th August 1893.

CWH
13.8.96.

Improvements to the Police Station house.— The estimate provides for two additional rooms each 18'x12' these will be built one on each side of the existing Station house with side & rear verandah 6'8" wide, vide plan.

The materials of construction are just the same as that of the Police hospital except that the roof in this case will be tiled.

Remarks

"New Police Hospital". The details of the iron roof, which it is proposed to obtain from Calcutta, has not been submitted. From the plan & estimate it would appear that there are 4 iron trusses at the points marked in pencil; it is not clear how these trusses are to be fixed ~~to~~ span the ends over the pillars ~~[illegible]~~, particularly in the absence of masonry pillars marked a, a, a in pencil, moreover no bressummers are provided for in the estimate, further, the ends being open gables it is very probable that the rubble in clay wall plastered with mud will be kept damp during the rains, some sort of weather boards, it is submitted, may be provided at these open gable faces.

Provision has been made for 8 iron bed steads, each 6'x2'6" at a cost of Rs 96 in all. These do.

does not appear to be chargeable under Fixtures & under para 2 Chap X, Volume I of the P. W. Code, the item may be expunged.

"Extension to Station house" —
The gable faces above the verandah roof is proposed to be plastered with mud & whitewashed. This it is submitted may be pointed or plastered with chunam, as the surface is exposed to the weather.

The loop-holes marked on plan at points C.C.C, may be omitted, as ordered in G.O. No. 2181 W dated 24th Augt 93.

The scantlings for roof timbers are correct

The rates entered are very high when compared with the Divisional Schedule. They are stated to be based from information given by a pensioned Head Constable, who contracted for the existing Station house and also from in:formation obtained locally. It is also reported that labour has to be imported from the plains & that owing to the cold & prevalence of fever, much difficulty is ex:perienced in inducing labourers to work &c.

The site has been selected in consultation with the Supdt & Asst. Supdt. of Police & the proposed new buildings are to be built to the east & west of the Station house. The land belongs to Govt.

The plans & estimates have been countersigned

by the I.G. of Police & approved in the Judicial Dept.

15/8/96

To be print. [illegible]

Dw

On orders —

11/8/96

C. No. 6346 No. 2477 W, dated 27th August 1896 **P. W. Secretariat.**

Note by Budget Section.

Work Constructing a Police Hospital and Magazine and improving the Police Station-house at Chintapalli, Vizagapatam District.

Fund - Provincial

Service Head Civil Buildings

Departmental Head Original Works.

Amount of Estimate	Rs. 12,300	
Expenditure in previous year ...	" "	
Allotment in current year ...	" 4,000	(Item No. 91 of the final issue of the Provincial budget for 1896-97)
Balance required to complete ...	" 8,300	
Total Rs...	12,300	

Note of available Funds.

The amount at the credit of the Provincial Reserve is Rs 46,149. As it is proposed to reserve Rs 30000 for works at Govt. Houses, Guindy and Madras, and the drain near the Fort, there is left a sum of Rs 16,149 only available for other works.

11.8.96.

Note by Budget Section.

[G./53]
3,000—26-3-96

18

Judicial *Department.*

CHIEF SECRETARIAT, MADRAS.

PROCEEDINGS OF THE MADRAS GOVERNMENT.

~~Read the following paper:—~~

× B.P. 1349 w.d. 7.6.95

⊗ Not Comm'd

Read again G.O.'s Nos 1153 ˣ & 688 ⊗ dated 29th May 1895 and 7th April 1896 respectively.

Read also the following:-

From the Inspector-General of Police, No 2377, dated 16th June 1896:-

I have the honour to submit, duly countersigned, for the sanction of Government, plans and estimates amounting to ~~as~~ Rs 12,300 for the construction of a Police Hospital and Magazine and improvements to the station house at Chintapalli in the Vizagapatam District.

2. The estimates have been revised in accordance with the instructions contained in G.O., No 688 Judicial, dated 7th April 1896. The amount of the estimate has been reduced from Rs 17,300 to Rs 12,300.

3. The Superintending Engineer says "At Chintapalli, labor "is scarce, working hours limited and materials dear and have "to be conveyed to workspot by coolies: under these circumst- "-ances, I do not think that the accompanying estimate is "capable of any further reduction."

O R D E R :- No 1120 dated 6th July 1896.

The revised plans and estimates are approved and will be transferred to the Public Works Department.

(True Extract) Francis

For Chief Secretary.

To
The Public Works Department (with enclosures)
---- Inspector-General of Police.

6

Judicial

The Public Works
Department

1920 6 July

pproving and transfer
the P.W.D. revised
[illegible] to [illegible]
the [illegible] of a
Hospital
[illegible]

[G/15]

6346

Govt. of {1896} Madras.

Judicial

Encls 13 (3 plans)
Recd: 14.7.96

To

The Public Works Department.

Proceedings, No. 1120 dated 6th July 1896.

Subject.

Approving and transferring to the P. W. D revised plans and estimates for the construction of a Police Hospital and Magazine and improvements to the Station House at Chintapalli.

No. 2181 W, d 24-8-93
.. 297 C, d 17-1-96
.. 2681 C, d 5-9-95
.. 1349 W, d 7-6-95

J
15-7-96

R.S. 322

24TH AUGUST 1893, No. 2181 W., PUBLIC WORKS.

GOVERNMENT OF MADRAS.

PUBLIC WORKS DEPARTMENT.

Buildings and Roads.
Civil Works.

READ—the following paper:—

G.O., dated 7th August 1893, No. 1569, Judicial.

Read—the following letter from the Inspector-General of Police, dated 14th July 1893, No. 3916:—

I have the honour to bring to the notice of Government that in the *standard designs* for Police station-houses the loop-holes in the lock-ups can easily be made the means of conveying articles from outside to the prisoners in the cells; these loop-holes seem unnecessary for the purpose of ventilation; the ventilator at the top and the iron barred doors should suffice, more especially as prisoners are never confined in them for more than a few hours at a time. I beg therefore to ask that the plan may be revised.

2. I would also suggest that all lock-ups should have boarded roofs.

Order—dated 7th August 1893, No. 1569, Judicial.

The Inspector-General's proposals are approved and the necessary action will be taken in the Public Works Department.

(True Extract.)

(Signed) J. F. PRICE,
Chief Secretary.

ORDER—dated 24th August 1893, No. 2181 W., Public Works.

Communicated to officers of the Public Works Department in view to the standard designs circulated with G.O., Nos. 435 W., dated 26th February, and 1828 W., dated 2nd August 1880, being corrected in accordance with paragraph 1 of the Inspector-General's letter.

2. With reference to paragraph 2 of the same letter, it is observed that the estimate of quantities issued with G.O., No. 1828 W., dated 2nd August 1880, provides for a planked ceiling for the roof of all lock-ups in tiled station-houses.

(True Extract.)

(Signed) J. HANNAN,
Ag. Joint Secy. to Govt., P.W.D.,
General, Buildings and Roads Branch.

To Superintending Engineers.
,, the Consulting Architect to Government.
,, the Judicial Department.

Exd. C. A. Munisawmy.
Spare Copies

BUILDINGS AND ROADS.
CIVIL WORKS.

Govt. of {1893} Madras.

PUBLIC WORKS.

Dated August, 24th.

Recd. Encl.

G.O., 24th Aug. 1893, No. 2181 W.

AUGUST.

Standard designs for Police Station-houses

Proceedings, Judicial Department, approving of certain proposals of the Inspector-General of Police for revising the —, communicated to Superintending Engineers with instructions.

Copy of letter from the Inspector General of Police, dy 11th May 1895, No 2853.

I have the honour to solicit the sanction of Government for the following works at Chintapalli, Vizagapatam District, viz:

1. Construction of a Police Hospital and Magazine.

and 2. improvements to the station House, being carried out by the Public Works Department.

2. In G. O. No 1874, dy 5th October 1892, J.D. Government remarked that it would be desirable that the hospital and magazine should be more durable structures than the other buildings and asked the Inspector General of Police to offer his suggestions. This was done by Colonel Porteous in his letter No 7935, dated 22d December 1892, disposed of in G. O. No 2389, dated 28th December 1892, J.D. The suggestions were that the hospital should be of the same materials as the huts, but that it should have a corrugated iron instead of a thatched roof, that the flooring on the basement should be asphalte or cement and that the walls, for about 3 feet should be built of brick or stone in chunam, and that for the Magazine, a small brick and chunam bomb-proof building might be erected.

3. The Station House at Chintapalli was constructed

constructed in 1891 at a cost of Rs: 2612. In October 1893, when Colonel Porteous visited the station, he left the following remarks in the visiting book.

"The present back of station will become its front for which a verandah will be required. The station also requires lengthening at both ends for store rooms &c: At present the lock-ups and record room are used for storage of tools, ammunition &c"

A rough plan of the station house building is enclosed. The portion in pink is the existing building that in yellow the two rooms proposed to be added, the portions marked in pencil a, b, c are the verandahs to be newly added. The estimated cost of these improvements is about Rs: 2,400.

4. In G.O. No 1594, d/ 30th July 1888, the Government approved of Colonel Porteous' proposal that the buildings at Chintapalli be constructed by departmental agency, through local contractors and Muttadars, the Public Works Deptt having expressed its inability to do the work. Subsequently Colonel Porteous recommended that the pucka buildings should be constructed by the Public Works Deptt, as it was found impossible for the Police Department to carry them out. (paras: 4, 5, 8 and 10 of his letter disposed of in G.O. No 1874, dated 6th October 1892, J.D.). The present Superintendent states, in his letter No 308, d/ 29th March 1895, herewith submitted, that there is only one muttadar left at Gudem, that his hill people cannot do anything more than mud work that it is extremely difficult to get them even to do that, the contractor, who constructed the Police Station refuses to do any work, and that under these circumstances, the Police Department cannot carry out the pucka works. From a copy of the Executive Engineer's letter forwarded by the Superintendent with his letter above quoted, it appears that that Officer is willing to undertake the construction of the buildings at Chintapalli.

5. I therefore request that Govt may be pleased to issue orders in the Public Works Department for the preparation of the necessary plans and estimates.

(1) for the Police Hospital at Chintapalli.
(2) for the Magazine at Chintapalli
(3) improvements to the station which can be conveniently done at the same time as the above two works.

6. In its order No 2197, d/ 10th September 1894, J.D. Government decided that Chintapalli should remain the Head Quarters of the Police in the Golgonda Hills and directed that the construction of the stockade and the

and the necessary buildings at Chintapalli should be vigorously pushed on. A well, station house and huts have already been built by departmental agency at the cost shown in the margin. 18 more huts (including 3 for Inspector) are required, and these will also be erected by departmental agency. The hospital and magazine (and therewith certain additions to the Station House) are herein recommended for construction by the Public Works department. The stockade being of earth work will be erected by the Police Department. These complete the list of works at Chintapalli. I ask for the very early orders of Government on the matter. The completion of the Police Station and surrounding buildings at Chintapalli is a very urgent matter. In view of the two grave disturbances which have taken place in these Hills in the last ten years, it is of the greatest importance that the orders of Government regarding the satisfactory housing of Police at Chintapalli should be carried out. Unfortunately the difference in the views taken by the Agent and Col: Porteous as regards the system under which the Police should occupy these Golgonda Hills hindered the completion of the works at Chintapalli. Now that that matter has been finally settled I hope that no avoidable delay will take place in carrying out the urgent works referred to in this letter.

	R.
Well	355
Station House	2612
30 Huts	3750

Encl. No. 2 to letter No. 2853 dated 11th May 1895 from the I. G. of Police

No. 308.
(Enclosure 2)

OFFICE OF THE SUPERINTENDENT OF POLICE
Vizagapatam. 29th March 1895.

From
C. G. W. Clogstoun Esqre.
~~H. G. YOUNG Esqre.~~
Ag: SUPERINTENDENT OF POLICE,
VIZAGAPATAM DISTRICT.

To
THE Inspector General of Police
Madras.

Reference:- Chief office memoros, No. 599
dated 16th October 1894 and No.
237 dated 19th January 1895.

Sir,
I have the honor to request that
Government may be moved to issue the necessary orders for the preparation of plans and Estimates by the Public Works Department for the construction of the Hospital and Magazine at Chintapally and certain improvements to the Station House building at Chintapally. Copies of letters from the Superintending Engineer and the Executive Engineer are attached for perusal.

It will be seen that the Superintending Engineer in para 2 of his letter states that Government has decided that such works should be undertaken by the Police. This however was not decided as an ultimatum

NB

If such a decision was arrived at it was simply due to the fact that the D. P. W would not give us a decisive reply as to whether they would or would not undertake these works.

They however led us to understand that they did not particularly care about taking up construction works in the Gudem Hills.

Matters have now taken a different turn. I persuaded the Executive Engineer to accompany me in February last to Chintapally and it will be seen by his letter that he is willing to undertake the works.

I may as well add that our Department cannot possibly undertake the construction of such pakka works.

There is now only one Muttadar left visibly at Gudem 14 miles from Chintapally, his hill people cannot do anything more than mud work and it is extremely difficult to get them even to do that.

As for Contractors the only one we could get for the construction of the Police Station which took us two years to build now refuses to assist us in any way and if these works are left to us to carry out it will probably be 10 years before they are completed and the work would not be half as good as the D. P. W can turn out.

I have the honor to be
Sir
Your most obedt. Servt.
Cuthbert G W Crosthwaite
Ag: Superintendent of Polic

Dam

57
1772

FROM

THE SUPERINTENDENT OF POLICE,

VIZAGAPATAM DISTRICT.

To

The Inspr. Genl. of Police

Madras.

No. 308
Dated 29. 3. } 95
Despatched 30th do }

Subject

Requesting with remarks that Govt. may be moved to issue the necessary orders for the preparation of Plans and Estimates by D. P. W. for the Construction of Works at Chintapalle

[illegible] / [illegible]/95

OFFICE OF THE INSPECTOR GENERAL OF POLICE
3 APR 95
MADRAS

1895
Jud.
Bundle No. 2
G. No. 2430.

Encl. No 3 to letter No 2853 dated 11 May 1895 from the I. G. of P.

Vizagapatam Division Office

No 3703 of 18.3.95.

From
The Executive Engineer
Vizagapatam Dn.
To
The Superintendent of Police
Vizagapatam.

Sir,

With reference to your letter No 81/25.1.95 I have the honor to forward a Copy of Superintending Engineer's No. 777 V2 and to state that if you wish me to undertake the work in question, I am quite willing to do so and you may inform the Inspector General accordingly. But the orders of Government will have to be obtained before I may submit the plans and estimates.

I have the honor &c
(Sd) G. J. Handcock
Executive Engineer
Vizagapatam Dn.

(True Copy)

Cuthbert G. W. [illegible]
Ag: Superintendent of Police

Judicial Department.

1895
Jud. Dep^t.
Enclos. No 3
To
C. No 2430.

Pr. P.W.S. 1
4244/55

PROCEEDINGS OF THE MADRAS GOVERNMENT.

READ the following paper :—

Copy attached

From the Inspector General of Police, d/ 11th May 1895, No. 2853.

Order:- d/ 29th May 1895 No. 1153.

The Inspector General's proposals are approved and the necessary orders for the preparation of plans and estimates for the Police hospital and Magazine and the improvements to the station house at Chintapalli in the Vizagapatam District, will be issued in the Public Works Department. The Inspector General should consider whether the buildings should not be loop-holed and should, if possible, see that they are so arranged as to provide for flanking fire.

(True Extract)
Lionel Davidson
28/5
Ag. Under Secretary
for Chief Secretary.

To

The Public Works Deptt. (with enclos.)
" Inspector Genl. of Police.

WR
28/5

P. W. CURR

4241

urgent

129 Enclos 4 (1 Plan)
Recd: 5. 6. 95

B

No. 1349W Dt 7th June 1895

Communicated to the Suptg: Engineer I Circle who will arrange for the early preparation of the required plans and estimates

Communicated to the Suptg: Engineer I Circle who will arrange for the early preparation of the required plans and estimates

Rem Min. OOP 31.V

[illegible]
30/5 95

S
20.5

DESPATCH
1 JUN. 95

S.E. I Circle with 1 plan.

S.E. I Circle with 1 plan

R.S.
Reminder sent 2 6/6

B 108
R 5/6

Te. 11/6

S. E. I/5 500—4-4-95

No. 685 V. Z.

From

A H Garrett Esqr
Superintending Engineer
First Circle,

Enclosures, 10. To

The Inspector General
of Police
Madras

Dowlaishweram, 11 Jany 1896.

Sir,

With reference to G.O. no. 1349W/7.6.95, I have the honour to forward herewith plans and estimates amounting to Rs 17300 for (I) the Police hospital and Magazine and (II) the improvements to the Station house at Chintapalli in the Vizagapatam District, for your countersignature and submission to Government for Sanction.

I have etc
Sd A H Garrett.
Supg Engr 1st Circle

No. 686 V. Z. dated 11th January 1896.

Copy submitted to the Chief Engineer P.W.D. with reference to his memorandum no: 2681C/5.9.95

Supg Engineer 1st Circle

E.F. 11/1

P. W. CURRENT No. 345

From A. H. Garrett Esqr.
Superintending Engineer I Circle

To The Chief Engineer P.W.D.
Madras,

Recd: 15-1-96

Dated 11th
Despd: 11th January 1896

No. 686. V.2.

No. C 297 cd/17th January 1896
Recorded

Recorded

Subject

Police Hospital & Magazine and Station house at Chintapalle- submits copy of letter to the Inspector General of Police, Madras forwarding plans & estimates for — for counter-signature and submission to Govt. for sanction

Cat 1818
15/1 96

16/1/96

T/B

No. 1349 W. d/7-6-95

Cr

22/1