Public Works (1896) Department.

G.O., No. 40

DATED 8-1-96

[Despatch Abstract.]

Police Ward. Estimate of Rs 4250 for constructing a — in the Compound of the new Civil dispensary at Kollegal, in the Coimbatore D. C., sanctioned with remarks.

P.W. 86
[illegible]

BACK PAPERS.

G.O.	No.	Department.	Date.	G.O.	No.	Department.	Date.

FURTHER PAPERS.

G.O.	No.	Department.	Date.	G.O.	No.	Department.	Date.

BUILDINGS AND ROADS.
CIVIL WORKS.

Govt. of {1896} Madras.

PUBLIC WORKS.

Dated January, 8th.

Recd. *Encl.*

G.O. No. 40 W., 8th Jan. 1896.

JANUARY.

Police Ward

Estimate of Rs. 4,250 for constructing a — in the compound of the new civil dispensary at Kollegál in the Coimbatore district, sanctioned with remarks.

No. 40 W., 8th January 1896.

GOVERNMENT OF MADRAS.

PUBLIC WORKS DEPARTMENT.

Buildings and Roads.
Civil Works.

Read—the following paper:—

G.O., No. 2372, Judicial, dated 18th November 1895.

Read—the following paper from the Inspector-General of Police, dated 28th October 1895, No. 5394:—

With reference to G.O., No. 1638, Judicial, dated 6th August 1895, I have the honour to enclose a rough plan of the hospital compound at Kollegál showing where it is now proposed to build the police hospital.

2. The Superintendent proposes to leave the southern side of the building without a verandah. As the building was designed to face originally, I intended the eastern side (the back of the building) to have no verandah, "west" was a mistake in my letter. Now the building has been turned round and faces north with its southern side against a jungle stream. I do not agree that this side should be left without a verandah. It will make the building very hot to leave it so. My only idea in altering the original design, which gave a verandah on all sides, was to save expense, the difference being between Rs. 5,320 and Rs. 4,250. Under the present circumstance I think the original estimates for verandahs on all sides should be sanctioned. If the Government agrees, I will obtain and forward them.

Order—No. 2372, Judicial, dated 18th November 1895.

The Government approves of the situation for the building now chosen and marked on the plan, but there appears to be no necessity for a verandah on the south side towards the Nullah and this should be omitted. In other respects the design is approved, and the plans and estimates will be transferred to the Public Works Department.

(True Extract.)

(Signed) W. FRANCIS,
for Chief Secretary.

Note by the Chief Engineer, Public Works Department.

The undersigned considers that it is desirable to increase the width of the concrete foundations from three feet to four. This will entail an excess of about Rs. 104 which can, however, be met by adhering to the following schedule rates, the necessity for deviating from which has not been explained:—

	RS.	A.	P.		RS.	A.	P.
(1) Brick in chunam	18	8	0	instead of	20	0	0
(2) Jungle-wood work	2	4	0	do.	2	8	0
(3) Three-fourth inch asphalting ...	16	0	0	do.	18	0	0
(4) Plastering two coats	2	4	0	do.	2	8	0
(5) Wood-oiling	1	8	0	do.	2	0	0

(Signed) J. PENNYCUICK, Col., R.E.,
Chief Engineer, P.W.D.

20th December 1895.

Order—No. 40 W., dated 8th January 1896.

The estimate, amounting to Rs. 4,250, for constructing a police ward in the compound of the new civil dispensary at Kollegál in the Coimbatore district, is sanctioned.

2. The attention of the Superintending Engineer, IV Circle, is drawn to the Chief Engineer's note and to the Proceedings in the Judicial Department recorded above.

3. The Superintending Engineer will report the amount that can be spent on the work during the current official year.

4. The sanction accorded in paragraph 1 has been registered as Provincial No. 89 W. of 1895-96, and classified as Civil Buildings, Original Works.

(True Extract.)

Under Secy. to Govt., P.W.D.

To the Superintending Engineer, IV Circle, with six enclosures.
„ Examiner, Public Works Accounts.
„ Judicial Department.

Exd. Md. Pahilvan.
Spare Copies

X

Public Works Department.

No. 40 W. of 8th January 1896

PROCEEDINGS OF THE MADRAS GOVERNMENT.

Pr. Civil W[illegible]

Read the following

Print

Proceedings of Govt. in the Judicial Deptt. No. 2372 d/18th Novr. 1895

Note by the Chief Engineer P.W. Deptt. d/ 20th Decr. 1895

4 P

The estimate, amounting to Rs 4250, for constructing a Police ward in the compound of the new Civil Dispensary at Kollegal in the Coimbatore District is sanctioned.

W
5 Jan

2. The attention of the Suptg. Engineer, IV Circle, is drawn to the Chief Engineer's note and to the Proceedings in the Judicial Department recorded above.

3. The Suptg: Engineer will report the amount that can be spent on the work during

during the current official year.

4. The sanction accorded in para 1 has been registered as Provincial No 89 W of 1895-96 and classified as Civil Buildings, Original Works.

CWB 16/12 95

PWH No 20/12 R7/1

Estimate for a Police ward in the compound of the new Civil Dispensary at Kollegal, Coimbatore Dt.

Th/B III

To

The S.E. IV Circle with 6 enclos.
" Exar P.W. Accts
" Judicial Deptt

P.W.D.

No 40 W of 8th Jany 1896.

Note by the Chief Engineer P.W.

3P

The undersigned considers that it is desirable to increase the width of the concrete foundations from three feet to four. This will entail an excess of about Rs 104 which can however be met by adhering to the following schedule rates, the necessity for deviating from which has not been explained:

(1) Brick in chunam	Rs 18-8-0	instead of Rs 20-0-0
(2) Junglewood work	Rs 2-4-0	Do Rs 2-8-0
(3) 3/4" Asphalting	" 16-0-0	Do 18-0-0
(4) Plastering 2 coats	" 2-4-0	Do 2-8-0
(5) Woodoiling	" 1-8-0	Do 2-0-0

PWH

CWBs 16/12 95 E.W.

No 40 W. of 8th January 1896

Public Works Department.

Current No. 9,313.

Letter No. 2,372

Dated 18th November 1895

From the Judicial Dept.

NOTE BY TECHNICAL SECTION.

Name of Work Constructing a Police ward in the compound of the new Civil Dispensary at Kollegal. Coimbatore District.

Amount of Estimate, Rs. 4,250.

PARTICULARS OF ESTIMATE.

Main Building	Ward.	Rs.	3,982
Subsidiary Buildings		,,	..
Contingencies	5 %	,,	170
Petty Supervision	2½ %	,,	98
Land compensation		,,	..
Total Rupees ...			4,250.

PARTICULARS OF CONSTRUCTION.

Surface soil not stated.

Sub soil firm gravel at a depth of 3 feet.

Foundations are proposed to be laid to a depth of 3 feet with concrete to ground level.

Basement is to be raised 2 feet high & built of brick in chunam.

Walls of the ward are to be raised 14'3" & of the verandah rooms 9 feet & built of brick in chunam with flat archwork over doors & windows

Plastering ~~or Pointing~~ the interior & exterior faces of walls are to be plastered with 2 coats of chunam.

Flooring is to be of concrete 6" thick & the surface laid with 3/4" asphalte.

Roofing is to be of flat & pan tiles laid over teak reapers, ~~and~~ jungle wood rafters &c. the ridge ventilator is to be of corrugated iron.

Doors and Windows are to be of the description which in the estimate of teakwood & painted 2 coats with Silicate chocolate paint.

Roof timbers of the trusses purlins, bressummers are to be of teak & rafters hips &c. of junglewood.

Scantlings are correct.

Rates a few of the rates are in excess of the Divisional schedule, vide remarks.

The plinth area of the main building is 2,013 square feet, and the cost per square foot will be Rs. 2-1-9 exclusive of slips

The plans and estimate~~s~~ have been countersigned by the Inspr. General of Police and approved in the Judicial Dept. with ~~Department~~. the remark that there appears to be no necessity for a verandah on the south side towards the nullah, which should be omitted.

~~Remarks~~

: Remarks :

The plans & estimate under review have been framed with reference to G.O. No. 934 W dated 5th Ap 1894 & provide for constructing a Police ward to accommodate 12 beds in the compound of the new Civil Dispensary at Kollegal in the Coimbatore District.

The ward is to be 61'0" x 33'0" outer dimensions & will consist of a large room 38'6" x 20'0" & two verandah side rooms each 8' x 8' with front & side verandahs 8 feet wide, & is to accommodate 12 beds.

The following rates are in excess of the Divisional schedule.

Brick in chunam	Rs 20....	against	Rs 18-8.. ×
Jungle woodwork.	2-8..	-do-	2-4..
3/4" Asphalting	18....	-do-	16....
Plastering 2 coats.	2-8..	-do-	2-4..
Wood ceiling	2....	-do-	1-8..

× These rates for Erode Sub-Dist. in which the building is situated.

~~[illegible]~~ The Judicial Dept. in approving the plan & estimate remark about the omission of the rear verandah towards the nullah. the plan & estimate submitted provide for this omission.

9-XII-95

If schedule rates be adopted the amount of the estimate will be reduced by Rs 200-

The estimate may be sanctioned with a note to the effect that it is considered desirable to increase the width of the concrete foundations from three feet to four. This will entail an excess of about Rs 104 which can however be met by adhering to schedule rates namely:-

Brick in chunam Rs 18-8 instead ~~of~~ of Rs 20

and it is observed that no necessity for deviation from these rates had been explained

CNBB
13/12/95

[G./53]
3,000-13-8-95.

Judicial *Department.*

CHIEF SECRETARIAT
MADRAS.

P. 934 W
5/4/94

PROCEEDINGS OF THE MADRAS GOVERNMENT.

READ the following paper:—

From the Inspector General of Police, Madras, dated I2th. July I895, No. 4306.

I have the honour to submit, for the sanction of Government, plans and estimates amounting to Rs. 4350, for the construction of a Police Hospital ward at Kollegal in the Coimbatore District.

2. The work was approved of in G.O., dated 29th. March I894, No. 772 J.D.

3. The Superintending Engineer at first forwarded an estimate amounting to Rs. 5320 to accommodate I2 beds. I considered the amount excessive, and at my suggestion the estimate was reduced to Rs. 4350 by ommitting a Verandah and two corner rooms on the west side of the building- I do not think that the estimate can be reduced any further.

ORDER, dated 6th. August I895, No.I6~~85~~38.

It appears from the plans submitted with the Inspector General's letter that there will only be a space of 6 ' 9 '' between the Police Hospital and the Civil Dispensary. Hospital buildings should not be crowded together so closely as this.

3.

2. If it is necessary to omit any Verandah, it should be that on the northern side of the building and not that on the western side upon which the ~~monsoon~~ monsoon beats.

3. The plans and estimates will now be returned to the Inspector General for revision with reference to the foregoing remarks.

(True extract)

/ Signed / J.F. PRICE,

CHIEF SECRETARY.

P.W. Secl
9313/95

[G. / 53]
3,000—15-8-95.

Judicial Department.

Read – the following paper
G.O. dated 18 Nov 1895, No. 2372
Read the foll.

PROCEEDINGS OF THE MADRAS GOVERNMENT.

READ the following paper:—

From the Inspector General of Police, Madras, d/ 28th. October 1895, No. 5394.

With reference to G.O.No. 1688 Judicial, dated 6th. August 1895, I have the honor to enclose a rough plan of the Hospital compound at Collegal, showing where it is now proposed to build the Police Hospital.

Not need be
P.W. Secretariat
[illegible] 13th

2. The Superintendent proposes to leave the southern side of the building without a Verandah. As the building was designed to face originally, I intended the Eastern side (the back of the building) to have no Verandah, 'West' was a mistake in my letter. Now the building has been turned round and faces North with its southern side against a Jungle stream. I do not agree that this side should be left without a verandah. It will make the building very hot to leave it so My only idea in altering the original design, which gave a verandah on all sides was to save expense the difference being between Rs. 5320 and Rs. 4250. Under the present circumstance I think the original estimates for verandahs on all sides should be sanctioned. If the Government agrees, I will obtain and forward them.

---------0---------

ORDER,

ORDER, dated I8th. November I895, No. 3372.

The Government approves of the situation for the building now chosen and marked on the plan but there appears to be no necessity for a verandah on the south side towards the Nullah and this should be omitted. In other respects the design is approved, and the plans and estimates will be transferred to the Public Works Department.

(True extract)

H Francis

Ag. Under Secretary,
for Chief Secretary.

To

The Public Works Department. with copy of G.O 1638/6-8-95
.. Inspector General of Police.

2

[G/15]

P. W. CURRENT No. 9313

Govt. of {1895} Madras.
Judicial dept

Recd. 25.11.95

To

P. W. D.

En: 7
(3 plans)

No. 3094 W d/ 22-11-86 ✓
" 2806 W. " 7-10-92 ✓
" 281 W " 4-2-93 ✓
" 525 W " 28-2-93 ✓
" 1343 W " 18-5-93 ✓
" 3008 C " 4-9-93 ✓
" 3153 W " 5-12-93 ✓
" 934 W " 5-4-94 ✓
" 1566 W " 26-6-95 ✓

Proceedings, dated 18 November 1895.
No. 2372.

Subject.

Approving and transferring, with remarks, to P.W.D. plans & estimates for the construction of a Police ward in the compound of the new Civil Dispensary at Kollegal, Coimbatore Dist.

I

Yr secretary

CWM 28/11/95