

Public Works (1898) Department.

*www*  
G.O., No.

611 J

DATED

12<sup>th</sup> August '98

13/6

[Despatch Abstract.]

Inspection Bungalow at Lalpet

Revised Estimate of  
Rs 2280 for reconstructing the          in  
the Chidambaram St, S. Arcot Str, sanctioned.

110/6

781

28  
19/8/98

Department

IRRIGATION.  
ACCOUNT.

Government {1898} of Madras.  
PUBLIC WORKS.

Recd.

Enclosures

} 1898.

Regd.

Spare copies

G.O., No. 611 I., 12th August 1898.

AUGUST.

Inspection Bungalow at Laulpet

Revised estimate of Rs. 2,280 for reconstructing the — in the Chidambaram taluk, South Arcot district, sanctioned.



Public Works (1898) Department.

CURRENT No. 6714

from the Chief-Engineer for Infra

Order

No. 2129

Dated 8-8-98

Received

Registered

11-8-98

Enclosures 4-5

Spare copies

SUBJECT.

Inspection Bungalow at  
Saulpet, Chidambaram Taluk  
Holi recommending for sanction  
revised estimate of Rs 2280 for  
reconstructing —

## FURTHER PAPERS.

## IRRIGATION BRANCH.

PROCEEDINGS OF THE MADRAS GOVERNMENT.

UNDER date the

READ the following

From Supg Enp. V. C. Rich, No. 279 E. I. of 25 July/98  
 Note by the Ag Chief Enp  
 for Disposition.

July 10. No. 7995, 4  
1<sup>st</sup> Sept 1997, an estimate  
amount to Rs 1600, for  
reconstructing the  
inspection bungalow  
at Laulpet, Lower  
Cokeron ancient system,  
was sanctioned. The  
Suff Eng. Clark,  
now submits a revised  
estimate involving  
an excess of Rs 250  
which is chiefly due to  
it being absolutely  
necessary to increase  
the height of the basement  
from 1 foot to 2 feet &  
to the materials from

to suit the levels of  
the site selected.

BACK

No.

The dismantled bungalow being valued at only half the amount originally anticipated. The excess may be passed.

Order thereon No 6112 of 12.8.98.

The following revised estimate is sanctioned in super-session of the estimate of Rs. 1980 sanctioned in G.O. No 799 of 1st Sept. 1997:-

Irrigation  
43. Minor works Major - Minor works for which Capital & Rev. Accts are kept.

Lower Coleroon Canal System  
Capital Account

1. Head works  
4. Buildings.

Reconstructing inspection bungalow at Sankar,

in the Chidambaram taluk, South Arcot Dist.

|                   |             |
|-------------------|-------------|
|                   | Rs          |
| I. Works          | 1850        |
| II Establishment  | 426         |
| III Tools & Plant | 4           |
| Total Estimate    | <u>2280</u> |

2. This sanction is registered as No. 60 of 1898-99.

11/8/98

7.8.98

22/8/98

To The Chief Eng for I. S. Supply & Recd with 3 inches by I. S. S.

Recd 5/8/98

BACK

No.

Public Works (1898) Department.

CURRENT No. 45Ja

From  
The Supy Engineer  
Office

No. 2798

Dated 25<sup>th</sup> July 1898

Received 27 — 50 —

Enclosures 4

Spare copies

SUBJECT.

Inspection Bungalows  
at Laulpett Mithamburam Taluk

Submitting for sanction  
revised Estimate of Rs 1850  
for  
for constructing the —

D.S.

18  
Check sent now

27/7 6/11/9

M.H.

The estimate has been  
checked

Sd.  
4/8/98

Sd.  
4-8-98.

## BACK PAPERS.

| No.     | Date.    |
|---------|----------|
| R 480 J | 14 9. 97 |

## FURTHER PAPERS.

| No.      | Date.   |
|----------|---------|
| J 212 J. | 8 8. 98 |

Report to accompany the revised Estimate for  
reconstructing the Inspection Bungalow at  
Laulpat

Amount of Revised Estimate Rs 1850.

The site chosen for the present Bungalow being low and on sloping ground, it is necessary to raise the basement by one foot more than what is provided for in the original estimate so as to allow of the low position of the ground on the north of the site being filled up.

Further, on demolishing the old Bungalow the woodwork was found to be rotten and the walls built of underburnt bricks and laths. The value of the old materials has therefore been put down at Rs 100 half the amount expected originally.

Among other petty items, demolishing the old Bungalow, clearing site & pointing doors and windows have been included as absolutely necessary.

The Revised estimate provides for all the work is necessary.

NW Myssman-Ed  
22. 6. 88  
Assistant Engineer

APERS.  
FURTHER PAPERS.  
[Faint handwritten text, mostly illegible]

From  
Colonel A.W. Smart R.E.  
SUPERINTENDING ENGINEER,  
V CIRCLE.

To  
THE Chief Engineer  
for Irrigation.

SIR,

- Enclosures. 4  
1 Report  
1 Detailed estimate  
1 Abstract do.  
1 Comparative statement  
4

I have the honour to submit for sanction the enclosed revised estimate of Rs 1850 with comparative statement, for reconstructing the inspection Bungalow at Laupet in Chidambaram taluk, South Arcot Division, showing an excess of Rs 250/- over the original estimate of Rs 1600/- sanctioned in G.O. No 799.I. dated 1<sup>st</sup> September 1897.

The basement allowed in the sanctioned estimate is only 1 foot high and the levels of the ground at the site fixed by Mr. Paul are as follows:—

- 51.28 South west corner
- 50.51 South east —
- 50.00 North east —
- 50.77 North west —

27 JUL 1897  
45.30  
1

565.1  
6714/89

Top of foundation as already built is 50.00.

As the site is on low ground it is therefore absolutely necessary to increase the height of basement from 1 foot to 2 feet - hence the excess over the original estimate

Early sanction to the estimate is requested for proceeding with the work.

I have the honour to be,

Sir,

Your most obedt Servant.

*Am Law*  
Colonel R.R.

Offg Supg Engineer  
5th Circa

45 SA

0.55.5  
6714/58

22.7.98