

Public Works (1898) Department.

G.O., No. 89 W

DATED 14 January 1898

17/1/98

[Despatch Abstract.]

Police Station House at Kandal. Estimate
of Rs. 2565 for constructing a third class
—, cotaca mund, sauchines for ex-
cution when funds are available.

==

100
14

2 m 11 40

Government {1898} of Madras.
PUBLIC WORKS.

Spare copies

JANUARY.

Police Station-house at Kandam
 Estimate of Rs. 2,565 for constructing a third-class —, Ootacamund, sanctioned for execution when funds are available.

GOVERNMENT OF MADRAS.
PUBLIC WORKS DEPARTMENT.

Buildings and Roads.
Civil Works.

READ—the following papers:—

G.O., No. 1423, Judicial, dated 1st October 1897.

Read—the following letter from the Inspector-General of Police, Madras, dated 14th September 1897, No. 3307:—

I have the honour to submit, for the sanction of Government, plans and estimates amounting to Rs. 2,700 for the construction of a third-class station-house at Kandal in the Nilgiris.

2. The order for the preparation of plans and estimates for this work was given in G.O., No. 24, Judicial, dated 8th January 1897.

3. The building will be of brick in chunam to basement level, and the superstructure will be of brick in mud and plastered.

Order—No. 1423, Judicial, dated 1st October 1897.

The plans and estimates, aggregating Rs. 2,700, are approved and will be transferred to the Public Works Department.

(True Extract.)

(Signed) F. J. WILSON,
for Chief Secretary.

From J. HANNAN, Esq., Superintending Engineer, IV Circle, to the Chief Engineer, Public Works Department, dated Coimbatore, 4th December 1897, No. 664/W.

With reference to your memo., No. 4383, dated 28th October 1897, I have the honour to forward, herewith, a fresh plan and an estimate amounting to Rs. 2,600 for constructing a third-class Police station-house at Kandal in Nilgiri district duly revised, and to request that you will be good enough to obtain the sanction of Government to the same at an early date.

Note by the Chief Engineer, Public Works Department.

The Chief Engineer considers that it is sufficient to provide one purlin on each slope of the roof instead of two as designed. By this alteration the estimate has been reduced from Rs. 2,600 to Rs. 2,565.

8th January 1898.

(Signed) W. B. DEWINTON,
Ag. Chief Engineer.

ORDER—No. 89 W., dated 14th January 1898.

The estimate, amounting to Rs. 2,565, as altered by the Chief Engineer, Public Works Department, for constructing a third-class Police station-house at Kandal, Ootacamund, in the Nilgiri district, is sanctioned for execution when funds are available.

2. Attention is drawn to the Chief Engineer's note recorded above.

3. This sanction has been registered as Provincial No. 75 W. of 1897-98, and classified as Civil Buildings—Original Works.

(True Extract.)

Under Secretary to Government.

To the Superintending Engineer, IV Circle, with six enclosures.
" Examiner, Public Works Accounts.
" Judicial Department.

Exd. T. K. Narayana Aiyangar.

A. H. E. the Governor ✓

P.W. DEPARTMENT.

Papers to be read in proceedings:—

Again G.O., dated

189 , No.

Again G.O., dated

189 , No.

Print { Current No. 9902 of 1897, dated 1st October 1897 from the Judicial Dept.
" " 12174 " 1897, " 4th December 1897 " the S.R. IV Circle
" " " 189 " " " the Chief Engineer P.W.D.
" " " " " " " 8-1-98

Printed with
ORDER.

to 896 & 11-1-98

The estimate amounting to Rs 2,565 as altered by the Chief Engineer, P.W.D. for constructing a third class Police Station-house at Kandal, Ota-camund, in the Nilgiri District is sanctioned for execution when funds are available.

2. Attention is drawn to the Chief Engineer's note recorded above.

3. This sanction has been registered as Provincial No. 754 of 1897-98 and classified as Civil Buildings, Original Works.

T. H. B. C. M. P.

The S.R. IV Circle with benches.
" Exar. P.W. Accts.
" Judicial Dept.

Cur
May 21-98

Note. This estimate which is

H. E. 8/1

is dealt with in the accompanying
technical note is ~~not~~ recommended
for sanction.

Cy
May

Srom
7.1.98

H. H. H. / J. 1. 98
W

b.p. P.W.D.
Note by the Chief Engineer

The Chief Engineer
considers that it is sufficient
to provide one purlin on each
slope of the roof instead of
two as designed. By this
alteration the estimate has
been reduced from Rs 2,600
to Rs 2,565.

Srom
P. 9. 98

Cy
May

Srom
7.1.98

H. H. H. / J. 1. 98
E. W.

Public Works Department.

Current No. 12174

Letter No. 664/W

Dated 20 Dec 1897

From the Super Engineer W. C. C. C.

NOTE BY TECHNICAL SECTION.

Name of work Police station house at Kandahar, Afghanistan.

Amount of Estimate Rs 2600.

With reference to this office memo No. 43836 dated 28 October 1897, the SE W. C. C. C. resubmits for early sanction an estimate amounting to Rs 2600 for constructing a Police Station house at Kandahar, Afghanistan, duly revised as per instructions contained in the Memo under reference.

The depth of foundations has now been reduced from 4 to 3 feet and the work carried on purlins only, instead of rafters + purlins as originally proposed.

For particulars of construction &c. please see my note dated 20 Oct. 1897, on the first estimate.

The plans & estimate are in order

89 W
Please see pencil note on plan regarding the purlins being placed unnecessary and too near, should only one purlin be provided for each slope, a large saving would have been effected.

T. The original est. allows 6x4 purlins - if this is the meaning allowed in the original, then 1 purlin will do instead of 2 - the est. can be altered in this office ^{effected} _{from} 4.1.97.

1. The saving in the item roofing by omitting the rafters is only 2 1/2 per cent which is trifling compared with the 50 per cent anticipated by T in his note of 20-10-97.

2. The estimate of Rs 2600 may be sanctioned.

C. H. W.

17/12/97.

DW. The estimate has been ~~altered~~ ^{revised} according to the ~~original~~ ^{revised} plan 5.1.98.

sanctioned from 5/1

W. C. C. C.

13.12.97

Public Works (1897) Department.

CURRENT No. 12174

Order

From The Supg. Engineer
4th Circle.

No. 664
W.

Dated 4th December 1897.

Received 8.12.97

Enclosures 5. 6 (2 plans)

Spare copies ✓

SUBJECT.

3rd Class Police Station house
at Kandal in Nizari District.

Forwards for sanction
of Government a fresh plan &
estimate amounting to Rs 2600
for constructing a —

I am submitting
Cons
9-12-97
✓

$$n = \frac{b_0}{w}$$

From,

J. Hannan Esq
Supg: Engineer, 4th Circle
Coimbatore

40.

The Chief Engineer
P. W. P. Madras.

Li.

Enc: 5

- 1 Site plan
- 1 Plan of building
- 1 Estimate
- 1 Report
- 1 Data sheet.

With reference to your Memorandum No 4383 dated 28th October 1897, I have the honor to forward herewith a fresh plan and an estimate amounting to Rs 2600 for Constructing a 3^d class Police Station house at Kandal in Nilgiri District duly revised and to request that you will be good enough to obtain the Sanction of Government to the same at an early date.

I have the honor to be,

En.

Your Most Obedt. Servant.

Иванов

Supg: Engr. 4" Circle.

Public Works (1897) Department.

CURRENT No. 9902

89/4

From

The Judicial Department

Order

No. 1423

Dated 1st October 1897

Received }
Registered } 7-10-97

Enclosures 6 (2 plans)

Spare copies

SUBJECT.

Approving & transferring the plans & estimates aggregating Rs 2,700 for the construction of a third class police station house at Kandal in the Nilgiris

J

BACK PAPERS.

FURTHER PAPERS.

2.096-24-6-97

Judicial Department.



PROCEEDINGS OF THE MADRAS GOVERNMENT.

READ the following paper :—

From the Inspector-General of Police, Madras, No.5507,
dated 14th September 1897:-

I have the honour to submit, for the sanction of Government, plans and estimates amounting to Rs.2700 for the construction of a Third Class Station House at Kandal in the Nilgiris.

328 kW
4-2-97

2. The order for the preparation of plans and estimates for this work was given in G.O.No.24, Judicial, dated 8th January 1897.

5. The building will be of brick in chunam to basement level and the superstructure will be of brick in mud and plastered.

Order No.1425, dated 1st October 1897.

The plans and estimates aggregating Rs.2700,-
are approved and will be transferred to the Public Works
Department.

(True Extract)

for Chief Secretary.

TO

The Public Works Department
with all enclosures in original.

., Inspector-General of Police.

128
128