

Public Works (1899) Department

G.O., No.

2169 W

DATED 15 August 1899.

[Despatch Abstract.]

Salem Div Office - Report of S.E. [?] Clerk
regarding the accommodation in the
recorded -

Thm. 10/11/99
B

Indexed. 19/11

[illegible]

CURRENT No. 6205

Order No. 262 15-888
Recorded.

No. 418
w

Received } 31. 7. 99

Registered

Enclosures ✓ Plans } 2 Tab
Others }

Spare copies. ~

SUBJECT.

Salem Division Office.

To

The Supts. Ingr., TV Circle

Reports regarding the
accommodation in the _____

LS349 R12/8

BACK PAPERS.

No.	Date.
1404W	2-6-99
489W	16-2-99
3645C	19-8-98
1316W	22-5-98
2822W	6-11-95
2019C	19-10-95
2504W	10-10-95
2027W	15-8-95
925W	22-4-95

FURTHER PAPERS

No.	Date.
-----	-------

No. 418
W

Office of the Suptg Engineer Chile
Camp Salem Dated 28.7.99

From

A. H. Gamett Esquire,
Superintendent Engineer
Chile

To

The Chief Engineer
Public Works Department

Sir,

With reference to para 2 of G.O.
no. 1404^W dated 2.6.1899, I have the honor
to state that I have inspected the Salem
Division office and find that the two
draftsmen work in a room the area of
which is 450 Sq feet and I consider
this space gives them ample room to
work in and to conveniently keep
all their plans and papers. There is
also sufficient light.

2. The accountant and
Clerks work in a room containing
600 Square feet of floor space. A
lot of this space is occupied by an
unnecessary number of boxes which
Should

Should be got rid of, and when the old and useless papers of which there is a large accumulation, are destroyed, I think there will be ample room for the clerical establishment and the office records.

3. As regards the accommodation for tools, I think it will be found sufficient when a lot of surplus tools now in store are transferred.

4. The Clerks complain that the building is low and hot. The height of the roof is 15 feet at the Centre and 7 feet at the sides. There was a ridge ventilator but Mr. Ramanujam Pillai when acting for Mr. Lambert had it closed which should never have been done.

5. Besides some slight repairs including a ridge ventilator and the construction of a good drain round the building, I do not recommend any

any change at present.

I have the honour to be,

Sir,

Yours most obedt Servt.

Arthur P.

Suptg. Engineer M. C. C.