

Public Works (1899) Department.

G.O., No.

2384 W

DATED 11 September 1899.

[Despatch Abstract.]

Tirupati water works -

Encl of ~~pt~~ IV Circle forwarding copy
of letter from the E. E. North Arcot Div
reporting on certain points in the Sanitary
Commissioner's inspection notes on
Command to the Local & Mun. Dept.

G.O.	No.	Department.	Date.	G.O.	No.	Department.	Date.

CURRENT No. 70.12

From The Lupton Engineers
to the Circle

Order

No: 2384 w 3/2-9-88

communicated

No. 467

to the Local & Municipal
Dept. with reference to
L.O. No 980 ll dated
12th July 1898.

Dated 23rd August 1899

Received 3 28 '88-99

Registered

Enclosures

Spare copies

SUBJECT.

Tirupati water works.

of Calumet with his remarks
Copy of letter from the C.
to A. D. reporting on the
Commissioners inspection
on —————

To

The Local & Municipal. Dept.

0.25 449

which

en

ult

Charles

BACK PAPERS.

FURTHER PAPERS.

Copy of letter No: 496_{SE} of 16th August 1899 from
S. D. Pears Esq. Executive Engineer, North Arcot
Dist. to the Suptg Engineer T. V. Circle

In reply to your No: 444
12.8.99, I have the honor
to report that the suggestion in the Sanitary
Commissioner's para 2 has already been
carried out.

2. With regard to para 3, the rats and snakes are welcome to make a residence of the overflow Chamber for they cannot get at the water to contaminate it. The masonry is in my opinion preferable to the iron suggested by the Sanitary Commissioner as being less liable to injury and more easily repaired when injured.

3. With regard to parapet, the usual masonry pillars have been adopted, but with pointed (instead of cement plastered) surfaces

4 The Sanitary Commissioners' Objection
seems rather fine-drawn and it is
hardly worth while to partly demolish
all the pillars (all of which have been
completed) merely in order to build

lazed

tiles into them.

N 3464
W

Forwarded to the Chief Engineer P.W.D.
with reference to G.O. no: 2064 W of 7. 8. 99.

The suggestions of the Sanitary Commissioner
in para 2 have been carried out and
it does not seem necessary to make
any alteration in the overflow Cham-
ber. As regards the Sanitary Com-
missioner's remarks in para 4, the
insertion of the glazed tiles might be
postponed till it is seen whether
the pillars do become dangerously
unsanitary.

Camp Trapatwa }
23rd August 1899 } Mr. [unclear]
Inftg: Engr: W. C. [unclear]

To
The Chief Engineer
P.W. Department