

Public Works (1899) Department.

G.O., No.

2614 W

DATED

5 Oct 1899.

[Despatch Abstract.]

Trinipati Water Works

Proo. Loe & run Sept recording P.W.D.
order communicating endorsement of the
S.E. IV Circle on the Sanitary Commissioner
inspection notes on the — recorded —

[illegible]

G.O.	No.	Department.	Date.	G.O.	No.	Department.	Date.

CURRENT No. 7928

The Local Municipal Dept^y

Order

No: 2614 W & 5-10-8
Recorded.

No. 1392d

Dated 22-7-99

Received

Registered

Enclosures


Spare copies.

Tripathi Waterworks

Recording SO M^d Communicating
endorsement of the Superintending
Engineer 18 Board on the Sanitary
Commissioners' inspection notes on —

Rs. 549 Rupees

No.	Date.
2384W	12-9-98
2064W	7-8-98
3221C	21-7-98
2986C	3-6-98
2724C	15-7-98
2444C	20-5-98



PROCEEDINGS OF THE MADRAS GOVERNMENT.

READ the following paper:—

Proceedings of the Public Works Department, No. 2384 W.,
dated 12th September 1899.

Read the following :-

Letter from the Executive Engineer, North Arctic Division,
No. 496 S.E., dated 16th August 1899.

In reply to your No.444/12th August 1899, I have the honour to report that the suggestion in the Sanitary Commissioner's para.3 has already been carried out.

2. With regard to para.3, the rats and snakes are welcome to make a residence of the overflow chamber for they cannot get at the water to contaminate it. The masonry is in my opinion preferable to the idea suggested by the Sanitary Commissioner as being less liable to injury and more easily repaired when injured.

3. With regard to para.4, the usual masonry pillars have been adopted, but with pointed (instead of cement plastered) surfaces.

4. The Sanitary Commissioner's objection seems rather fine-drawn and it is hardly worthwhile to partly demolish all the pillars (all of which have been completed) merely in order to build glazed tiles into them.

— 100 —

Endorsement thereon by the Superintending Engineer, IV
Circle, No.467 W., dated 23rd August 1899.

Forwarded to the Chief Engineer, Public Works Department,
with reference to G.O., No. 2064 W of 7th August 1899. The suggestion

of the Sanitary Commissioner in para.2 have been carried out and it does not seem necessary to make any alteration in the overflow chamber. As regards the Sanitary Commissioner's remarks in para.4, the insertion of the glazed tiles might be postponed till it is seen whether the pillars do become dangerously insanitary.

-----+-----


Order thereon No.2384 W., dated 12th September 1899.

Communicated to the Local and Municipal Department with reference to G.O., No. 980 M., dated 12th July 1899.

ORDER. No. 1392 M. Mis., dated 22nd September 1899.

R E C O R D E D.

(True Extract)



for Secretary to Government.

To, The Public Works Department.

" Chairman, Municipal Council, Tirupati,
through the Collector of North Arcot.

" Sanitary Commissioner.