

Public Works (189) Department.

✓ G.O., No.

3157 W

DATED

6th Dec 1907

7/12/1907

[Despatch Abstract.]

By Tahsildar's office at Perundurai,
Combatore Dt. The estimate, amounting
to Rs 19,770 for the construction of a
— sanctioned for execution when funds
are available.

110
4

T
B
CO 24/12

BACK PAPERS.

FURTHER PAPERS.

BUILDINGS AND ROADS.
CIVIL WORKS.

Government {1899} of Madras.
PUBLIC WORKS.

Recd.

Regd.

} 1899.

Enclosures

Spare copies

G.O., No. 3157 W., 6th December 1899.

DECEMBER.

Deputy Tahsildar's office at Perundurai, Coimbatore District

The estimate, amounting to Rs. 19,770, for the construction of a — sanctioned for execution when funds are available.

GOVERNMENT OF MADRAS.

PUBLIC WORKS DEPARTMENT.

Buildings and Roads,
Civil Works.

READ—the following papers:—

G.O., Mis. No. 2818, Revenue, dated 2nd July 1898.

Read—the following papers:—

Reference from the Board of Revenue (Land Revenue), dated 25th March 1898, No. 355, on letter from the Collector of Coimbatore, Ref. on Cur. No. 410-Rev., dated 28th February 1898.

The site plan and estimate amounting to Rs. 20,900 for the construction of a new Deputy Tahsildar's office at Perundurai are submitted for the sanction of Government with reference to G.O., No. 557, Revenue, dated 18th March 1897.

2. The estimate includes a provision of Rs. 704 for fencing the compound of the office with wire. The Superintending Engineer and the Collector, however, are of opinion that a good hedge would be preferable, as a wire fence soon gets out of order. The Board agrees with the Collector and the Superintending Engineer.

Reference from the Board of Revenue (Land Revenue), dated 12th May 1898, No. 532.

ABSTRACT.—Re-submitting to Government the estimates and plans for the construction of a new Deputy Tahsildar's office at Perundurai, duly countersigned by the Collector of Coimbatore, as directed in Revenue official memo. No. 89, dated 4th April 1898.

Order—Mis. No. 2818, Revenue, dated 2nd July 1898.

Approved and transferred to the Public Works Department.

2. The question whether it would not be more economical to substitute a wall of mud or stone for a wire fence will be considered in that department.

(True Extract.)

(Signed) A. S. RUSSELL,
for Secretary to Government.

From A. H. GARRETT, Esq., Superintending Engineer, IV Circle, Coimbatore, to the Chief Engineer, Public Works Department, dated Camp, Ootacamund, 2nd November 1898, No. 579 W.

With reference to your memo. No. 4176 C., dated 22nd September 1898, I have the honour to retransmit the original papers in connection with the construction of a Deputy Tahsildar's cutcherry at Perundurai with alternative estimates for a compound wall of rough stone in mud and for a wire fence with hedge along it amounting to Rs. 2,150 and Rs. 590, respectively.

2. Roofing with Mangalore tiles set in mortar over flat tiles has been allowed for the main building except the jail wards, property room, police guard, passage, arms and record rooms for which terrace ceiling is allowed. For verandahs Mangalore tiles with teak reepers alone have been provided for as in the standard estimate.

Note by the Chief Engineer, Public Works Department.

The estimate for constructing a Deputy Tahsildar's office at Perundurai in the Coimbatore district is recommended for the sanction of Government with the following remarks:—

The estimate provides for spacing the rafters $2\frac{1}{2}$ feet under the Mangalore tiles set in mortar over flat tiles laid on teak reepers $2" \times \frac{1}{2}"$ spaced at 6 inch centres. The distance of the rafters should be altered to $1\frac{3}{4}$ feet apart.

The roof of the record-room should be carried on jack arches laid over rolled steel joists spaced 5 feet apart and of a section $10" \times 5"$ weighing 29 lb. per foot so as to make the room fire-proof.

Morton's patent wire fencing should be used instead of Shaw's patent wire fencing.

The provision of 11 teakwood record-racks should be held in abeyance until the revised design for iron record-racks are circulated.

The total amount of the estimate has been reduced by means of the alterations above proposed from Rs. 19,900 to Rs. 19,770.

(Signed) W. B. DEWINTON,
Chief Engineer.

29th November 1899.

ORDER—No. 3157 W., dated 6th December 1899.

The estimate amounting to Rs. 19,770, as altered by the Chief Engineer, for the construction of a Deputy Tahsildar's office at Perundurai, Coimbatore district, is sanctioned for execution when funds are available.

2. The attention of the Superintending Engineer is drawn to the Chief Engineer's remarks in his note read above.

3. This sanction has been registered as Provincial No. 96 W. of 1899-1900, and classified as Civil Buildings—Original Works.

(True Extract.)

Under Secretary to Government.

To the Superintending Engineer, IV Circle, with twelve enclosures.
" Examiner, Public Works Accounts.
" Revenue Department.

Ed. A. F. Eccleston.

Read the following:—

From the Revenue Department No 2818 M.D. dated 2nd July 1898
 From the Suptg Engineer, IV circle No 579 W dated 2nd November 1898
 Note by the Chief Engineer P.W.D. dated 29-11-99

Circulated to H & the Engineer

ORDER

By Tahsildar's office at
 Perundurai, Coimbatore District
 No: 3/57 W 36-12 EF

The estimate amounting
 to Rs 19,770, as altered by the Chief Engineer
 for the construction of a Deputy Tahsildar's
 Office at Perundurai Coimbatore District
 is sanctioned for execution when funds
 are available.

2. The attention of the Suptg Engineer
 is drawn to the Chief Engineer's remarks in
 his note read above.

3. This sanction has been
 registered as Provincial No 96 W of 1899-1900
 and classified as Civil buildings, Original Works.

PKS
 Note The estimate is dealt with in the ac-
 companying technical note and the Chief Engineer's
 note read above. This estimate has been
 Unaltered in the Technical Branch

PKS
 29-11-99

For
 28/5/1899

Done
 29/5/99

To
 S.E. IV circle with 12
 .. Examined P.W.D.
 .. Revenue Dept

[P. W. 4.
 1,000-18-7-99.]

15/12/99

37

Note by E. W.

The estimate for constructing a Deputy Tahildars Office at Perundurai in the Coimbatore District is recommended for the sanction of Govt. with the following remarks.

The estimate provides for spacing the rafters $2\frac{1}{2}$ feet under the Mangalore tiles set in mortar over flat tiles laid on teak rafters $2\frac{1}{2} \times \frac{1}{2}$ spaced at 6 inch centres. The distance of the rafters should be altered to $1\frac{3}{4}$ ft apart.

The roof of the record room should be carried on jack arches laid over rolled steel joists spaced 5 feet apart & of a section $10" \times 5"$ weighing 29 lbs per foot so as to make the room fire proof.

Ironless patent wire fencing should be used instead of Sham patent wire fencing.

The provision of 11 teakwood record racks should be held in abeyance until the revised design for iron record racks are circulated.

The total amount of the estimate has been reduced by means of the above alterations above proposed from Rs 19,900 to Rs 19,770.

[Signature]
S. W.

W. L.

24/11/99

W. For approval of alterations suggested below.

ACK

22-1-99.

Approved, W. L. W. L. W. L.

[Signature]
23-1-99

Allow for Watson's fence with hedges.

[Signature]

Public Works Department.

Current No. 9110-1998

Letter No. 579/W

Dated 21 November 1898

From the Supply Engineer IV Circle

NOTE BY TECHNICAL SECTION.

Name of work Deputy Tahsildar Office at Perundurai, Cumbalur District.

In reply to the letter from the S.E. dated 22 Sept. 1898, the S.E. IV Circle submits the estimate for constructing a Deputy Tahsildar Office at Perundurai with alterations. The estimate for a compound wall and for a wire fence with hedges along the boundary is Rs 2,150 and Rs 590 respectively.

The estimate now provides for roofing with Mangalore tiles cut in time instead of flat tiles in view of Mangalore tiles & plank ceiling for the main building, except the jail wards, properly worn, police guard, arm and record rooms for which terraced ceiling & Mangalore tiles laid over teak rafters is allowed. The verandah roof will be roofed in with Mangalore tiles laid on teak rafters alone, as per printed estimate.

The necessity for a double roof

over the sub jail wards, pres-
ents worn, police guard, arms &
second room in a place like the
murder in the Criminals Div.
is not apparent, moreover this
description of wiring has also
been objected to by W as the
space enclosed above the tenues
ceiling with harbours damp and
perman.

The estimate provides for spec-
ing the ceiling under the Manager's
room at 2 1/2 feet, this dis-
tance appears to be too great for
Manager's table set in motion on
flat tiles & supports 2 1/2" spaced
6 inch. The ceiling should at
least be 1 1/4 ft apart.

The roof of the second room
should be of jack arches laid over
rolled steel joists & supports to make
the room fire proof.

Perimeter has been made for
all kitchen and second racks, there
should be substituted by iron
racks, vide G.O. No. 5163W of 9th
Decr. 98.

The amount of the estimate in-
cluding Shams patient wire fencing
as submitted is Rs 19,900. This a-
mount will be altered to Rs 20,200
by substituting iron fence for
Shams patient, as now ordered.

The alternative estimate in-
cluding a compound wall of rough
stone in mud in lieu of wire fence
will be Rs 21,460.

W. The type design does provide
for fencing into jail wards &c.
together with tiled roof over kitchen
for places on the West Court.

After, as advised by W
informal estimate
but does not the standard
design which provide
fencing for jail ward-
sc! 21-1-99
T. H. S. / 20-1-99
A.C.H.

Yes. After estimate
accordingly

Yes

Yes

As a wall of stone in mud
involves an excess of Rs 1260
over the cost of Shams patient
wire fencing with bedg. it is
under the Rs 20,200 (Rs 21,460 allowed)

Public Works (189) Department.

CURRENT No. 9220

From The Supt. Engineer,
4th Circle.

No. 579

Dated 2nd November 1898

Received

Registered

Enclosures 1/3. (2 plans)

Spare copies

SUBJECT.

Dy. Tahsildar's Catchment
at Perundurai.

Re transmits certain papers
in connection with the construction
of a — with alternative estimates
for compound wall &c.

Order

The Memo 4176 dated
22 Sept/98, was issued. W has
prohibited the use of Shams' wire
fencing, & has ordered that
to be used. Substitute the latter
in the rest in place of Shams'

A.C.H.

11-11-98.

T. H. S. / 11-11-98
A.C.H. / 11-11-98

BACK PAPERS.



FURTHER PAPERS.

No.	Date.
4176c	22-9-98
+ papers.	

No.	Date.

Public Works (1898) Department.

CURRENT No. 5714



From

The Revenue Department.

Order

No. 2818 Mis.

Dated 2nd July 1898.

Received 7-20

Registered 9-7-28

Enclosures 9 (2 Plans)

Spare copies

SUBJECT.

Approving and transferring to the P.W.D. B.P. (L.R.) submitting, with remarks, for the sanction of Govt. the site plan and estimate amounting to --- Rs.20,900 for the construction of a new Dy. Tahsildar's office at Perundurai.

Handwritten: J. Amerson
APK 20-7-98
OW
283

BACK PAPERS.

FURTHER PAPERS.

No. 579
W.

Superintending Engineer's Office
Fourth Circle
Camp. Aotagamund 2nd Nov^r 1898
~~Chandore~~

From

A. H. Garrett Esq

Supg Engineer & Civil

Coimbatore

20

The Chief Engineer

P. W. Department

Sir

With reference to your Memo-
randum No 4176 C dated 22^d September
1898, I have the honor to retransmit
the original papers in connection with
the construction of a Deputy Tahsildar's
Cutcherry at Perundurai with alternat-
ive estimates for a compound wall of
rough stone in mud and for a wire
fence with hedge along it amounting
to Rs 2150 and Rs 590 respectively.

2 Roofing with Mangalore tiles
set in mortar over flat tiles has
been allowed for the main building
except the Jail Wards, property room,
Police

Police guard, passage, Arms and
record rooms for which terrace ceiling
is allowed. For veranda Mangalore
tiles with teak reepers alone have been
provided for as in the standard
estimate.

I have the honor to be
Sir

Your most obedt. servant

Arthur
Supg Engineer & Co

30. x. 98

REVENUE DEPARTMENT.



PROCEEDINGS OF THE MADRAS GOVERNMENT.

Read the following paper:—

Reference from the Board of Revenue, Land Revenue, dated 25th March 1898, No.355, on letter from the Collr. of Coimbatore, Ref. on Cur. No.410/Rev. of '98, dated 28th Feby. 1898:—

REFERENCE :— The site plan and estimate amounting to Rs.20,900 for the construction of a new Dy. Tahsildar's office at Perundurai are submitted for the sanction of Govt. with reference to G.O. No.557 Rev. dated 13th March 1897.

2. The estimate includes a provision of Rs.704 for fencing the compound of the office with wire. The Supdg. Engineer and the Collector, however, are of opinion that a good hedge would be preferable, as a wire fence soon gets out of order. The Board agrees with the Collr. and the Supdg. Engineer.

Read also Reference from the Board of Revenue, Land Revenue, dated 12th May 1898, No.532, resubmitting to Government the estimates and plans for the construction of a new Dy. Tahsildar's office at Perundurai duly countersigned by the Collector of Coimbatore, as directed in Revenue Official Memo. No.89 dated 4th April 1898.

—:—

ORDER thereon No.2818 Mis. dated 2nd July 1898.

Approved and transferred to the Public Works Department.

2. The question whether it would not be more economical to substitute a wall of mud or stone for a wire fence will be considered in that Department.

(True extract)

A. Russell

For Secretary to Government.

To the Public Works Dept. with encls.

,, Bd. of Revenue, Land Revenue.



"Encls: m23 to letter N2579"
W

Am
6-7-98

63
220/22
26

50