

Public (1895) Department.

ORDINARY MS.

G.O., No. 1307

Dated 11-12-96

INDEXED.

[Despatch Abstract.]

Gout Laper Hospital, Madras. Cont to the Super-
gent Public Works departt proceedings con-
cerning the estimate of Rs 2700 for constructing
a laundry and returning, for upmt. on certain
point, an estimate of Rs 7,190 for building an
upper story to the female ward.

Department	Date	G.O.	No.	By

FURTHER PAPERS.

Department	Date	G.O.	No.	Department

[G]
[+]
*100-15-5-05.

NOTE FOR THE CHIEF SECRETARY.

Thereby to the
H.M.'s query is - because
the f.d. is at variance
with the Audt. the
H.M. passed the latter
& not the former.


As H.M. has seen
the paper nothing
further is needed.

Handwritten notes and signatures, including "3013" and "9/4/11".

Handwritten notes in Tamil script, including "செய்து" and "செய்யப்படும்".

BUILDINGS AND ROADS.
CIVIL WORKS.

Government {1896} of Madras.
PUBLIC WORKS.



Recd. 2-12- } 1896.
Regd. 2-12- }

Enclosures

Spare copies - 6 (not used)

G.O., No. 3302 W., 18th November 1896.

NOVEMBER. .

H.M. No 1307 of 11-12-96
Coupa to the
Surgeon General

30/11
5/12/96
7.12.96

Government Leper Hospital, Madras.

Returning to the Consulting Architect, for report on certain point, an estimate of Rs. 7,190 for building an upper story to female ward at the —, and sanctioning the estimate of Rs. 2,700 for constructing a laundry in the hospital.

GOVERNMENT OF MADRAS.

PUBLIC WORKS DEPARTMENT.

Buildings and Roads.
Civil Works.

READ—the following papers :—

From the Consulting Architect to Government, dated 7th September 1896, No. 2974.

From Surgeon-Colonel D. F. BATEMAN, Acting Surgeon General with the Government of Madras, to the Chief Secretary to Government, dated 21st September 1896, No. 411.

I have the honour to submit, for the sanction of Government, the accompanying plans and estimates for the erection of an upper story to the European female ward to accommodate native females and a laundry in the Government Leper Hospital, Madras, at an estimated cost of Rs. 7,190 and 2,671, respectively.

2. In my letter, No. 569, dated 19th December 1895, I forwarded a list of these works in addition to those proposed to be carried out during the current year, and they appear in class I-B of the Final issue of the Public Works Department budget communicated to this office in endorsement order, No. 537, dated 16th May 1896. The works are absolutely necessary—the former to prevent the great over-crowding which at present exists in the institution; and as regards the latter the washing at present is conducted in a small ill-ventilated building which was formerly a bath-room attached to a latrine, and as it is most advisable that a leper institution should have its own laundry, this work is one that is urgently required.

No. 2012, Public.

Approved and transferred to the Public Works Department.

OOTACAMUND,
5th October 1896.(Signed) A. T. ARUNDEL,
Ag. Chief Secretary.

Note by the Chief Engineer, Public Works Department.

Upper Story to Female Ward.—It is not considered safe to construct an upper story over foundations so slight as those existing, particularly as the soil is shown as sandy clay; and the weakness of these foundations is accentuated by the fact that more substantial foundations are allowed for the Leper Hospital laundry where the walls proposed are only 13 feet high, whereas those of the female ward would be 30 feet above basement. Therefore, this portion of the estimate should be abandoned unless the Consulting Architect can give good reasons for the foundations being sufficient.

Laundry in the Government Leper Hospital.—The corrugated iron roof over the boiler is too low. The headway should be altered from 5 feet to 6 feet. To provide for this alteration, the estimate is raised to Rs. 2,700.

11th November 1896. (Signed) D. McNEIL CAMPBELL, Col. R.E.,
Chief Engineer.

ORDER—No. 3302 W., dated 18th November 1896.

With the papers recorded above, the undermentioned estimates in connection with the Government Leper Hospital at Madras have been received :—

	RS.
(a) Building an upper story to female ward	7,190
(b) Constructing a laundry	2,671

The estimate for item (a) is returned to the Consulting Architect for report on the point raised by the Chief Engineer in paragraph 1 of his note quoted above. The estimate for item (b) has been raised to Rs. 2,700 by the Chief Engineer and is sanctioned for the altered amount.

2. The Consulting Architect will report the amount that can be spent on the latter work during the current year.

3. The sanction accorded in paragraph 1 has been registered as Provincial No. 111 W. of 1896-97, and classified as Civil Buildings—Original Works.

(True Extract.)

Under Secretary to Government.

To the Consulting Architect to Government, with ~~seven~~ enclosures.
" Examiner, Public Works Accounts.
" Public Department.

Exd. T. K. Narayana Aiyangar.

Public (1896) Department.

CURRENT No. 3123.

From The Surgeon-General

Order

Contd. no. 20127 5-10-96.

No. 441.

Approved and
transferred to the
Public Works Depart-
ment

Dated 21st
Received 23rd
Registered 24th
Enclosures 10.
Spare copies 1
} September
1896

SUBJECT.

Submitting for sanction
of Govt. plans & estimate
for the erection of an
upper storey to the
European female ward
the accommodate native
females & a laundry
the Govt. Lepet Hospital
Madras.

BACK PAPERS.

G.O.	No.	Department.	Date.
	537	Pul	16/5/6
	240	"	18/2/6

FURTHER PAPERS.

G.O.	No.	Department.	Date.

[G.
25 A.]
1,000-21-3-90.

Public DEPARTMENT

C. No. 3/23

Proposed additions to the foot-leper Hospital, Madras

FOR ORDERS.

Hon^{ble} Mr. H. C. S. S. S. S.

I w^d sanction these
proposals

By
1/10/90

The Surgeon General submits plans and estimates for the erection of (1) an upper storey to the European female ward at the foot-leper Hospital, Madras to accommodate native females, and (2) a laundries for that institution. The estimate amount to Rs 7,190 and Rs 2,671 respectively, giving a total of Rs 9,861.

Surgeon Genl. Bateman states that the works are absolutely necessary, the first to prevent the great and undesirable ^{over}crowding that exists at present, and the second as washing is now done in a small ill-ventilated building adjoining a latrine & once a bathroom.

It seems very desirable that a properly constructed

laundry should be provided.
If the upper storey is saved.
it is submitted that the
Europeans may occupy
it and the native females
be accommodated downstairs

FOR ORDERS.

5/3
9.9.6. When are funds
to come from?

At 29.9.96
The P. W. D. will provide.
It has plenty (it has
been ascertained).

5/3
29.9.6
The buildings will be useful
if funds are available At
30.9.96.

H. E. THE GOVERNOR.

THE HON'BLE MR. H. W. BLISS, C.I.E.

THE HON'BLE MR. J. GROSE, C.I.E.