M.R.O. 14—13,000—27-9-24.

MADRAS RECORD OFFICE.

Government of Madras.

Revenue DEPARTMENT.

G.O. No. 2171 Press ~~Mis.~~

15-16

Dated 1-12-~~19~~1863

Not to be folded or roughly handled

Proceedings of the Madras Government, Revenue Department, 1st December 1863.

No. 15. Read the following letter from Lieutenant-Colonel A. J. M. BOILEAU, R. E., Superintending Engineer, 4th Division, to Colonel C. A. ORR, R. E., Secretary to Government, Public Works Department, dated Madras, 23rd November 1863, No. 3,538:—

SIR,

1. I have the honor to request that I may be permitted to sanction for execution from the balance remaining of the Budget allotment for repairs, "Military," "Staff," the accompanying Estimate amounting to Rupees 365, for building up pillars to support the centres of the beams of the Sea Custom House verandah at the Presidency, the full allotment for repairs to "Revenue" buildings having been availed of.

"Military," "Staff."

	Rs.
Allotment	4,750
Availed of	1,699
Remaining ...	3,051

ENCLOSURE.

1 Abstract Estimate.

2. The beams in question have sagged very much, and the roof leaks in many places, and it would not be safe to put off the execution of the proposed work till next year.

Referred to the Revenue Department, with the suggestion that instead of heavy masonry pillars, light ornamental hollow cast-iron columns may be obtained from the Foundry at the Mint.

Chepauk,
26th November 1863.

(Signed) C. A. ORR, Colonel, R. E.,
Secretary to Government, P. W. D.

No. 16. ORDER THEREON, 1st December 1863, No. 2,171.

The substitution of hollow iron pillars is approved.

(True Extract.)

(Signed) J. D. SIM,
Secretary to Government.

To the Board of Revenue.
,, Department Public Works.

Exd. S. T. Augustin.

Referred to the
Revenue Department with
the suggestion that instead of
heavy masonry pillars light
ornamental hollow cast
iron columns may be
obtained from the
Foundry at the
Mint.

Asstt Sec. to Govt
Secretary to Govt
Pub Works Dept

Chd Asstt
26 Nov 63
x 282 W 2471 VII
The substitution of
hollow iron pillars is
approved. JP
1st Decr
1863
28 Nov 63

Dept
Rec'd from Govt for
The Supt Engr 4th Dn

To The Secretary to Govt
C. W. D

Dated 23 November
Recd 1863
2nd
Cl Asst No. 3538

Requests to sanction for
Carrying out the accom:
Surveying Estimate Rs 365
for Building up Pillars
to support the centre in
the Beams of the sea
Custom House Verandah.

No 2471- 1st Asst

With an order

14 copies to Asst Sec to Govt Pub Works Dept
21 " " Supt Engr 4th Dn